

SCHEME OF VALUATION

(Scoring Indicators)

Revision - 2015

Course Code - 6023

Course Title - Refrigeration and Airconditioning

Qst No:	Scoring Indicator	Split UP Score	Sub Total	Total
<u>PART-A</u>				
I	<p>1) The heat absorbed or rejected by a substance, which causes change of state (Phase change) with no change in temperature.</p> <p>2) Trap liquid particles if present in vapour refrigerant leaving the evaporator</p> <p>3) Refrigerants which do not take part directly in refrigeration system and absorb heat in the form of sensible heat</p> <p>4) Air which contains maximum amount of water vapour that it can hold at a particular temperature.</p> <p>5) i) comfort air conditioning ii) Industrial - air conditioning</p>	2 2 2 2 2	10	
II	<p>Refrigerator</p> <p>Heat Pump</p>	1 1/2 + 1 1/2		

A refrigerator works between cold body temp. and Atmospheric temp and its function is to maintain temperature of cold body lower than atmospheric temperature.

1/2

6

A heat pump works between Hot-body temp. and atmospheric temp. and its function is to maintain hot body temp. higher than atmospheric temperature.

1/2

2) Vapour Compression System

Vapour Absorption System


- | | |
|--|--|
| i) Work Operated system | i) Heat Heat Operated System |
| ii) Compressor is required | ii) Compressor is not required |
| iii) Single fluid system | iii) multi fluid system |
| iv) Charging is simple | iv) charging is difficult |
| v) Leakage tendency is more | v) Less leakage tendency |
| vi) Poor Part load performance | vi) Good Part load - Performance |
| vii) High COP | vii) Low COP |
| viii) System is compact | viii) System is Bulky |
| ix) Maintenance Cost is more | ix) Maintenance cost is less. |
| x) Capacity of the system drops drastically at lower evaporator pressure | x) System can operate at lower evaporator pressure |

1x6

6

Any six

3) It consists of two concentric cylindrical tubes one inside the other. cold water is circulated through inner tubes while hot refrigerant flows in opposite



Double tube Condenser

direction to that of water in the space between inner and outer tubes. In this way certain air cooling effect is also obtained besides water cooling.


4) i. Dew Point Temperature - It is the temperature of air recorded by a thermometer, when the moisture present in it begins to condense.

ii) Absolute humidity - It is the mass of water vapour present in 1m^3 of dry air, and is generally expressed in kg/m^3 of dry air.

iii) Relative humidity - It is the ratio of mass of water vapour present in 1m^3 of given volume of moist air to the mass of water vapour present in same volume of saturated air, at same temperature.

5) Heating and humidification - Heating the air and adding moisture simultaneously is called Heating and humidification. This process is generally used in winter air conditioning. It is done by passing air through a humidifier having spray water temperature higher than

the dry bulb temperature of the entering air, the unsaturated air will reach the condition of saturation and thus the air becomes hot.



1-2: Heating
2-3: Humidification
1-3: Total Process

— DBT —→

Heating & Humidification

6) i) Dry Bulb Temperature

ii) Relative Humidity

iii) Air Velocity

iv) Quality and Quantity of air

v) Hot and Cold surfaces in conditioned space


vi) Air stratification

vii) Heat production and regulation in human body

viii) Heat and moisture losses from human body

(any size)


7) It involves cooling and dehumidification



SUMMER A.C SYSTEM

Filtered outside atmospheric air is passed over a cooling coil, whose effective surface temperature is lower than dew point temperature of entering air. During this process air gets cooled and moisture in it is condensed there by dehumidifying.

III



Isentropic Compression (1-2) - There is no heat transfer

Isothermal Compression (2-3) - Heat rejected/kg

$$\begin{aligned} \text{of air} &= \text{Area } 2-3-3'-2' \\ &= T_2 (s_2 - s_3) \end{aligned}$$

Isentropic Expansion (3-4) - There is no heat transfer

Isothermal expansion (4-1) - Heat absorbed/kg of

$$\begin{aligned} \text{air} &= \text{Area } 1-4-3'-2' \\ &= T_1 (s_1 - s_4) \\ &= T_1 (s_2 - s_3) \end{aligned} \quad \left| \begin{array}{l} s_1 = s_2 \\ s_3 = s_4 \end{array} \right.$$


Work done/kg of air = Heat rejected - Heat absorbed

$$= T_2 (s_2 - s_3) - T_1 (s_2 - s_3)$$

$$\text{COP} = \frac{\text{Heat absorbed}}{\text{Work done}} = \frac{T_1 (s_2 - s_3)}{T_2 (s_2 - s_3) - T_1 (s_2 - s_3)}$$

where, T_1 = Lowest temp. in the cycle
 T_2 = Highest temp. in the cycle.

$$= \frac{T_1}{T_2 - T_1}$$



$$\begin{aligned} T_1 &= -5^\circ\text{C} \\ T_2 &= 151.8^\circ\text{C} \\ T_3 &= 15^\circ\text{C} \\ T_4 &= -53^\circ\text{C} \end{aligned}$$

$$\begin{aligned} \text{Compressor work / kg of air} &= \frac{\gamma}{\gamma-1} R (T_2 - T_1) \\ &= \frac{1.4 \times 0.287 (151.8 - (-5))}{0.4} \\ &= 157.5 \text{ kJ/kg} \end{aligned}$$

$$\begin{aligned} \text{Expander work / kg of air} &= \frac{n}{n-1} R (T_3 - T_4) \\ &= \frac{1.2 \times 0.287 (15 + 53)}{0.2} \\ &= 117.1 \text{ kJ/kg} \end{aligned}$$

$$\begin{aligned} \text{Net work done / kg on the air} &= \text{Compressor work} - \text{Expander work} \\ &= 157.5 - 117.1 \\ &= 40.4 \text{ kJ/kg} \end{aligned}$$

$$\begin{aligned} \text{COP} &= \frac{\text{Heat absorbed}}{\text{Net work done}} \\ &= \frac{C_p (T_1 - T_4)}{40.4} = \frac{1 (-5 + 53)}{40.4} \\ &= 1.18 \end{aligned}$$


IV a) In Open air refrigeration cycle, the air is directly led to the space to be cooled, allowed to circulate through the cooler and sucked by the compressor. In this air comes in direct contact with the space to be cooled (ie, refrigerator)

In closed air refrigeration cycle, the air is passed through pipes and component parts of the system and the air does not come in direct contact with the space to be cooled. The air is used to absorb heat from other fluids like brine and cold brine is circulated through the space to be cooled.


Advantages of closed cycle over open cycle

- i) The moisture is not carried by air
- ii) Since it can work at a suction pressure higher than atmospheric, the volume of air handled by compressor and expander are less
- iii) Operating pressure ratio is less and hence COP is higher

b)



T-s diagram



p-h diagram

Heat absorbed = $h_1 - h_4$

$$h_1 - h_4 = (1433.05 - 135.37)(x_1 - x_4)$$

$$= 1297.68 \times 0.87$$

$$= 1129 \text{ kJ/kg}$$

$$h_2 = h_{21} + (C_{p,v} \times 30)$$


$$= 1465.84 + (2.8 \times 30)$$

$$= 1549.84 \text{ kJ/kg}$$

$$\begin{aligned} \text{COP} &= \frac{h_1 - h_4}{h_2 - h_1} \\ &= \frac{1129}{1549.84 - 1394.12} \\ &= \frac{1129}{155.72} \\ &= \underline{\underline{7.25}} \end{aligned}$$

$$\begin{aligned} h_{fg1} &= 1433.05 - 135.37 \\ h_1 &= h_{f1} + (x_1 \times h_{fg1}) \\ &= 135.37 + (0.97 \times 1297.68) \\ &= 1394.12 \text{ KJ/kg} \end{aligned}$$

V a)



P_s - Spring Pressure

P_e - Evaporator Pressure

Automatic expansion Valve


It maintains constant evaporator pressure regardless of the load on the evaporator. The opening and closing of the valve depends upon the spring pressure (P_s) and evaporator pressure (P_e). When load on evaporator increases, evaporator pressure reduces, the valve opens more till desired evaporator pressure is reached. When load on the evaporator reduces, the evaporator pressure increases and closes the valve more, till the desired evaporator pressure is reached.

b) It employs vapour absorption refrigeration system with three fluids.

Ammonia as refrigerant

Water as absorbent and

Hydrogen as pumping agent



Electrolux Refrigerator

Ammonia circuit - Refrigerant ammonia is circulated through generator & condenser only. Ammonia vapour generated in generator is condensed in condenser. The liquid ammonia and hydrogen enters evaporator and ammonia evaporates by absorbing heat. The mixture of ammonia vapour and hydrogen enters the absorber.

Water circuit - Water separated out from ammonia vapour in separator flows down to generator and acts as absorbent and absorbs ammonia.

Hydrogen circuit - Hydrogen is liberated from condenser absorber and enters the evaporator along with liquid ammonia and promotes evaporation of ammonia.

VI

a) Freeze drying - The actual process during freeze drying is dehydration by sublimation and it is a modern food preservation method. It involves the following stages.


i) Initial freezing - The food stuff is frozen to a temperature of around -60°C

ii) Drying - The frozen products are taken to a high vacuum drying chamber, where heat is supplied to remove ice crystals formed. The ice crystals directly changes to vapour

iii) Water vapour removal - Enormous amount of water vapour is removed by condensation using refrigerator coils and ice crystals formed are removed by heating with steam.

iv) Storage and Packing - The packing is done either in vacuum or in presence of inert gases. Generally nitrogen is used.


b)



It employs Vapour Compression refrigeration system and evaporator coil is wrapped around storage tank. The refrigerant abstracts heat from water and evaporates. Water is cooled to about 7 to 13°C. The vapour refrigerant is then sucked by compressor and compressed to high pr. and delivers it to aircooled condenser. Here vapour ref. is condensed to liquid and passes through capillary tube through a strainer. In heat exchanger the refrigerant loses its heat to suction vapour to compressor. In capillary tube the high pr. liquid ref. expands and low pr. liquid ref. circulates through evaporator coil.

VII

a)



From Psychrometric chart

Specific volume at initial -
Condition (V_{s1}) = $0.8806 \text{ m}^3/\text{kg}$

sp. enthalpy at initial condition (h_1) = 71 kJ/kg


sp. enthalpy at final condition (h_2) = 50 kJ/kg

$$\text{Mass of air } (m) = \frac{120}{V_{s1}} = \frac{120}{0.8806} = 136.27 \text{ kg/min}$$

$$\begin{aligned} \text{Ref. effect to be produced} &= m (h_1 - h_2) \\ &= 136.27 (71 - 50) \\ &= 2861.67 \text{ kJ/min} \end{aligned}$$

$$\therefore \text{TR required} = \frac{2861.67}{210} = \underline{\underline{13.63 \text{ TR}}} \quad \left| \text{TR} = 210 \text{ kJ/min} \right.$$

b)



Bypass Factor

Balancing enthalpies

$$x \cdot C_{p_m} \cdot t_{d1} + (1-x) C_{p_m} \cdot t_{d3} = 1 \times C_{p_m} \times t_{d2}$$


$$x(t_{d3} - t_{d1}) = t_{d3} - t_{d2}$$

$$\text{BPF (or)} = \frac{t_{d3} - t_{d2}}{t_{d3} - t_{d1}}$$

1-BPF is known as efficiency


$$\begin{aligned} \eta_H &= 1 - \frac{t_{d3} - t_{d2}}{t_{d3} - t_{d1}} \\ &= \frac{t_{d2} - t_{d1}}{t_{d3} - t_{d1}} \end{aligned}$$

VIII



Hydrogen Liquefaction

Pure hydrogen gas at a pressure of 100 atm and 27°C from compressor is pre-cooled in two heat exchangers A and B. In HEA, the hydrogen^(incoming) is cooled by low pr. outgoing hydrogen and in HE(B) it is cooled by nitrogen. Then the high pressure pre-cooled hydrogen is passed through HE(C) where it is further cooled to -207°C by liquid nitrogen. The hydrogen is again cooled to -230°C in HE(II) by low pr. hydrogen returning from separator. The liquid hydrogen is produced by throttling hydrogen gas from HE(II) to atmospheric pressure.



Sp. humidity of mixture (w_3) = $\frac{m_1 w_1 + m_2 w_2}{m_3}$

Mass of mixture (m_3) = $m_1 + m_2$
= $900 + 100 = 1000 \text{ kg/hr.}$

$\therefore w_3 = \frac{900 \times 11.1 + 100 \times 13.7}{1000} = 11.36 \text{ gm/kg}$

Enthalpy of mixture (h_3) = $\frac{m_1 h_1 + m_2 h_2}{m_3}$
= $\frac{900 \times 53 + 100 \times 76}{1000}$
= 55.3 kJ/kg

Psych. chart - 2
1 x 6 = 6
8 15

IX

a) Room Volume = $21 \times 11 \times 5 = 1155 \text{ m}^3$

Volume of fresh air infiltrated/hr = 1155×0.5
= $577.5 \text{ m}^3/\text{hr}$

Density of air (ρ) = $\frac{P}{RT}$
= $\frac{1.0132 \times 10^5}{0.287 \times 313} = 1.128 \text{ kg/m}^3$

Mass of air infiltrated/hr (m_a) = Volume \times Density
= $577.5 \times 1.128 = 651.42 \text{ kg/hr}$


Infiltrated heat load/hr = $m_a \times C_{p, \text{air}} \times \Delta t = 651.42 \times 1 \times (40 - 20)$
= 13028.4 kJ/hr

2 7

1 1/2

1 1/2

b)



- E - Expn. Valve
- ER - Evaporator
- M - Motor
- CF - Condenser Fan
- EF - Evaporator Fan
- F - Filter
- AGI - Adjustable Grill
- C - Compressor
- CR - Condenser

Window Type Air Conditioner

It mainly consists of a vapour compression refrigeration system and is divided into two units. It is installed in window sill.

The two units are indoor unit and outdoor unit. Expansion valve and evaporator of vapour compression system are housed inside the room where as compressor and condenser are placed outside. A motor drives both condenser and evaporator fan. Condenser fan is axial while evaporator fan is of radial type.

Evaporator fan draws warm air from room through filter and evaporator. This air gets cooled while flowing over evaporator coil and is delivered back into room through adjustable grill. The condenser fan sucks atmospheric air and forces over condenser. The air cools and condenses the refrigerant vapour.

X a) i. Sensible heat gain


- By conduction through exterior walls, floors, ceiling, doors and windows.

- Heat received from solar radiation
- Heat given off by lights, motors, machinery, cooking operations, industrial process etc.
- Heat liberated by occupants
- Infiltrated heat load

ii) Latent heat gain

- heat gain due to moisture in outside air
- heat gain due to condensation of moisture from occupants
- heat gain due to condensation of moisture from any process such as cooking
- heat gain due to moisture passing directly into the conditioned space through permeable walls or partitions

b)



Central A.C. System

All components of A.C. system are grouped together in Plant room. Conditioned air is distributed from plant room to required places through ducts. This system is adopted for large capacity plants (25 TR and above)

Chiller is a cylindrical vessel in which cold refrigerant absorbs heat from water under circulation. Chilled water is then circulated through coils placed in an air chamber. Foul air coming from other rooms is passed over these coils. Chilled water absorbs heat from this air and cools it. Water return to chiller and cold air is distributed to rooms to be conditioned.

8

4