

3-5 Inspection before Wiring

3-5-1 Check the Insulation Resistor before Wiring

3-5-2 When to Check the Insulation Resistor

Insulation resistor measurement provides information of motor safety. Check the insulation resistor at the following time:

- Before first start-up of the motor
- After a long-term of storage or after the motor stops
- When performing motor maintenance

From the above inspection, you can check the following status of the insulation resistor:

- Is the insulation layer at the end of the winding contaminated with conductive dirt
- Whether the winding insulation layer is damp

Based on the above status inspection, you can decide whether to commission the motor or to take necessary treatments, such as cleaning or drying the windings:

- Whether the motor can run
- Cleaning or drying measures are required

3-5-3 First Check after Installation or Maintenance

Check the following items when the motor runs for about 5000 hours or at the latest after one year:

- Whether the motor operation complies with the electrical characteristic parameters
- If the motor is running above the allowable temperature of the coil
- Whether the motor runs smoothly and the motor noise does not get worse
- Is the motor appearance intact without cracks

If any problem is discovered during the inspection, it must be resolved promptly to avoid damage to the motor.

3-5-4 Routine Inspection

The following inspections are required after the motor has been running for about 16000 hours or at the latest after two years:

- Whether the motor installation and fixation meet the requirements
- Whether the motor operation complies with the electrical characteristic parameters
- If the motor is running above the allowable temperature of the coil
- Whether the motor runs smoothly and the motor noise does not get worse
- Is the motor appearance intact without cracks
- The motor centering is within the allowable tolerance range
- Are all mechanical and electrical fasteners tightened
- If the cables and insulation components are in good condition and have not discoloration