

For the definition of Output Dry Contact Signals interface, please refer to **Table 2-6**.

Table 2-6: The Definition of Output Dry Contact Signals Interface

Item	Pin No	Signal	Electrical Character		Function
OUTPUT (Dry Contacts)	1	RUN-A	250 Vac/ 30 Vdc	2.5A	Run state (PM Run, Close)
	2	RUN-B	250 Vac/ 30 Vdc	2.5A	
	3	FAULT-A	250 Vac/ 30 Vdc	2.5A	Fault state (PM Fault, Close)
	4	FAULT-B	250 Vac/ 30 Vdc	2.5A	
	5	FAN-A	250 Vac/ 30 Vdc	2.5A	Fan control (Fan ON, Close; Fan OFF, Open)
	6	FAN-B	250 Vac/ 30 Vdc	2.5A	

For the definition of Input Wet Contact Signals interface, please refer to **Table 2-7**.

Table 2-7: The Definition of Input Wet Contact Signals Interface

Item	Pin No	Signal	Electrical Character		Function
INPUT (Wet Contacts)	1	EPO-2	24V	10 mA	System EPO (Close, Enable Open, Disable)
	2	EPO-1	24V	10 mA	
	3	SPD-A	24V	10 mA	System SPD (Close, SPD Fault Open, NO Fault)
	4	SPD-B	24V	10 mA	
	5	ON/OFF-A	24V	10 mA	PM Turn ON/OFF (Close, Turn ON Open, Turn OFF)
	6	ON/OFF-B	24V	10 mA	