

APF Capacity	Recommended Protection Device Model
30A	Schneider NSX100H TM50D 3P3D (690V 50A)
50A	Schneider NSX100H TM80D 3P3D (690V 80A)
75A	Schneider NSX160H TM125D 3P3D (690V 125A)
100A	Schneider NSX160H TM160D 3P3D (690V 160A)
150A	Schneider NSX250H TM250D 3P3D (690V 250A)

- The short circuit parameters of the APF are as follows:

APF Capacity	Conditional Short Circuit Current (Icc)	Prospective Short Circuit Current for the Minimum Demand (Icp,mr)	Short Circuit Protection Device (SCPD)
30A	20 kA	2.5 kA	80A Fuse *2 Type: BUSSMANN 80FE
50A	20 kA	2.5 kA	80A Fuse *2 Type: BUSSMANN 80FE
75A	20 kA	2.5 kA	80A Fuse *2 Type: BUSSMANN 80FE
100A	20 kA	5 kA	160A Fuse *2 Type: HINODE 660GH-160
150A	20 kA	5 kA	160A Fuse *2 Type: HINODE 660GH-160

- The three-phase, four-wire APF is applicable to the power grid system with neutral grounding.
- The CT wiring shall be fastened to avoid open circuit, which will lead to high-voltage risk and secondary circuit burning.

1.3 Usage Warnings

- Only qualified service personnel can update APF hardware and firmware.
- Since the APF is used for harmonic compensation of the power grid, the capacity selection of the APF shall be subject to harmonic content to avoid poor compensation due to insufficient capacity.
- Before installation, wiring and working on the APF's internal circuits, please completely cut off all power supplying to the APF.