

For the definition of Input Wet Contact Signals interface, please refer to **Table 2-7**.

Table 2-7: The Definition of Input Wet Contact Signals Interface

Item	Pin No	Signal	Electrical Character		Function
INPUT (Wet Contacts)	1	EPO-2	24V	10 mA	System EPO (Close, Enable Open, Disable)
	2	EPO-1	24V	10 mA	
	3	SPD-A	24V	10 mA	System SPD (Close, SPD Fault Open, NO Fault)
	4	SPD-B	24V	10 mA	
INPUT (Wet Contacts)	5	ON/OFF-A	24V	10 mA	PM Turn ON/OFF (Close, Turn ON Open, Turn OFF)
	6	ON/OFF-B	24V	10 mA	

For the definition of EXTERNAL (Communication Terminals) interface, please refer to **Table 2-8**.

Table 2-8: The Definition of EXTERNAL (Communication Terminals) Interface

Item	Pin No	Signal	Function
EXTERNAL (Communication Terminals)	1	PE	PE
	2	RS485A	Outer RS485 using
	3	RS485B	
	4	Reserved	Internal using
	5	Reserved	Internal using
	6	GF2	RS485 signal ground