

● AMB. TEMP PROBE Port:

Ambient Temperature ^{*5}	ADU Status
< 20°C	1. All fans turn on. 2. Fan-status LED indicator: Off 3. Min. fan speed (Duty cycle: 20%)
20°C~25°C	1. All fans turn on. 2. Fan-status LED indicator: Off 3. Fan speed varies according to the ambient temperature (Duty cycle: 100% at 25°C).
25°C~50°C	1. All fans turn on. 2. Fan-status LED indicator: Off 3. The temperature alarm goes off. The actual alarm depends on user's application of dry contact (Pin 2) ^{*6}. 4. Max. fan speed (Duty cycle: 100%)
> 50°C	1. All fans automatically turn off. 2. Fan-status LED indicator: Red 3. The temperature, fan, and high-temperature alarms go off. The actual alarms depend on user's application of dry contact (Pin 2, Pin 3 & Pin 4) ^{*6}.

^{*5}: The operating temperature is 20°C~25°C under one condition when the ambient temperature > the source temperature.

^{*6}: Please see **Chapter 4** for dry contact information.