

- Since APF is used for harmonics mitigation, external CT shall be connected to detect the harmonic currents.
- To guarantee sound reliability and avoid overheating, do not block or cover the air inlet and outlet.
- The thermal loss of Mixed Fixed type APF is not bigger than 3% of rated apparent power. Rated APF power is $V_{\text{phase}} \cdot I_{\text{rated}} \cdot 3$ or $V_{\text{line}} \cdot I_{\text{rated}} \cdot \sqrt{3}$.
- The operating environment temperature of APF should be between -10°C (14°F) and 55°C (131°F). The relative humidity shall be within 95% (non-condensing). For detailed derating information, please refer to 2.3 Functions & Features.
- The APF system shall be installed at a place with altitude less or equal to 1000 m (3280 ft). Derating 1% per 100 m (328 ft) when the altitude is between 1000 m and 3000 m (3280 ft ~ 9842 ft). For more question, please consult Delta or Delta distributor.
- Before applying electric power to the APF, you must allow the APF to adjust to room temperature (20°C ~ 25°C (68°F ~ 77°F)) for at least one hour and ensure that there is no moisture condensing inside the unit.
- Do not put beverages on the APF or any other accessory associated with the APF.
- Do not open or remove the covers or panels of the APF to avoid high-voltage electric shock. Only authorized Delta engineers or service personnel can do so for installation or maintenance. If you want to open or remove the covers or panels, do it only under the supervision of authorized Delta engineers or service personnel.
- Some components like fans will become worn-out due to long-term usage, and this will increase the risk of APF failure. To replace and maintain the components, please contact Delta service personnel.
- The APF complies with the regulations of Overvoltage Category III in IEC 62477. It is suggested that appropriate surge voltage protection devices shall be chosen in accordance with the actual power system type. If appropriate protection devices are not used, the surge voltage may exceed the APF's capacity and cause APF damage. If you are uncertain regarding the APF's application, please contact Delta service personnel.

Wiring System	Recommended Model	Main Technology Indicator
3P3W	Sichuan Zhongguang Lightning ZGG40-385 (3+0) Ar	Nominal Operating Voltage U_o : 230V AC Max. Continuous Operating Voltage U_c : 385V AC Rated Discharge Current I_n : 20 kA
3P4W	Sichuan Zhongguang Lightning ZGG40-385 (3+1) r	Max. Discharge Current I_{max} : 40 kA Voltage Protection Level U_p : 1.8 kV