

**NOTE:**

1. Except for the input and output ports, other terminals are insulated. Contacting these terminals will not cause the risk of electric shock.
2. Specifications of the input and output ports are as follows.

No.	Port Definition	Port Specs
①	OUTPUT (Dry contacts)	250Vac/ 30Vdc, 2.5A
②	INPUT (NTC)	$R_{25} = 10\text{kohm}$, $B_{25/85} = 3435$, $\pm 1\%$
③	INPUT (Except for NTC)	24V, 10mA

For the definition of Output Dry Contact Signals interface, please refer to **Table 2-2**.

Table 2-2: The Definition of Output Dry Contact Signals Interface

Item	Pin No	Signal	Electrical Character		Function
OUTPUT (Dry Contacts)	1	RUN-A	250 Vac/ 30 Vdc	2.5A	Run state (PM Run, Close)
	2	RUN-B	250 Vac/ 30 Vdc	2.5A	
	3	FAULT-A	250 Vac/ 30 Vdc	2.5A	Fault state (PM Fault, Close)
	4	FAULT-B	250 Vac/ 30 Vdc	2.5A	
	5	FAN-A	250 Vac/ 30 Vdc	2.5A	Fan control (Fan ON, Close; Fan OFF, Open)
	6	FAN-B	250 Vac/ 30 Vdc	2.5A	

For the definition of Input Wet Contact Signals interface, please refer to **Table 2-3**.

Table 2-3: The Definition of Input Wet Contact Signals Interface

Item	Pin No	Signal	Electrical Character		Function
INPUT (Wet Contacts)	1	NTC-A	NA	NA	Cabinet's ambient NTC
	2	NTC-B	NA	NA	
	3	EPO-2	24V	10 mA	System EPO (Close, Enable Open, Disable)
	4	EPO-1	24V	10 mA	