

No.	Item	Description
①	RTU	RTU communication ports.
②	USB1 USB2	The USB communication ports.
③	LAN	The standard Ethernet port for the communication with the master computer.
④	EXTERNAL (Communication Terminals)	For the external RS485 and RS232 signals and the communication with the master computer.



NOTE:

1. Except for the dry contacts and wet contacts, other terminals are insulated. Contacting these terminals will not cause the risk of electric shock.
2. Specifications of the dry contacts and wet contacts are as follows.

No.	Item	Description
①	OUTPUT (Dry Contacts)	250Vac/ 30Vdc, 2.5A
②	INPUT (Wet Contacts)	24V, 10mA

For the definition of Output Dry Contact Signals interface, please refer to **Table 2-6**.

Table 2-6: The Definition of Output Dry Contact Signals Interface

Item	Pin No	Signal	Electrical Character		Function
OUTPUT (Dry Contacts)	1	RUN-A	250 Vac/ 30 Vdc	2.5A	Run state (PM Run, Close)
	2	RUN-B	250 Vac/ 30 Vdc	2.5A	
	3	FAULT-A	250 Vac/ 30 Vdc	2.5A	Fault state (PM Fault, Close)
	4	FAULT-B	250 Vac/ 30 Vdc	2.5A	
	5	FAN-A	250 Vac/ 30 Vdc	2.5A	Fan control (Fan ON, Close; Fan OFF, Open)
	6	FAN-B	250 Vac/ 30 Vdc	2.5A	