

3/4.4 REACTOR COOLANT SYSTEM

3/4.4.1 REACTOR COOLANT LOOPS AND COOLANT CIRCULATION

STARTUP AND POWER OPERATION

LIMITING CONDITION FOR OPERATION

3.4.1.1 All reactor coolant loops shall be in operation.

APPLICABILITY: MODES 1 and 2.*

ACTION:

With less than the above required reactor coolant loops in operation, be in at least HOT STANDBY within 1 hour.

SURVEILLANCE REQUIREMENT

4.4.1.1 The above required reactor coolant loops shall be verified to be in operation and circulating reactor coolant in accordance with the Surveillance Frequency Control Program.

*See Special Test Exception 3.10.4.

REACTOR COOLANT SYSTEM

HOT STANDBY

LIMITING CONDITION FOR OPERATION

- 3.4.1.2 a. At least two of the reactor coolant loops listed below shall be OPERABLE:
1. Reactor Coolant Loop 21 and its associated steam generator and reactor coolant pump,
 2. Reactor Coolant Loop 22 and its associated steam generator and reactor coolant pump,
 3. Reactor Coolant Loop 23 and its associated steam generator and reactor coolant pump,
 4. Reactor Coolant Loop 24 and its associated steam generator and reactor coolant pump.
- b. At least one of the above coolant loops shall be in operation* when the rod control system is deenergized**.
- c. All of the above coolant loops shall be in operation when the rod control system is energized**.

APPLICABILITY: MODE 3

ACTION:

- a. With less than the above required reactor coolant loops OPERABLE, restore the required loops to OPERABLE status within 72 hours or be in HOT SHUTDOWN within the next 12 hours.
- b. With no reactor coolant loop in operation, suspend all operations involving a reduction in boron concentration of the Reactor Coolant System and immediately initiate corrective action to return the required coolant loop to operation.

REACTOR COOLANT SYSTEM

HOT STANDBY

SURVEILLANCE REQUIREMENTS

4.4.1.2.1 At least the above required reactor coolant pumps, if not in operation, shall be determined to be OPERABLE in accordance with the Surveillance Frequency Control Program by verifying correct breaker alignments and indicated power availability.

4.4.1.2.2 At least one cooling loop shall be verified to be in operation and circulating reactor coolant in accordance with the Surveillance Frequency Control Program.

4.4.1.2.3 The required steam generator(s) shall be determined OPERABLE by verifying secondary side water level to be greater than or equal to 5% (narrow range) in accordance with the Surveillance Frequency Control Program.

* All reactor coolant pumps may be de-energized for up to 1 hour provided: (1) no operations are permitted that would cause dilution of the reactor coolant system boron concentration (2) core outlet temperature is maintained at least 10°F below saturation temperature, and (3) the rod control system is de-energized**

** The rod control system shall be considered de-energized when one or more of the following conditions exist:

- 1) Both Rod Drive MG set motor breakers are open.
- 2) Both Rod Drive MG set generator breakers are open.
- 3) A combination of at least three of the Reactor Trip and/or Reactor Trip Bypass Breakers are open.

If none of the above conditions for de-energizing the rod control system are met; the system shall be considered energized.

REACTOR COOLANT SYSTEM

HOT SHUTDOWN

LIMITING CONDITION FOR OPERATION

- 3.4.1.3 a. At least two of the coolant loops listed below shall be OPERABLE:
1. Reactor Coolant Loop 21 and its associated steam generator and reactor coolant pump,*
 2. Reactor Coolant Loop 22 and its associated steam generator and reactor coolant pump,*
 3. Reactor Coolant Loop 23 and its associated steam generator and reactor coolant pump,*
 4. Reactor Coolant Loop 24 and its associated steam generator and reactor coolant pump,*
 5. Residual Heat Removal Loop 21,
 6. Residual Heat Removal Loop 22.
- b. At least one of the above coolant loops shall be in operation.**

APPLICABILITY: MODE 4

ACTION:

- a. With less than the above required loops OPERABLE, immediately initiate corrective action to return the required loops to OPERABLE status as soon as possible; be in COLD SHUTDOWN within 20 hours.
- b. With no coolant loop in operation, suspend all operations involving a reduction in boron concentration of the Reactor Coolant System and immediately initiate corrective action to return the required coolant loop to operation.

* A reactor coolant pump shall not be started with one or more of the RCS cold leg temperatures less than or equal to the POPS enable temperature specified in the PTLR unless 1) the pressurizer water volume is less than 1650 cubic feet (equivalent to approximately 92% of level) or 2) the secondary water temperature of each steam generator is less than 50°F above each of the RCS cold leg temperatures.

** All reactor coolant pumps and residual heat removal pumps may be de-energized for up to 1 hour provided 1) no operations are permitted that would cause dilution of the reactor coolant system boron concentration, and 2) core outlet temperature is maintained at least 10°F below saturation temperature.

REACTOR COOLANT SYSTEM

SURVEILLANCE REQUIREMENTS

4.4.1.3.2 The required reactor coolant pump(s), if not in operation, shall be determined to be OPERABLE in accordance with the Surveillance Frequency Control Program by verifying correct breaker alignments and indicated power availability.

4.4.1.3.3 The required steam generator(s) shall be determined OPERABLE by verifying secondary side water level to be greater than or equal to 5% (narrow range) in accordance with the Surveillance Frequency Control Program.

4.4.1.3.4 At least one coolant loop shall be verified to be in operation and circulating reactor coolant in accordance with the Surveillance Frequency Control Program.

REACTOR COOLANT SYSTEM

COLD SHUTDOWN

LIMITING CONDITION FOR OPERATION

3.4.1.4 Two# residual heat removal loops shall be OPERABLE* and at least one RHR loop shall be in operation.**

APPLICABILITY: MODE 5.##

ACTION:

- a. With less than the above required loops operable, immediately initiate corrective action to return the required loops to OPERABLE status as soon as possible.
- b. With no RHR loop in operation; suspend all operations involving a reduction in boron concentration of the Reactor Coolant System and immediately initiate corrective action to return the required RHR loop to operation.

SURVEILLANCE REQUIREMENTS

4.4.1.4 At least one residual heat removal loop shall be verified to be in operation and circulating reactor coolant in accordance with the Surveillance Frequency Control Program.

One RHR loop may be inoperable for up to two hours for surveillance testing, provided the other RHR loop is OPERABLE and in operation. Additionally, four filled reactor coolant loops, with at least two steam generators with their secondary side water levels greater than or equal to 5% (narrow range), may be substituted for one residual heat removal loop.

A reactor coolant pump shall not be started with one or more of the RCS cold leg temperatures less than or equal to the POPS enable temperature specified in the PTLR unless 1) the pressurizer water volume is less than 1650 cubic feet (equivalent to approximately 92% of level), or 2) the secondary water temperature of each steam generator is less than 50°F above each of the RCS cold leg temperatures.

* Systems supporting RHR loop operability may be excepted as follows:

- a. The normal or emergency power source may be inoperable.

** The residual heat removal pumps may be de-energized for up to 2 hours provided 1) no operations are permitted that would cause dilution of the reactor coolant system boron concentration, and 2) core outlet temperature is maintained at least 10°F below saturation temperature.

THIS PAGE LEFT INTENTIONALLY BLANK

REACTOR COOLANT SYSTEM

3/4.4.2 SAFETY VALVES

SAFETY VALVES - SHUTDOWN

LIMITING CONDITION FOR OPERATION

3.4.2 A minimum of one pressurizer code safety valve shall be OPERABLE* with a lift setting of 2485 psig $\pm$ 3%. **,***

APPLICABILITY: Mode 4 and 5

ACTION:

With no pressurizer code safety valve OPERABLE, immediately suspend all operations involving positive reactivity changes and place an OPERABLE RHR loop into operation in the shutdown cooling mode.

SURVEILLANCE REQUIREMENTS

4.4.2.1 No additional Surveillance Requirements other than those required by the INSERVICE TESTING PROGRAM.

-
- * While in Mode 5, an equivalent size vent pathway may be used provided that the vent pathway is not isolated or sealed.
 - ** The lift setting pressure shall correspond to ambient conditions of the valve at nominal operating temperature and pressure.
 - *** Following testing the lift setting shall be reset to within $\pm$ 1%.

REACTOR COOLANT SYSTEM

3/4.4.3 SAFETY VALVES - OPERATING

LIMITING CONDITION FOR OPERATION

3.4.3 All pressurizer code safety valves shall be OPERABLE with a lift setting of 2485 psig $\pm$ 3%.*,**

APPLICABILITY: MODES 1, 2 and 3.

ACTION:

With one pressurizer code safety valve inoperable, either restore the inoperable valve to OPERABLE status within 15 minutes or be in HOT SHUTDOWN within 12 hours.

SURVEILLANCE REQUIREMENTS

4.4.3 No additional Surveillance Requirements other than those required by the INSERVICE TESTING PROGRAM.

* The lift setting pressure shall correspond to ambient conditions of the valve at nominal operating temperature and pressure.

** Following testing the lift setting shall be reset to $\pm$ 1%.

REACTOR COOLANT SYSTEM

3/4.4.4 PRESSURIZER

LIMITING CONDITION FOR OPERATION

3.4.4 The pressurizer shall be OPERABLE with a water volume of less than or equal to 1650 cubic feet (92% indicated level), and at least two groups of pressurizer heaters each having a capacity of ≥ 150 kw and capable of being powered from an emergency power supply.

APPLICABILITY: MODES 1, 2, and 3.

ACTION:

- a. With the pressurizer inoperable due to an inoperable emergency power supply to the pressurizer heaters either restore the inoperable emergency power supply within 72 hours or be in at least HOT STANDBY within the next 6 hours and in HOT SHUTDOWN within the following 6 hours.
- b. With the pressurizer otherwise inoperable, be in at least HOT STANDBY with the reactor trip breakers open within 6 hours and in HOT SHUTDOWN within the following 6 hours.

SURVEILLANCE REQUIREMENTS

4.4.4.1 The pressurizer water volume shall be determined to be within its limit in accordance with the Surveillance Frequency Control Program.

4.4.4.2 The capacity of each of the above required groups of pressurizer heaters shall be verified by measuring circuit current in accordance with the Surveillance Frequency Control Program.

4.4.4.3 The emergency power supply for the pressurizer heaters shall be demonstrated OPERABLE in accordance with the Surveillance Frequency Control Program by manually transferring power from the normal to the emergency power supply and energizing the heaters.

REACTOR COOLANT SYSTEM

3/4.4.5 RELIEF VALVES

LIMITING CONDITION FOR OPERATION

=====

3.4.5 Two power relief valves (PORVs) and their associated block valves shall be OPERABLE.

APPLICABILITY: MODES 1, 2, and 3.

ACTION:

- a. With one or both PORVs inoperable because of excessive seat leakage, within 1 hour either restore the PORV(s) to OPERABLE status or close the associated block valve(s) with power maintained to the block valve(s); otherwise, be in at least HOT STANDBY within the next 6 hours and in HOT SHUTDOWN within the following 6 hours.
- b. With one PORV inoperable due to causes other than excessive seat leakage, within 1 hour either restore the PORV to OPERABLE status or close its associated block valve and remove power from the block valve; restore the PORV to OPERABLE status within the following 72 hours or be in HOT STANDBY within the next 6 hours and in HOT SHUTDOWN within the following 6 hours.
- c. With both PORVs inoperable due to causes other than excessive seat leakage, within 6 hours either restore at least one PORV to OPERABLE status or close the associated block valves and remove power from the block valves and be in HOT STANDBY within the next 6 hours and in HOT SHUTDOWN within the following 6 hours. Restore the remaining PORV to OPERABLE status within 72 hours from failure of that valve to meet the Limiting Condition for Operation.
- d. With one block valve inoperable, within 1 hour restore the block valve to OPERABLE status or place the associated PORV in manual control; restore the block valve to operable status within 72 hours or be in at least HOT STANDBY within the next 6 hours and in HOT SHUTDOWN within the following 6 hours.
- e. With both block valves inoperable, within 1 hour restore the block valves to OPERABLE status or place the associated PORVs in manual control; restore at least one block valve to OPERABLE status within the next 6 hours or be in at least HOT STANDBY within the next 6 hours and in HOT SHUTDOWN within the following 6 hours. Restore the remaining block valve to OPERABLE status within 72 hours from failure of that valve to meet the Limiting Condition for Operation.

REACTOR COOLANT SYSTEM

3/4.4.5 RELIEF VALVES

SURVEILLANCE REQUIREMENTS

4.4.5.1 In addition to the requirements of the INSERVICE TESTING PROGRAM, each PORV shall be demonstrated OPERABLE in accordance with the Surveillance Frequency Control Program by:

- a. Operating the PORV through one complete cycle of full travel during MODES 3 or 4, and
- b. Operating solenoid valves, air control valves, and check valves on associated air accumulators in PORV control systems through one complete cycle of full travel, and
- c. Performing a CHANNEL CALIBRATION of the actuation instrumentation.

4.4.5.2 Each block valve shall be demonstrated OPERABLE in accordance with the Surveillance Frequency Control Program by operating the valve through one complete cycle of full travel unless the block valve is closed in order to meet the requirements of ACTION b, or c in Specification 3.4.5.

REACTOR COOLANT SYSTEM

3/4.4.6 STEAM GENERATOR (SG) TUBE INTEGRITY

LIMITING CONDITION FOR OPERATION

3.4.6 SG tube integrity shall be maintained and all SG tubes satisfying the tube plugging criteria shall be plugged in accordance with the Steam Generator Program.

APPLICABILITY: MODES 1, 2, 3 and 4.

ACTION:

- a.* With one or more SG tubes satisfying the tube plugging criteria and not plugged in accordance with the Steam Generator Program:
 - 1. Verify tube integrity of the affected tube(s) is maintained until the next refueling outage or SG tube inspection within 7 days; and
 - 2. Plug the affected tube(s) in accordance with the Steam Generator Program prior to entering HOT SHUTDOWN following the next refueling outage or SG tube inspection.
- b. With SG tube integrity not maintained or the required Action of a. above not met, be in at least HOT STANDBY within 6 hours and in at least COLD SHUTDOWN within the following 30 hours.

SURVEILLANCE REQUIREMENTS

4.4.6.1 Verify SG tube integrity in accordance with the Steam Generator Program.

4.4.6.2 Verify that each inspected SG tube that satisfies the tube plugging criteria is plugged in accordance with the Steam Generator Program prior to entering HOT SHUTDOWN following a SG tube inspection

* Separate Action is allowed for each SG tube.

Pages 3/4 4-10 through 3/4 4-15a Deleted

REACTOR COOLANT SYSTEM

3/4.4.7 REACTOR COOLANT SYSTEM LEAKAGE

LEAKAGE DETECTION SYSTEMS

LIMITING CONDITION FOR OPERATION

3.4.7.1 The following Reactor Coolant System leakage detection systems shall be OPERABLE:

- a. The containment atmosphere particulate radioactivity monitoring system,
- b. The containment pocket sump level monitoring system, and
- c. Either the containment fan cooler condensate flow rate or the containment atmosphere gaseous radioactivity monitoring system.

APPLICABILITY: MODES 1, 2, 3 and 4.

ACTION:

With only two of the above required leakage detection systems OPERABLE, operation may continue for up to 30 days provided grab samples of the containment atmosphere are obtained and analyzed at least once per 24 hours when the required gaseous and/or particulate radioactivity monitoring system is inoperable; otherwise, be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.

SURVEILLANCE REQUIREMENTS

4.4.7.1 The leakage detection systems shall be demonstrated OPERABLE by:

- a. Containment atmosphere particulate and gaseous (if being used) monitoring systems-performance of CHANNEL CHECK, SOURCE CHECK, CHANNEL CALIBRATION and CHANNEL FUNCTIONAL TEST in accordance with the Surveillance Frequency Control Program.
- b. Containment pocket sump level and containment fan cooler condensate flow rate (if being used) monitoring systems-performance of CHANNEL CALIBRATION in accordance with the Surveillance Frequency Control Program.

OPERATIONAL LEAKAGE

LIMITING CONDITION FOR OPERATION

3.4.7.2 Reactor Coolant System leakage shall be limited to:

- a. No PRESSURE BOUNDARY LEAKAGE,
- b. 1 GPM UNIDENTIFIED LEAKAGE,
- c. 150 gallons per day primary-to-secondary leakage through any one steam generator, and
- d. 10 GPM IDENTIFIED LEAKAGE from the Reactor Coolant System, and
- e. NOT USED
- f. 1 GPM leakage at a Reactor Coolant System pressure of 2230 ± 20 psig from any Reactor Coolant System Pressure Isolation Valve

APPLICABILITY: MODES 1, 2, 3 and 4

ACTION:

- a. With any PRESSURE BOUNDARY LEAKAGE, or primary-to-secondary leakage not within limit, be in at least HOT STANDBY within 6 hours and in COLD SHUTDOWN within the following 30 hours.
- b. With any Reactor Coolant System leakage greater than any one of the above limits, excluding PRESSURE BOUNDARY LEAKAGE and leakage from Reactor Coolant System Pressure Isolation Valves, and primary-to-secondary leakage, reduce the leakage rate to within limits within 4 hours or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.
- c. With any Reactor Coolant System Pressure Isolation Valve leakage greater than the above limit, isolate the high pressure portion of the affected system from the low pressure portion within 4 hours by use of at least two closed manual or deactivated automatic valves, or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.

SURVEILLANCE REQUIREMENTS

4.4.7.2.1 Reactor Coolant System leakages shall be demonstrated to be within each of the above limits by:

- a. Monitoring the containment atmosphere particulate radioactivity monitor in accordance with the Surveillance Frequency Control Program.
- b. Monitoring the containment sump inventory in accordance with the Surveillance Frequency Control Program.

SURVEILLANCE REQUIREMENTS (Continued)

- c*. Verifying primary-to-secondary leakage is ≤ 150 gallons per day through any one steam generator in accordance with the Surveillance Frequency Control Program during steady state operation,
- d*. Performance of a Reactor Coolant System water inventory balance** in accordance with the Surveillance Frequency Control Program. The water inventory balance shall be performed with the plant at steady state conditions. The provisions of specification 4.0.4 are not applicable for entry into Mode 4, and
- e. Monitoring the reactor head flange leakoff system in accordance with the Surveillance Frequency Control Program.

4.4.7.2.2 Each Reactor Coolant System Pressure Isolation Valve shall be demonstrated OPERABLE pursuant to the INSERVICE TESTING PROGRAM, except that in lieu of any leakage testing required by the INSERVICE TESTING PROGRAM, each valve shall be demonstrated OPERABLE by verifying leakage to be within its limit:

- a. In accordance with the Surveillance Frequency Control Program.
- b. Prior to entering MODE 2 whenever the plant has been in COLD SHUTDOWN for 72 hours or more and if leakage testing has not been performed in the previous 9 months.
- c. Prior to returning the valve to service following maintenance repair or replacement work on the valve.
- d. For the Residual Heat Removal and Safety Injection Systems hot and cold leg injection valves and accumulator valves the testing will be done within 24 hours following valve actuation due to automatic or manual action or flow through the valve. For all other systems testing will be done once per refueling.

The provisions of specification 4.0.4 are not applicable for entry into MODE 3 or 4.

* Not required to be completed until 12 hours after establishment of steady state operation.

** Not applicable to primary-to-secondary leakage.

This page intentionally left blank

PAGES 3/4 4-20 THROUGH 3/4 4-22 DELETED

SALEM - UNIT 2

3/4 4-20 through 3/4 4-22

Amendment No. 161

FEB 22 1996

REACTOR COOLANT SYSTEM

3/4.4.9 SPECIFIC ACTIVITY

LIMITING CONDITION FOR OPERATION

3.4.9 The specific activity of the primary coolant shall be limited to:

- a. $\leq 1.0 \mu\text{Ci/gram DOSE EQUIVALENT I-131}$, and
- b. $\leq 600 \mu\text{Ci/gm DOSE EQUIVALENT XE-133}$.

APPLICABILITY: MODES 1, 2, 3, and 4.

ACTION:

NOTE

Specification 3.0.4.c is applicable

- a. With the specific activity of the primary coolant $> 1.0 \mu\text{Ci/gram DOSE EQUIVALENT I-131}$:
 - 1. Verify DOSE EQUIVALENT I-131 $\leq 60 \mu\text{Ci/gram}$ at least once every 4 hours and restore DOSE EQUIVALENT I-131 to $\leq 1.0 \mu\text{Ci/gram}$ within 48 hours, or
 - 2. Be in HOT STANDBY within 6 hours and in COLD SHUTDOWN within the following 30 hours.
- b. With the specific activity of the primary coolant $> 600 \mu\text{Ci/gram DOSE EQUIVALENT XE-133}$:
 - 1. Restore DOSE EQUIVALENT XE-133 to $\leq 600 \mu\text{Ci/gram}$ within 48 hours, or
 - 2. Be in HOT STANDBY within 6 hours and in COLD SHUTDOWN within the following 30 hours.

SURVEILLANCE REQUIREMENTS

NOTES

SR 4.4.9.1 is not required to be performed in MODE 4, and is not required to be performed in MODE 3 until 24 hours after $T_{\text{avg}} \geq 500^\circ\text{F}$.

- 4.4.9.1 Verify the specific activity of the primary coolant $\leq 600 \mu\text{Ci/gm DOSE EQUIVALENT XE-133}$ in accordance with the Surveillance Frequency Control Program.
- 4.4.9.2 Verify the specific activity of the primary coolant $\leq 1.0 \mu\text{Ci/gm DOSE EQUIVALENT I-131}$ in accordance with the Surveillance Frequency Control Program, and between 2 and 6 hours after a THERMAL POWER change of $\geq 15\%$ RATED THERMAL POWER within a one hour period.

This page intentionally left blank.

This page intentionally left blank.

This page intentionally left blank.

REACTOR COOLANT SYSTEM

3/4.4.10 PRESSURE/TEMPERATURE LIMITS

REACTOR COOLANT SYSTEM

LIMITING CONDITION FOR OPERATION

3.4.10.1 The Reactor Coolant System (except the pressurizer) temperature and pressure shall be limited in accordance with the limits specified in the PTLR with:

- a. A maximum heatup rate within the limits specified in the PTLR,
- b. A maximum cooldown rate within the limits specified in the PTLR, and
- c. A maximum temperature change within the limits specified in the PTLR, during hydrostatic testing operations above system design pressure.

APPLICABILITY: At all times.

ACTION:

With any of the above limits exceeded, restore the temperature and/or pressure to within the limit within 30 minutes; perform an engineering evaluation to determine the effects of the out-of-limit condition on the structural integrity of the Reactor Coolant System; determine that the Reactor Coolant System remains acceptable for continued operation or be in at least HOT STANDBY within the next 6 hours and reduce the RCS T_{avg} and pressure to less than 200°F and 500 psig, respectively, within the following 30 hours.

SURVEILLANCE REQUIREMENTS

4.4.10.1.1 The Reactor Coolant System temperature and pressure shall be determined to be within the limits specified in the PTLR in accordance with the Surveillance Frequency Control Program during system heatup, cooldown, and inservice leak and hydrostatic testing operations.

4.4.10.1.2 The reactor vessel material irradiation surveillance specimens shall be removed and examined, to determine changes in material properties, at the intervals required by 10 CFR 50, Appendix H. The results of these examinations shall be used to update the P-T Limit Curves specified in the PTLR.

THIS PAGE LEFT INTENTIONALLY BLANK

THIS PAGE LEFT INTENTIONALLY BLANK

REACTOR COOLANT SYSTEM

PRESSURIZER

LIMITING CONDITION FOR OPERATION

3.4.10.2 The pressurizer temperature shall be limited to:

- a. A maximum heatup of 100°F in any one hour period,
- b. A maximum cooldown of 200°F in any one hour period, and
- c. A maximum spray water temperature differential of 320°F.

APPLICABILITY: At all times.

ACTION:

With the pressurizer temperature limits in excess of any of the above limits, restore the temperature to within the limits within 30 minutes; perform an engineering evaluation to determine the effects of the out-of-limit condition on the structural integrity of the pressurizer; determine that the pressurizer remains acceptable for continued operation or be in at least HOT STANDBY within the next 6 hours and reduce the pressurizer pressure to less than 500 psig within the following 30 hours.

SURVEILLANCE REQUIREMENTS

4.4.10.2 The pressurizer temperatures shall be determined to be within the limits in accordance with the Surveillance Frequency Control Program during system heatup or cooldown. The spray water temperature differential shall be determined to be within the limit in accordance with the Surveillance Frequency Control Program during auxiliary spray operation.

REACTOR COOLANT SYSTEM

OVERPRESSURE PROTECTION SYSTEMS

LIMITING CONDITION FOR OPERATION

3.4.10.3 At least one of the following overpressure protection systems shall be OPERABLE:

- a. Two Pressurizer Overpressure Protection System relief valves (POPS) with a lift setting of less than or equal to the value specified in the PTLR, or
- b. The Reactor Coolant System (RCS) depressurized with an RCS vent of greater than or equal to 3.14 square inches.

APPLICABILITY: When the temperature of one or more of the RCS cold legs is less than or equal to the POPS enable temperature specified in the PTLR, except when the reactor vessel head is removed.

ACTION:

- a. With one POPS inoperable in MODE 4 and the temperature of one or more of the RCS cold legs is less than or equal to the POPS enable temperature specified in the PTLR, restore the inoperable POPS to OPERABLE status within 7 days or depressurize and vent the RCS through a 3.14 square inch vent(s) within the next 8 hours; maintain the RCS in a vented condition until both POPSs have been restored to OPERABLE status.
- b. With one POPS inoperable in MODES 5 or 6 with the Reactor Vessel Head installed, restore the inoperable POPS to OPERABLE status within 24 hours, or complete depressurization and venting of the RCS through at least a 3.14 square inch vent(s) within the next 8 hours; maintain the RCS in a vented condition until both POPSs have been restored to OPERABLE status.
- c. With both POPSs inoperable, depressurize and vent the RCS through a 3.14 square inch vent(s) within 8 hours; maintain the RCS in a vented condition until both POPSs have been restored to OPERABLE status.
- d. In the event either the POPS or the RCS vent(s) are used to mitigate a RCS pressure transient, a Special Report shall be prepared and submitted to the Commission pursuant to Specification 6.9.2 within 30 days. The report shall describe the circumstances initiating the transient, the effect of the POPS or vent(s) on the transient and any corrective action necessary to prevent recurrence.
- e. LCO 3.0.4.b is not applicable when entering MODE 4.

SURVEILLANCE REQUIREMENTS

4.4.10.3.1 Each POPS shall be demonstrated OPERABLE by:

REACTOR COOLANT SYSTEM

SURVEILLANCE REQUIREMENTS (Continued)

- a. Performance of a CHANNEL FUNCTIONAL TEST on the POPS actuation channel, but excluding valve operation, within 31 days prior to entering a condition in which the POPS is required OPERABLE and in accordance with the Surveillance Frequency Control Program thereafter when the POPS is required OPERABLE.
- b. Performance of a CHANNEL CALIBRATION on the POPS actuation channel in accordance with the Surveillance Frequency Control Program.
- c. Verifying the POPS isolation valve is open in accordance with the Surveillance Frequency Control Program when the POPS is being used for overpressure protection.
- d. Testing pursuant to the INSERVICE TESTING PROGRAM.

4.4.10.3.2 The RCS vent(s) shall be verified to be open in accordance with the Surveillance Frequency Control Program* when the vent(s) is being used for overpressure protection.

* Except when the vent pathway is provided with a valve which is locked, sealed, or otherwise secured in the open position, then verify these valves open in accordance with the Surveillance Frequency Control Program.

REACTOR COOLANT SYSTEM

3.4.11 DELETED

3/4.4.12 DELETED

|