


OPERATOR TRAINING PROGRAM  
JOB PERFORMANCE MEASURE

|                                                                    |                                                                                                              |                              |                                         |
|--------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------|------------------------------|-----------------------------------------|
| STATION:                                                           | SALEM                                                                                                        |                              |                                         |
| SYSTEM:                                                            | ADMINISTRATIVE                                                                                               |                              |                                         |
| TASK:                                                              | Review a completed surveillance to demonstrate Operability of 21 CFCU                                        |                              |                                         |
| TASK NUMBER:                                                       | N1230300302                                                                                                  |                              |                                         |
| JPM NUMBER:                                                        | 15-01 NRC SRO Admin A1-1                                                                                     |                              |                                         |
| ALTERNATE PATH:                                                    | <input type="checkbox"/>                                                                                     | K/A NUMBER:                  | 2.1.25                                  |
| APPLICABILITY:                                                     | IMPORTANCE FACTOR:                                                                                           |                              | 4.2                                     |
| EO <input type="checkbox"/>                                        | RO <input type="checkbox"/>                                                                                  | STA <input type="checkbox"/> | SRO <input checked="" type="checkbox"/> |
| EVALUATION SETTING/METHOD:                                         | Classroom                                                                                                    |                              |                                         |
| REFERENCES:                                                        | S2.OP-ST.CBV-0003, Rev. 19 (checked 8-10-16)                                                                 |                              |                                         |
| TOOLS AND EQUIPMENT:                                               |                                                                                                              |                              |                                         |
| VALIDATED JPM COMPLETION TIME:                                     | 12 min                                                                                                       |                              |                                         |
| TIME PERIOD IDENTIFIED FOR TIME CRITICAL STEPS:                    | N/A                                                                                                          |                              |                                         |
| Developed By:                                                      | G Gauding<br>Instructor                                                                                      | Date:                        | 8-10-16                                 |
| Validated By:                                                      | R Boyer / P Williams<br>SME or Instructor                                                                    | Date:                        | 9-28-16 / 10-4-16                       |
| Approved By:                                                       | <br>Training Department   | Date:                        | 10/11/16                                |
| Approved By:                                                       | <br>Operations Department | Date:                        | 10/11/16                                |
| ACTUAL JPM COMPLETION TIME:                                        |                                                                                                              |                              |                                         |
| ACTUAL TIME CRITICAL COMPLETION TIME:                              |                                                                                                              |                              |                                         |
| PERFORMED BY:                                                      |                                                                                                              |                              |                                         |
| GRADE: <input type="checkbox"/> SAT <input type="checkbox"/> UNSAT |                                                                                                              |                              |                                         |
| REASON, IF UNSATISFACTORY:                                         |                                                                                                              |                              |                                         |
| EVALUATOR'S SIGNATURE:                                             |                                                                                                              | DATE:                        |                                         |

OPERATOR TRAINING PROGRAM  
JOB PERFORMANCE MEASURE

NAME: \_\_\_\_\_

DATE: \_\_\_\_\_

**SYSTEM:** Administrative

**TASK:** Review a completed surveillance to demonstrate Operability of 21 CFCU

**TASK NUMBER:** N1230300302

**INITIAL CONDITIONS:** 21 CFCU was returned from corrective maintenance. S2.OP-ST.CBV-0003, Containment Systems - Containment Cooling was performed for the Operability Retest.

**INITIATING CUE:** You have been directed to review the surveillance for completeness and accuracy IAW Step 5.3.4.

If any discrepancies are identified, note them and any actions that you would take on Attachment 8, Section 1.0, Comments.

**Successful Completion Criteria:**

1. All critical steps completed
2. All sequential steps completed in order
3. All time-critical steps completed within allotted time
4. JPM completed within validated time. Completion time may exceed the validated time if satisfactory progress is being made (and NRC concurrence is obtained).

**Task Standard for Successful Completion:**

1. Identify that the Minimum Flow Rate recorded on Attachment 1, Section 3.0, for 87 psid is incorrectly recorded as 1592. Identify the correct Minimum Flow Rate should be 1638.
2. Identify that the actual Cooling Water Flow Rate (1625) is below the Minimum Flow Rate required as shown on Attachment 1 and Exhibit 1, and the surveillance is UNSAT vs SAT.

**OPERATOR TRAINING PROGRAM  
JOB PERFORMANCE MEASURE**

NAME: \_\_\_\_\_

DATE: \_\_\_\_\_

**System:** ADMINISTRATIVE

**Task:** Review a completed surveillance to demonstrate Operability of 21 CFCU

| * | STEP<br>NO. | STEP<br>(* Denotes a Critical Step) | STANDARD                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                              | EVAL<br>S/U | COMMENTS<br>(Required for UNSAT<br>evaluation) |
|---|-------------|-------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------|------------------------------------------------|
|   |             |                                     | Provide completed S2.OP-ST.CBV-0003 surveillance.                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                     |             |                                                |
|   |             |                                     | Reviews procedure.                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                    |             |                                                |
|   |             |                                     | <p>Identifies that the Minimum Flow Rate recorded on Attachment 1, 21 CFCU Data Sheet, Section 3.0, for 87 psid is incorrectly recorded as 1592. (This was due to operator performing ST rounding down as opposed to rounding up IAW P&amp;L 3.4.)</p> <p>Identifies correct value for Minimum Flow Required as 1638.</p> <p><b>Cue: IF</b> candidate only determines flow is wrong, <b>THEN</b> ask candidate to determine correct flow.</p> <p>Identifies that the actual Cooling Water Flow Rate of 1625 gpm is below the Minimum Flow Rate of 1638 as shown on Exhibit 1 and the ST is UNSAT.</p> |             |                                                |
|   |             |                                     | When candidate turns in JPM, ensure they have provided correct flow as per Cue above, then state JPM is complete.                                                                                                                                                                                                                                                                                                                                                                                                                                                                                     |             |                                                |

OPERATOR TRAINING PROGRAM  
JOB PERFORMANCE MEASURE

TQ-AA-106-0303  
Revision 4

JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

**NOTE:** All steps of this checklist should be performed upon initial validation. Prior to JPM usage, revalidate JPM using steps 8 and 11 below.

- ✓ 1. BO 1. Task description and number, JPM description and number are identified.
- ✓ 1. BO 2. Knowledge and Abilities (K/A) references are included.
- ✓ 1. BO 3. Performance location specified. (in-plant, control room, or simulator)
- ✓ 1. BO 4. Initial setup conditions are identified.
- ✓ 1. BO 5. Initiating and terminating Cues are properly identified.
- ✓ 1. BO 6. Task standards identified and verified by SME review.
- ✓ 1. BO 7. Critical steps meet the criteria for critical steps and are identified with an asterisk (\*).
1. BO 8. Verify the procedure referenced by this JPM matches the most current revision of that procedure: Procedure Rev. 19 Date 9/22/16
1. BO 9. Pilot test the JPM:  
a. verify Cues both verbal and visual are free of conflict, and  
b. ensure performance time is accurate.
- \_\_\_\_\_ 10. If the JPM cannot be performed as written with proper responses, then revise the JPM.
- \_\_\_\_\_ 11. When JPM is revalidated, SME or Instructor sign and date JPM cover page.

SME/Instructor: [Signature] 130101

SME/Instructor: [Signature] Williams

SME/Instructor: \_\_\_\_\_

Date: 9/28/16

Date: 10/4/16

Date: \_\_\_\_\_

**INITIAL CONDITIONS:**

21 CFCU was returned from corrective maintenance. S2.OP-ST.CBV-0003, Containment Systems - Containment Cooling was performed for the Operability Retest.

**INITIATING CUE:**

You have been directed to review the surveillance for completeness and accuracy IAW Step 5.3.4.

If any discrepancies are identified, note them and any actions that you would take on Attachment 8, Section 1.0, Comments.