


OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE

STATION:	SALEM		
SYSTEM:	Emergency Plan		
TASK:	Classify an event and complete an ICMF within the regulatory committed time limit (ESG-2)		
TASK NUMBER:	1240020502		
JPM NUMBER:	15-01 NRC SRO Admin A4-1 (ESG-2)		
ALTERNATE PATH:	☐	K/A NUMBER:	2.4.41
		IMPORTANCE FACTOR:	4.6
APPLICABILITY:		RO	SRO
EO	☐	RO	☐
STA	☐	SRO	☒
EVALUATION SETTING/METHOD:	Simulate (Simulator or Classroom)		
REFERENCES:	EP-SA-111-F2 Rev. 2 (ALERT)		
TOOLS AND EQUIPMENT:	Inform Simulator Operators – DO NOT ERASE ANY PROCEDURES UNTIL THE SRO EVALUATOR APPROVES		
VALIDATED JPM COMPLETION TIME:	12 minutes		
TIME PERIOD IDENTIFIED FOR TIME CRITICAL STEPS:	15 minutes		
Developed By:	G Gauding Instructor	Date:	9-19-15
Validated By:	C Davis / P Williams SME or Instructor	Date:	9-21-16 / 10-4-16
Approved By:	 Training Department	Date:	10/11/16
Approved By:	 Operations Department	Date:	10/11/16
ACTUAL JPM COMPLETION TIME:			
ACTUAL TIME CRITICAL COMPLETION TIME:			
PERFORMED BY:			
GRADE:	☐ SAT	☐ UNSAT	
REASON, IF UNSATISFACTORY:			
EVALUATOR'S SIGNATURE:			DATE:

OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE

NAME: _____

DATE: _____

SYSTEM: Emergency Plan

TASK: Classify an event and complete an ICMF within the regulatory committed time limit (ESG-2)

TASK NUMBER: 1240020502

INITIAL CONDITIONS:

1. You have a maximum of 5 minutes to review the Emergency Operating Procedures used during this scenario to refresh your memory of all events/paths. At the end of your review you will become the Shift Manager (SM). Inform the Evaluator when you are ready to assume SM duties. You may continue to reference the procedures or to look at the control board but "the clock will be running." If there are multiple ECG calls, classify the most severe.

INITIATING CUE:

You are the Duty SM. Classify the event, complete the correct ECG Attachment and provide an ICMF to the Primary Communicator.

This is a Time Critical JPM.

Successful Completion Criteria:

1. All critical steps completed.
2. All sequential steps completed in order.
3. All time-critical steps completed within allotted time.
4. JPM completed within validated time. Completion time may exceed the validated time if satisfactory progress is being made.

Task Standard for Successful Completion:

1. Declare an **ALERT under EAL RB3.L** within 15 minutes of start time, and provide ICMF to the Primary Communicator within the next 15 minutes.

OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE

NAME: _____
DATE: _____

SYSTEM: **Emergency Plan**

TASK: Classify an event and complete an ICMF within the regulatory committed time limit (ESG-2)

*	STEP NO.	STEP (*Denotes a Critical Step)	STANDARD	EVAL S/U	COMMENTS (Required for UNSAT evaluation)
		Provide candidate with "Tear-off sheet" and Blank Copies of EP-SA-111-F1 through F4 (UE, ALERT, SAE, GE)	Reviews initial conditions and EOP's (as necessary – 5 minute limit prior to starting)		
		*START TIME: _____ *Start time begins when candidate reports he/she is ready to assume SM duties	Cue: The regulatory commitment time clock has started.		
		Reviews ECG to classify event	Note: It is acceptable to use the laminated tables in the simulator, rather than the ECG		
		Classifies the event	Determines the classification of the event and refers to ECG Attachment 2 (Alert)		
	Att 2 A.1	CALL communicators to the Control Room	Pages communicators and initials as SM Cue: I am the Primary Communicator		

OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE

NAME: _____
DATE: _____

SYSTEM: **Emergency Plan**

TASK: Classify an event and complete an ICMF within the regulatory committed time limit (ESG-2)

*	STEP NO.	STEP (*Denotes a Critical Step)	STANDARD	EVAL S/U	COMMENTS (Required for UNSAT evaluation)
	Att 2 A.2	IF a Security Event is in progress, THEN IMPLEMENT the prompt actions of NC.EP-EP.ZZ-0102, EC Response, Attachment 10, prior to the classification.	Determines Security Event is not in progress.		
	Att 2 A.3	If time allows, DIRECT Classification Independent Verification to be performed.	Cue: No independent verification will be performed.		

OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE

NAME: _____
DATE: _____

SYSTEM: **Emergency Plan**

TASK: Classify an event and complete an ICMF within the regulatory committed time limit (ESG-2)

*	STEP NO.	STEP (*Denotes a Critical Step)	STANDARD	EVAL S/U	COMMENTS (Required for UNSAT evaluation)
* *	Att 2 A.4	After Classification Independent Verification is obtained: • DECLARE the ALERT (enter time and date on ICMF) • COMPLETE / APPROVE the ICMF	Declares an ALERT under RB3.L within 15 minutes of Start Time: _____:_____:_____ Completes and Approves the ICMF as follows: EAL#(s): RB3.L Description of Event: Loss of the Reactor Coolant System Boundary Note: Description of Event is found in EAL Description Table <u>Fills out Section III:</u> Checks IS for a Radiological Release in progress. <u>Fills out Section IV:</u> Retrieves wind speed (10)and direction (160) data from SPDS <u>Initials for approval to transmit</u>		
	Att 2 A.5	If time allows OBTAIN accuracy peer check of the completed ICMF	Cue: No peer check will be performed.		

OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE

NAME: _____
DATE: _____

SYSTEM: **Emergency Plan**

TASK: Classify an event and complete an ICMF within the regulatory committed time limit (ESG-2)

*	STEP NO.	STEP (*Denotes a Critical Step)	STANDARD	EVAL S/U	COMMENTS (Required for UNSAT evaluation)
*	Att 2 A.6	Continue with NOTIFICATION AND ACTIVATION as follows: • If not previously performed, ACTIVATE / DIRECT ACTIVATION of ERO Emergency Callout (EP 96-003) • DIRECT the Primary Communicator to implement ECG Attachment 6	Cue: Activation of ERO Emergency Callout is not required for this JPM. Provides ICMF to Primary Communicator within 15 minutes of event declaration ____:____:____		
			Terminate JPM when ICMF is given to the Evaluator.		

JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

NOTE: All steps of this checklist should be performed upon initial validation. Prior to JPM usage, revalidate JPM using steps 8 and 11 below.

- ✓ WCP 1. Task description and number, JPM description and number are identified.
- ✓ WCP 2. Knowledge and Abilities (K/A) references are included.
- ✓ WCP 3. Performance location specified. (in-plant, control room, or simulator)
- ✓ WCP 4. Initial setup conditions are identified.
- ✓ WCP 5. Initiating and terminating Cues are properly identified.
- ✓ WCP 6. Task standards identified and verified by SME review.
- ✓ WCP 7. Critical steps meet the criteria for critical steps and are identified with an asterisk (*).
- ✓ WCP 8. Verify the procedure referenced by this JPM matches the most current revision of that procedure: Procedure Rev. 2 Date 9.21.16
- ✓ WCP 9. Pilot test the JPM:
 a. verify Cues both verbal and visual are free of conflict, and
 b. ensure performance time is accurate.
- ✓ WCP 10. If the JPM cannot be performed as written with proper responses, then revise the JPM.
- ✓ WCP 11. When JPM is revalidated, SME or Instructor sign and date JPM cover page.


SME/Instructor:



Date:

9.21.16

SME/Instructor:



Date:

10/7/16

SME/Instructor:

Date:

INITIAL CONDITIONS:

1. You have a maximum of 5 minutes to review the Emergency Operating Procedures used during this scenario to refresh your memory of all events/paths. At the end of your review you will become the Shift Manager (SM). Inform the Evaluator when you are ready to assume SM duties. You may continue to reference the procedures or to look at the control board but "the clock will be running." If there are multiple ECG calls, classify the most severe.

INITIATING CUE:

You are the Duty SM. Classify the event, complete the correct ECG Attachment and provide an ICMF to the Primary Communicator.

This is a Time Critical JPM.