

OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE

STATION:	SALEM		
SYSTEM:	Waste Gas		
TASK:	Authorize a Radioactive Gas Release Form		
TASK NUMBER:	N1120650302		
JPM NUMBER:	13-01 NRC SRO Admin A3		
ALTERNATE PATH:	☒	K/A NUMBER:	2.3.6
APPLICABILITY:	EO ☐	IMPORTANCE FACTOR:	RO 3.8 SRO
	RO ☐	STA ☐	SRO ☒
EVALUATION SETTING/METHOD:	Classroom		
REFERENCES:	S1.OP-SO.WG-0010 Rev. 31 (Rev checked 9/22/14)		
TOOLS AND EQUIPMENT:			
VALIDATED JPM COMPLETION TIME:	20 min		
TIME PERIOD IDENTIFIED FOR TIME CRITICAL STEPS:	N/A		
Developed By:	G Gauding Instructor	Date:	9-22-14
Validated By:	N Salam SME or Instructor	Date:	10-16-14
Approved By:	 Training Department	Date:	10-23-14
Approved By:	 Operations Department	Date:	10-23-14
ACTUAL JPM COMPLETION TIME:			
ACTUAL TIME CRITICAL COMPLETION TIME:			
PERFORMED BY:			
GRADE:	☐ SAT	☐ UNSAT	
REASON, IF UNSATISFACTORY:			
EVALUATOR'S SIGNATURE:		DATE:	

OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE

NAME: _____

DATE: _____

SYSTEM: Waste Gas

TASK: Authorize a Radioactive Gas Release Form

TASK NUMBER: N1120650302

INITIAL CONDITIONS: 13 GDT is in holdup in preparation for performing a gas release. Chemistry has performed all required sampling and authorized the gas release. The release procedure, S1.OP-SO.WG-0010, Discharge of 13 Gas Decay Tank to Plant Vent has just been handed to you by the Unit 1 PO, who informs you the release is ready for CRS approval.

INITIATING CUE: Review the entire S1.OP-SO.WG-0010 procedure for completeness, accuracy, and release approval. Approve the release or provide justification for NOT approving the release, and also note any discrepancies found in the procedure, in the comments section of the procedure.

Note to Evaluator: A cue directing the performer to review the entire procedure is embedded several places in body of JPM, based on previous performance of this JPM where an operator will find the first flaw and discontinue reviewing the remainder of the procedure. If required, stress during initiating cue that the entire procedure is to be reviewed.

Successful Completion Criteria:

1. All critical steps completed
2. All sequential steps completed in order
3. All time-critical steps completed within allotted time
4. JPM completed within validated time. Completion time may exceed the validated time if satisfactory progress is being made (and NRC concurrence is obtained).

Task Standard for Successful Completion:

1. Review Gas Release and identify that:

- a. Pre-release verification has not been performed at step 5.2.8
- b. Attachment 2, Step 4.1, second bullet, calculated Maximum Allowable Release rate from Section 3.4 has been entered as 32 SCFM instead of the correct value of 100 scfm.

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE**

NAME: _____

DATE: _____

System: ADMINISTRATIVE

Task: Authorize a Radioactive Gas Release Form

* STEP NO.	STEP (* Denotes a Critical Step)	STANDARD	EVAL S/U	COMMENTS (Required for UNSAT evaluation)
	Provide marked up S1.OP-SO.WG-0010 to operator.			
		Operator reviews procedure. Possible Cue Required: On page 17, the Estimated Total Volume of Waste Gas to be released is entered by Chemistry during performance of Attachment 2, section 3.0, DOSE, VOLUME ESTIMATES AND APPROVAL. IF a candidate requests the Release Permit, or questions the estimated release volume or ANY aspect of Section 3.0, THEN provide the following cue: Cue: The data provided in Section 3 of Attachment 2 can be assumed to be correct.		
*		The first error in the procedure is that the performance of the pre-release valve position verification in Attachment 1, has not been performed at step 5.2.8., prior to the procedure being given to the CRS for release approval. Possible Cue Required: If candidate identifies that Step 5.2.8 has not been performed and does not go any further to see if the rest of the procedure is correct, then a cue stating that the candidate needs to review the entire procedure will need to be given.		

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE**

NAME: _____

DATE: _____

System: ADMINISTRATIVE

Task: Authorize a Radioactive Gas Release Form

* STEP NO.	STEP (* Denotes a Critical Step)	STANDARD	EVAL S/U	COMMENTS (Required for UNSAT evaluation)
*		The second error is that the release rate which was calculated as 100 scfm and entered on Att. 2 page 2 of 6, Step 3.4 second bullet, has been incorrectly entered as 32 scfm on Att. 2, page 4 of 6, step 4.1 1st bullet. (The release rate entered here must be >32 scfm in order to sign off the next bullet). Possible Cue Required: If candidate identifies that the release rate has been entered incorrectly and does not go any further to see if the rest of the procedure is correct, then a cue stating that the candidate needs to review the entire procedure will need to be given.		
	Operator identifies and records discrepancies.	When operator records discrepancies and has reviewed the entire procedure, then terminate JPM.		

OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE

JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

NOTE: All steps of this checklist should be performed upon initial validation. Prior to JPM usage, revalidate JPM using steps 8 and 11 below.

- YM 1. Task description and number, JPM description and number are identified.
- YM 2. Knowledge and Abilities (K/A) references are included.
- YM 3. Performance location specified. (in-plant, control room, or simulator)
- YM 4. Initial setup conditions are identified.
- YM 5. Initiating and terminating Cues are properly identified.
- YM 6. Task standards identified and verified by SME review.
- YM 7. Critical steps meet the criteria for critical steps and are identified with an asterisk (*).
- YM 8. Verify the procedure referenced by this JPM matches the most current revision of that procedure: Procedure Rev. 31 Date 5/17/2006
- YM 9. Pilot test the JPM:
a. verify Cues both verbal and visual are free of conflict, and
b. ensure performance time is accurate.
- N/A 10. If the JPM cannot be performed as written with proper responses, then revise the JPM.
- N/A 11. When JPM is revalidated, SME or Instructor sign and date JPM cover page.

SME/Instructor:  Date: 10/16/14

SME/Instructor: _____ Date: _____

SME/Instructor: _____ Date: _____

INITIAL CONDITIONS:

13 GDT is in holdup in preparation for performing a gas release. Chemistry has performed all required sampling and authorized the gas release. The release procedure, S1.OP-SO.WG-0010, Discharge of 13 Gas Decay Tank to Plant Vent has just been handed to you by the Unit 1 PO, who informs you the release is ready for CRS approval.

INITIATING CUE:

Review the entire S1.OP-SO.WG-0010 procedure for completeness, accuracy, and release approval. Approve the release or provide justification for NOT approving the release, and also note any discrepancies found in the procedure, in the comments section of the procedure.