

OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE

STATION:	SALEM		
SYSTEM:	ADMINISTRATIVE		
TASK:	Review an OTSC to an Implementing Procedure		
TASK NUMBER:	N1230020302		
JPM NUMBER:	11-01 NRC SRO Admin A2		
ALTERNATE PATH:	☒	K/A NUMBER:	2.2.6
APPLICABILITY:	IMPORTANCE FACTOR:		3.6
EO ☐	RO ☐	STA ☐	SRO ☒
EVALUATION SETTING/METHOD:		Classroom	
REFERENCES:	AD-AA-101-101, Rev. 4, PSEG Implementing Procedure On The Spot Change (OTSC) Process		
TOOLS AND EQUIPMENT:			
VALIDATED JPM COMPLETION TIME:	15 min		
TIME PERIOD IDENTIFIED FOR TIME CRITICAL STEPS:	N/A		
Developed By:	G Gauding Instructor	Date:	8-14-12
Validated By:	A Crampton SME or Instructor	Date:	9-10-12
Approved By:	Training Department	Date:	
Approved By:	Operations Department	Date:	
ACTUAL JPM COMPLETION TIME:			
ACTUAL TIME CRITICAL COMPLETION TIME:			
PERFORMED BY:			
GRADE:	☐ SAT	☐ UNSAT	
REASON, IF UNSATISFACTORY:			
EVALUATOR'S SIGNATURE:			DATE:

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE**

NAME: _____

DATE: _____

{PRIVATE }SYSTEM: Administrative

TASK: Review an OTSC to an Implementing Procedure

TASK NUMBER: N1230020302

INITIAL CONDITIONS: Operators are performing S1.OP-PT.SW-0101, Differential Pressure Test of Turbine Area SW Stop Valves 11SW20, 13SW20, and 1SW26. The operator in the field identified an incorrect connection point for installation of a pressure instrument.

An OTSC has been initiated to allow the performance test to continue with the proper pressure test connection identified.

The OTSC Initiator has verified the correct revision (Rev. 6), and determined there are no other OTSCs associated with this procedure.

INITIATING CUE: As the operators Supervisor, review the proposed OTSC change. Determine if an OTSC is warranted for the condition. If so, review OTSC for completeness and accuracy. Note any problems, deficiencies, or comments on the OTSC form. If an OTSC is not warranted for this condition, inform the evaluator of this.

{PRIVATE }Successful Completion Criteria:

1. All critical steps completed
2. All sequential steps completed in order
3. All time-critical steps completed within allotted time
4. JPM completed within validated time. Completion time may exceed the validated time if satisfactory progress is being made (and NRC concurrence is obtained).

Task Standard for Successful Completion:

1. Identify that the OTSC process applies to this situation.
2. Identify the incorrect OTSC # during review of the OTSC.

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE**

NAME: _____

DATE: _____

System: ADMINISTRATIVE

Task: Review an OTSC to an Implementing Procedure

*	STEP NO.	STEP * Denotes a Critical Step	STANDARD	EVAL S/U	COMMENTS (Required for UNSAT evaluation)
			NOTE TO EVALUATOR: <u>IF</u> the candidate asks for drawings or other procedures with the intent of technically verifying the Component ID's, <u>THEN</u> cue candidate that the technical verification of the component IDs has been performed and verified by 2 other SROs.		
		Candidate reviews OTSC for applicability, completeness, and accuracy.	Provide OTSC Form F1, and pages 6,10,15-16, 18-20 of S1.OP-PT.SW-0101. When asked, provide a copy of AD-AA-101-101, PSEG Implementing Procedure On The Spot Change (OTSC) Process.		

**OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE**

NAME: _____

DATE: _____

System: ADMINISTRATIVE

Task: Review an OTSC to an Implementing Procedure

*	STEP NO.	STEP * Denotes a Critical Step	STANDARD	EVAL S/U	COMMENTS (Required for UNSAT evaluation)
*			Candidate reviews Form-1 and OTSC process procedure. The following should be noted: - The OTSC process is appropriate for this situation. The procedure steps cannot be performed as written because the pressure test connection is incorrect. - The OTSC No. on Form F1 is incorrect. As per the OTSC procedure, the sequential number is the current revision number followed by the next available sequential letter, and should be 6A, not 7A.		
		Candidate identifies and records discrepancies.	When candidate records discrepancies, terminate JPM.		

OPERATOR TRAINING PROGRAM{PRIVATE }
JOB PERFORMANCE MEASURE

JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

NOTE: All steps of this checklist should be performed upon initial validation. Prior to JPM usage, revalidate JPM using steps 8 and 11 below.

- _____ 1. Task description and number, JPM description and number are identified.
- _____ 2. Knowledge and Abilities (K/A) references are included.
- _____ 3. Performance location specified. (in-plant, control room, or simulator)
- _____ 4. Initial setup conditions are identified.
- _____ 5. Initiating and terminating Cues are properly identified.
- _____ 6. Task standards identified and verified by SME review.
- _____ 7. Critical steps meet the criteria for critical steps and are identified with an asterisk (*).
- _____ 8. Verify the procedure referenced by this JPM matches the most current revision of that procedure: Procedure Rev. _____ Date _____
- _____ 9. Pilot test the JPM:
 - a. verify Cues both verbal and visual are free of conflict, and
 - b. ensure performance time is accurate.
- _____ 10. If the JPM cannot be performed as written with proper responses, then revise the JPM.
- _____ 11. When JPM is revalidated, SME or Instructor sign and date JPM cover page.

SME/Instructor: _____

Date: _____

SME/Instructor: _____

Date: _____

SME/Instructor: _____

Date: _____

INITIAL CONDITIONS:

Operators are performing S1.OP-PT.SW-0101, Differential Pressure Test of Turbine Area SW Stop Valves 11SW20, 13SW20, and 1SW26. The operator in the field identified an incorrect connection point for installation of a pressure instrument.

An OTSC has been initiated to allow the performance test to continue with the proper pressure test connection identified.

The OTSC Initiator has verified the correct revision (Rev. 6), and determined there are no other OTSCs associated with this procedure.

INITIATING CUE:

As the operators Supervisor, review the proposed OTSC change. Determine if an OTSC is warranted for the condition. If so, review OTSC for completeness and accuracy. Note any problems, deficiencies, or comments on the OTSC form. If an OTSC is not warranted for this condition, inform the evaluator of this.