

OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE

STATION:	SALEM		
SYSTEM:	Emergency Plan		
TASK:	Classify an event and complete an ICMF within the regulatory committed time limit (ESG-1)		
TASK NUMBER:	1240020502		
JPM NUMBER:	11-01 NRC SRO Admin A4-1 (ESG-1)		
ALTERNATE PATH:	☐	K/A NUMBER:	2.4.41
APPLICABILITY:		IMPORTANCE FACTOR:	
EO ☐	RO ☐	STA ☐	SRO ☒
EVALUATION SETTING/METHOD:		Simulate (Simulator or Classroom)	
REFERENCES:		Salem ECG	
TOOLS AND EQUIPMENT:		Inform Simulator Operators – DO NOT ERASE ANY PROCEDURES UNTIL THE SRO EVALUATOR APPROVES	
VALIDATED JPM COMPLETION TIME:		12 minutes	
TIME PERIOD IDENTIFIED FOR TIME CRITICAL STEPS:		15 minutes	
Developed By:	G Gauding Instructor	Date:	08-21-12
Validated By:	Boos SME or Instructor	Date:	08-23-12
Approved By:	Training Department	Date:	
Approved By:	Operations Department	Date:	
ACTUAL JPM COMPLETION TIME:			
ACTUAL TIME CRITICAL COMPLETION TIME:			
PERFORMED BY:			
GRADE: ☐ SAT ☐ UNSAT			
REASON, IF UNSATISFACTORY:			
EVALUATOR'S SIGNATURE:			DATE:

OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE

NAME: _____

DATE: _____

SYSTEM: Emergency Plan

TASK: Classify an event and complete an ICMF within the regulatory committed time limit (ESG-1)

TASK NUMBER: 1240020502

INITIAL CONDITIONS:

1. You have a maximum of 5 minutes to review the Emergency Operating Procedures used during this scenario to refresh your memory of all events/paths. At the end of your review you will become the Shift Manager (SM). Inform the Evaluator when you are ready to assume SM duties. You may continue to reference the procedures or to look at the control board but "the clock will be running." If there are multiple ECG calls, classify the most severe.

INITIATING CUE:

You are the Duty SM. Classify the event, complete the correct ECG Attachment and provide an ICMF to the Primary Communicator.

This is a Time Critical JPM.

Successful Completion Criteria:

1. All critical steps completed.
2. All sequential steps completed in order.
3. All time-critical steps completed within allotted time.
4. JPM completed within validated time. Completion time may exceed the validated time if satisfactory progress is being made.

Task Standard for Successful Completion:

1. Complete the ICMF with the classification of **ALERT under EAL RB2.L** and provide it to the Primary Communicator within 15 minutes of Start Time.
OR
2. Complete the ICMF with the classification of **SAE under EAL RB2.L AND CB5.L** and provide it to the Primary Communicator within 15 minutes of Start Time. This is the classification if the cavitating charging pump is not recognized and it fails.

OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE

NAME: _____
DATE: _____

SYSTEM: **Emergency Plan**

TASK: Classify an event and complete an ICMF within the regulatory committed time limit (ESG-1)

*	STEP NO.	STEP (*Denotes a Critical Step)	STANDARD	EVAL S/U	COMMENTS (Required for UNSAT evaluation)
			Note: This ECG call can either be an ALERT or a SAE based on whether or not the crew tripped the cavitating charging pump.		
		Provide candidate with "Tear-off sheet"	Reviews initial conditions and EOP's (as necessary – 5 minute limit prior to starting)		
		*START TIME: _____ *Start time begins when candidate reports he/she is ready to assume SM duties	Cue: The regulatory commitment time clock has started.		
		Reviews ECG to classify event	Note: It is acceptable to use the laminated tables in the simulator, rather than the ECG		
		Classifies the event	Determines the classification of the event and refers to ECG Attachment 2 (Alert) OR refers to Att. 3 (SAE)		
	Att 2 A.1	CALL communicators to the Control Room	Pages communicators and initials as SM Cue: I am the Primary Communicator		

OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE

NAME: _____
DATE: _____

SYSTEM: **Emergency Plan**

TASK: Classify an event and complete an ICMF within the regulatory committed time limit (ESG-1)

*	STEP NO.	STEP (*Denotes a Critical Step)	STANDARD	EVAL S/U	COMMENTS (Required for UNSAT evaluation)
	Att 2 A.2	IF a security Event is in progress, THEN IMPLEMENT the prompt actions of NC.EP-EP.ZZ-0102, EC Response, Attachment 10 , prior to the classification.	Determines Security Event is not in progress.		
	Att 2 A.3	As time allows, OBTAIN Classification Independent Verification (ensure verifier understands the EAL assessment clock is running); STA or designee performs Independent Verification for SM. SM or designee performs Independent Verification for EDO. EDO or designee performs Independent Verification for ERM.	Cue: No independent review will be performed.		
	Att 2 A.4	While classification verification is in progress and if time allows, COMMENCE filling out the INITIAL CONTACT MESSAGE FORM (ICMF) (last page of this attachment)	Begins filling out ICMF.		
	Att 2 A.5	After classification verification and/or before 15 minute EAL assessment clock expires, DECLARE and ALERT (or SAE if appropriate based on ESG performance) at Salem Unit(s)_____	Before 15 minute assessment clock expires, declares ALERT (or SAE if appropriate based on ESG performance) at Salem Unit(s)_____		

OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE

NAME: _____
DATE: _____

SYSTEM: **Emergency Plan**

TASK: Classify an event and complete an ICMF within the regulatory committed time limit (ESG-1)

*	STEP NO.	STEP (*Denotes a Critical Step)	STANDARD	EVAL S/U	COMMENTS (Required for UNSAT evaluation)
	Att 2 B.1	ACTIVATE "ERO Emergency Callout" per posted instructions titled: "Emergency Callout Activation (Commitment EP96-003)	Cue: Activation of ERO Emergency Callout is not required for this JPM.		
*	Att 2 B.2	COMPLETE/APPROVE the (ICMF) (last page of this attachment).	<u>Fills out Section II of ICMF:</u> EAL#(s): RB2.L (or RB2.L AND CB5.L) Description of Event: Loss of the Reactor Coolant System Barrier OR Loss of the Reactor Coolant System Barrier, Loss of the Containment Barrier. Note: Description of Event is found in EAL Description Table <u>Fills out Section III:</u> Checks for a Radiological Release is in progress. <u>Fills out Section IV:</u> Retrieves wind speed and direction data from SPDS <u>Initials for approval to transmit</u>		

OPERATOR TRAINING PROGRAM
JOB PERFORMANCE MEASURE

NAME: _____
DATE: _____

SYSTEM: **Emergency Plan**

TASK: Classify an event and complete an ICMF within the regulatory committed time limit (ESG-1)

*	STEP NO.	STEP (*Denotes a Critical Step)	STANDARD	EVAL S/U	COMMENTS (Required for UNSAT evaluation)
	Att 2 B.3	IF time allows, OBTAIN an accuracy peer check of the completed ICMF.	Cue: Peer check is not provided.		
*	Att 2 B.4	PROVIDE the ICMF to the Primary Communicator and DIRECT the Communicator to implement ECG Attachment 6.	Provides ICMF to Primary Communicator within 15 minutes of START TIME COMPLETION TIME: _____		
			Terminate JPM when ICMF is given to the Evaluator.		

INITIAL CONTACT MESSAGE FORM

I. THIS IS _____, COMMUNICATOR IN THE ☒ CONTROL ROOM
(NAME) ☐ TSC

AT THE SALEM NUCLEAR GENERATING STATION, UNIT(s) NO. 2.

II. ☒ THIS IS NOTIFICATION OF AN ALERT WHICH WAS

DECLARED AT _____ TIME _____ ON _____ TODAYS DATE _____.
(Time-24 HR CLOCK) (DATE)

EAL #(s) **RB2.L** DESCRIPTION OF EVENT: **Loss of the Reactor**
Coolant System Barrier

III.

NOTE:

Radiological Release is defined as: Plant Effluent > Federal Limit of 2.42E+05 uCi/sec Noble Gas or 2.1E+01 uCi/sec I-131.

☒ NO RADIOLOGICAL RELEASE IS IN PROGRESS. see NOTE
☐ THERE IS A RADIOLOGICAL RELEASE IN PROGRESS for release
definition

IV. ☒ 33 FT. LEVEL WIND DIRECTION (From): _____ WIND SPEED: _____
(From MET Computer /SPDS) (DEGREES) (MPH)

V. ☒ NO PROTECTIVE ACTIONS ARE RECOMMENDED AT THIS TIME

Candidates Initial
EC Initials
(Approval to Transmit ICMF)

SGS

Rev. 00

INITIAL CONTACT MESSAGE FORM

I. THIS IS _____, COMMUNICATOR IN THE ☒ CONTROL ROOM
(NAME) ☐ TSC
☐ EOF

AT THE SALEM NUCLEAR GENERATING STATION, UNIT(s) NO. 2.

II. ☒ THIS IS NOTIFICATION OF A SITE AREA EMERGENCY WHICH WAS

DECLARED AT _____ TIME _____ ON _____ TODAYS DATE _____.
(Time-24 HR CLOCK) (DATE)

EAL #(s) **RB2.L AND CB5.L**

DESCRIPTION OF EVENT: **Loss of the Reactor Coolant System Barrier, Loss of the Containment Barrier**

III.

NOTE:

Radiological Release is defined as: Plant Effluent > Federal Limit of 2.42E+05 uCi/sec Noble Gas or 2.1E+01 uCi/sec I-131.

☒ NO RADIOLOGICAL RELEASE IS IN PROGRESS. see NOTE
☐ THERE IS A RADIOLOGICAL RELEASE IN PROGRESS for release
definition

IV. ☒ 33 FT. LEVEL WIND DIRECTION (**From**): _____ WIND SPEED: _____
(From MET Computer /SPDS) (DEGREES) (MPH)

V. ☒ NO PROTECTIVE ACTIONS ARE RECOMMENDED AT THIS TIME

Candidates Initial
EC Initials
(Approval to Transmit ICMF)

SGS

Rev. 01

JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

NOTE: All steps of this checklist should be performed upon initial validation. Prior to JPM usage, revalidate JPM using steps 8 and 11 below.

- _____ 1. Task description and number, JPM description and number are identified.
- _____ 2. Knowledge and Abilities (K/A) references are included.
- _____ 3. Performance location specified. (in-plant, control room, or simulator)
- _____ 4. Initial setup conditions are identified.
- _____ 5. Initiating and terminating Cues are properly identified.
- _____ 6. Task standards identified and verified by SME review.
- _____ 7. Critical steps meet the criteria for critical steps and are identified with an asterisk (*).
- _____ 8. Verify the procedure referenced by this JPM matches the most current revision of that procedure: Procedure Rev. _____ Date _____
- _____ 9. Pilot test the JPM:
 - a. verify Cues both verbal and visual are free of conflict, and
 - b. ensure performance time is accurate.
- _____ 10. If the JPM cannot be performed as written with proper responses, then revise the JPM.
- _____ 11. When JPM is revalidated, SME or Instructor sign and date JPM cover page.

SME/Instructor: _____ Date: _____

SME/Instructor: _____ Date: _____

SME/Instructor: _____ Date: _____

INITIAL CONDITIONS:

1. You have a maximum of 5 minutes to review the Emergency Operating Procedures used during this scenario to refresh your memory of all events/paths. At the end of your review you will become the Shift Manager (SM). Inform the Evaluator when you are ready to assume SM duties. You may continue to reference the procedures or to look at the control board but "the clock will be running." If there are multiple ECG calls, classify the most severe.

INITIATING CUE:

You are the Duty SM. Classify the event, complete the correct ECG Attachment and provide an ICMF to the Primary Communicator.

This is a Time Critical JPM.