

PLANT SYSTEMS

3/4.7.11 FUEL STORAGE POOL BORON CONCENTRATION

LIMITING CONDITION FOR OPERATION

3.7.11 The fuel storage pool boron concentration shall be ≥ 800 ppm

APPLICABILITY: When fuel assemblies are stored in the fuel storage pool and a fuel storage pool verification has not been performed since the last movement of fuel assemblies in the fuel storage pool.

ACTION:

With fuel storage pool boron concentration not within limit:

- a. Immediately suspend movement of fuel assemblies in the fuel storage pool and
- b. Initiate action to:
 1. immediately restore fuel storage pool boron concentration to within limit or
 2. immediately perform a fuel storage pool verification.
- c. The provisions of Specification 3.0.3 is not applicable.

SURVEILLANCE REQUIREMENTS

4.7.11 Verify the fuel storage pool boron concentration is within limit in accordance with the Surveillance Frequency Control Program.