



# PT. SURYA SEGARA safety marine

• AUTHORIZED SERVICE STATION ILR, LIFEBOAT, DAVIT LAUNCHING APPLIANCE  
• Fire Extinguisher, CO2 Fix System Service and Safety Equipment Supply  
Head Office : Jl. Perak Timur 358 Surabaya - Indonesia, Telp. +62 31 3292021, 3292022 Fax. +62 31 3291423  
APPROVAL : SAI GLOBAL ISO 9001, ABS, LLOYD'S REGISTER, DNV-GL, NKK, BTKP, BKI | [www.suryasegara.com](http://www.suryasegara.com)

## CERTIFICATE of Inspection

Year :	Month :	Day :	Type and name of ship/unit :	Flag :	IMO No. :	Certificate No. :
2021	07	09	GAS NURI ARIZONA	INDONESIA	9113927	SS-210704.2.1
Place of service :			Classification Society :		Enclosed :	
KALBUT - INDONESIA			KOREAN REGISTER		2	

We hereby certify that the systems and equipment specified below have been inspected, serviced, refilled, and tested according to requirement from IMO regulation, SOLAS and manufacturer.  
The quantity of equipment and working code enclosed in Service Report back of this page.

<input type="checkbox"/> -	Fixed CO2 System	<input type="checkbox"/> -	Medical Oxygen
<input type="checkbox"/> -	Fixed Foam System	<input type="checkbox"/> -	Breathing Apparatus
<input type="checkbox"/> -	Foam Test Analyst	<input type="checkbox"/> -	Escape Sets
<input type="checkbox"/> -	Fixed Halon System	<input type="checkbox"/> -	Rubber Boat
<input type="checkbox"/> -	Fixed Dry Powder System	<input type="checkbox"/> -	Life Jacket
<input checked="" type="checkbox"/> x	Portable Fire Extinguisher	<input type="checkbox"/> -	Summary of Actions



APPROVED BY :

PT. SURYA SEGARA



SUBARI

NAME IN PRINTED NAME

## PORTABLE FIRE EXTINGUISHER SERVICE REPORT

Page : 1 of 2

Year 2021	Month 07	Day 09	Type and name of ship / unit : <b>GAS NURI ARIZONA</b>	IMO No. : <b>9113927</b>	Certificate No. : <b>SS-210704.2.1</b>
--------------	-------------	-----------	---	-----------------------------	---

### Description of type :

DP	: Dry Powder	FAB	: Foam AB
W	: Water Gass	FAF	: Foam AFFF
CO2	: Carbon Dioxide	EAP	: Foam Application
BCF	: Halon 1211	FP	: Foam Protein
WC	: Wet Chemical		

### Description of working codes :

1 = Inspection	6 = New Extinguisher
2 = Refilling	7 = Service
3 = Hydrostatic test	8 = Rejected
4 = Repaired	9 = Check Weight
5 = Repainted	10 = Check Content

No.	Type	Cyl No.	Cap. / Volume	Mfg. Date / Latest Hyd. Test	Working Code	Remark
1	DP	-	1,2 Kg	-	1, 10	Good Condition
2	DP	-	1,2 Kg	-	1, 10	Good Condition
3	DP	0180	3,5 Kg	02 - 1994 / 04 - 2015	1, 10	Good Condition
4	DP	0176	3,5 Kg	04 - 2015	1, 10	Good Condition
5	DP	0576	3,5 Kg	-	1, 10	Good Condition
6	DP	-	3,5 Kg	-	1, 10	Good Condition
7	DP	-	3,5 Kg	04 - 2015	1, 10	Good Condition
8	DP	149370	6 Kg	08 - 2005 / 04 - 2015	1, 10	Good Condition
9	DP	-	6 Kg	-	1, 10	Good Condition
10	DP	-	40 Kg	04 - 2015	1, 10	Good Condition
11	FAB	03581	9 Ltr	-	1, 10	Good Condition
12	FAB	03582	9 Ltr	-	1, 10	Good Condition
13	FAB	03596	9 Ltr	-	1, 10	Good Condition
14	FAB	03501	9 Ltr	04 - 2015	1, 10	Good Condition
15	FAB	600562	9 Ltr	04 - 2015	2, 7, 10	Good Condition
16	FAB	03560	9 Ltr	12 - 1994 / 04 - 2015	1, 10	Good Condition
17	FAB	03554	9 Ltr	12 - 1994 / 04 - 2015	1, 10	Good Condition
18	FAB	03566	9 Ltr	12 - 1994 / 04 - 2015	1, 10	Good Condition
19	FAB	03565	9 Ltr	12 - 1994 / 04 - 2015	1, 10	Good Condition
20	FAB	03561	9 Ltr	12 - 1994 / 04 - 2015	1, 10	Good Condition
21	FAB	03584	9 Ltr	12 - 1994 / 04 - 2015	1, 10	Good Condition
22	FAB	03558	9 Ltr	12 - 1994 / 04 - 2015	1, 10	Good Condition
23	FAB	03563	9 Ltr	12 - 1994 / 04 - 2015	1, 10	Good Condition
24	FAB	03557	9 Ltr	12 - 1994 / 04 - 2015	1, 10	Good Condition
25	FAB	03525	9 Ltr	12 - 1994 / 04 - 2015	1, 10	Good Condition

This Portables fire extinguisher requires service 12 month from the latest inspection.





# PT. SURYA SEGARA safety marine

• AUTHORIZED SERVICE STATION ILR, LIFEBOAT, DAVIT LAUNCHING APPLIANCE  
• Fire Extinguisher, CO2 Fix System Service and Safety Equipment Supply  
Head Office : Jl. Perak Timur 358 Surabaya - Indonesia, Telp. +62 31 3292021, 3292022 Fax. +62 31 3291423  
APPROVAL : SAI GLOBAL ISO 9001, ABS, LLOYD'S REGISTER, DNV-GL, NKK, BTKP, BKI | [www.suryasegara.com](http://www.suryasegara.com)

## PORTABLE FIRE EXTINGUISHER SERVICE REPORT

Page : 2 of 2

Year	Month	Day	Type and name of ship / unit :	IMO No. :	Certificate No. :
2021	07	09	GAS NURI ARIZONA	9113927	SS-210704.2.1

Description of type :			Description of working codes :		
DP	: Dry Powder	FAB	: Foam AB	1 = Inspection	6 = New Extinguisher
W	: Water Gass	FAF	: Foam AFFF	2 = Refilling	7 = Service
CO2	: Carbon Dioxide	FAP	: Foam Application	3 = Hydrostatic test	8 = Rejected
BCF	: Halon 1211	FP	: Foam Protein	4 = Repaired	9 = Check Weight
WC	: Wet Chemical			5 = Repainted	10 = Check Content

No.	Type	Cyl No.	Cap. / Volume	Mfg. Date / Latest Hyd. Test	Working Code	Remark
26	FAB	00310	45 Ltr	11 - 1994 / 04 - 2015	2, 7, 10	Good Condition
27	FAP	002581	20 Ltr	-	1, 10	Good Condition
28	FAP	002582	20 Ltr	-	1, 10	Good Condition
29	PILOT N2	27801	150 Bar	08 - 1994 / 04 - 2015	1, 10	Good Condition

This Portables fire extinguisher requires service 12 month from the latest inspection.

  
**SURYA SEGARA**  
SUBARI

SIGN AND STAMP