

CERTIFICATE

OF INSPECTION

Date of Inspection: 10 OKTOBER 2020	Vessel name / Unit: ENC RHAYDEN	Job No / Certificate No: CMSI/FFA/4221/10/20
Port of Service: BATAM	Classification Society: ABS	Flag / IMO No: INDONESIA / 9277694

We hereby certify that the Systems and Equipment specified below have been Inspected and Serviced.
The Chart reference states the quantity and the letter code of relevant enclosed Service Charts.

SCOPE OF INSPECTION	SERVICE CHART
<input type="checkbox"/> CO2 High Pressure System	
<input type="checkbox"/> Foam System	
<input type="checkbox"/> Foam Concentrate Test	
<input type="checkbox"/> Dry Powder System	
<input type="checkbox"/> Nitrogen Inert System	
<input checked="" type="checkbox"/> Fire Extinguisher	P1
<input type="checkbox"/> Self Content Breathing Apparatus	
<input type="checkbox"/> Emergency Escape Breathing Device	
<input type="checkbox"/> Other System and Equipment –	
<input type="checkbox"/> Summary Report	
Comments to all Service Charts are summarized on Service Chart RP 1- 'Summary of Actions' where Performed Recommended, Maintenance, Repair & Replacement are Specified.	

This certificate is valid only when certificate and defined Service Charts are duly signed and stamp by

PT. CITRA MARINE SERVICES INTERNATIONAL

10 OCT 2020

Batam,
An. KEPALA KANTOR KESYAHBANDARAN DAN
OTORITAS PELABUHAN KHUSUS BATAM
KEMENTERIAN PERHUBUNGAN
KEMERIAH



Capt. FIRDALUS AFWINDRA, S.Tr, M.Mar

Penata (III/c)

NIP. 19810925 200712 1 002



AZLI ISHAK
Verified by
COMPANY STAMP AND SIGNATURE

NEXT INSPECTION DATE: 09 OKTOBER 2021

The Certificate of Inspection shall be issue by
PT. CITRA MARINE SERVICES INTERNATIONAL

CMS-CERT-F1 Rev.1

SERVICE CHART - P1

PORTABLE FIRE EXTINGUISHER AND SPARE CHARGES

Date of Inspection: 10 OKTOBER 2020			Vessel name / Unit: ENC RHAYDEN			Job No / Certificate No: CMSI/FFA/4221/10/20		
Description of Type: DP - DRY POWDER CO2 - CARBONDIOXIDE AB - CHEMICAL FOAM AFFF - FLUOROPOTEIN W - WATER APP - FOAM APPLICATOR			Description of Fire Class: A - SOLID MATERIALS OF AN ORGANIC NATURE B - FLAMMABLE LIQUIDS AND GASES C - ELECTRICAL EQUIPMENT D - COMBUSTIBLE MATERIAL			Description of working codes: 1 - SERVICED / INSPECTED 2 - CHECK CONTENT 3 - RECHARGED 4 - HYDROSTATIC TESTED 5 - REPAIR / REPAINT 6 - CONDEMNED		
Nos	Location	Serial No	Last Test Date	Maker	Type	Fire Class	Capacity	Working Codes
1	COLLECT ON BOARD	0073	01.2018	PYHROSAFE	CO2	B.C	6.8 KG	1,2,3
2	COLLECT ON BOARD	0036	01.2018	PYHROSAFE	CO2	B.C	6.8 KG	1,2,3
3	COLLECT ON BOARD	0034	01.2018	PYHROSAFE	CO2	B.C	6.8 KG	1,2,3
4	COLLECT ON BOARD	000073	11.2017	PYHROSAFE	DP	A.B.C	4.5 KG	1,2,3
5	COLLECT ON BOARD	000203	11.2017	PYHROSAFE	DP	A.B.C	4.5 KG	1,2,3
6	COLLECT ON BOARD	NA	NA	GLOBE	AFF	A.B	6 Ltr	1,2,3
7	COLLECT ON BOARD	NA	NA	GLOBE	AFF	A.B	6 Ltr	1,2,3
8	COLLECT ON BOARD	NA	10.2015	GLOBE	AFF	A.B	9 Ltr	1,2,3
9	COLLECT ON BOARD	NA	10.2015	GLOBE	AFF	A.B	9 Ltr	1,2,3
10	COLLECT ON BOARD	NA	10.2015	GLOBE	AFF	A.B	9 Ltr	1,2,3
11	COLLECT ON BOARD	NA	10.2015	GLOBE	AFF	A.B	9 Ltr	1,2,3
12	COLLECT ON BOARD	NA	10.2015	GLOBE	AFF	A.B	9 Ltr	1,2,3
13	COLLECT ON BOARD	000254	03.2017	PYHROSAFE	AFF	A.B	9 Ltr	1,2,3
14	COLLECT ON BOARD	000073	11.2017	PYHROSAFE	AFF	A.B	9 Ltr	1,2,3
15	COLLECT ON BOARD	024	01.2002	GLOBE	AFF	A.B	45 Ltr	1,2,3,4
16	COLLECT ON BOARD	203636	12.2001	GLOBE	DP	A.B.C	4.5 KG	1,2,3,4
17	COLLECT ON BOARD	203625	12.2001	GLOBE	DP	A.B.C	4.5 KG	1,2,3,4
18	COLLECT ON BOARD	203594	12.2001	GLOBE	DP	A.B.C	4.5 KG	1,2,3,4
19	COLLECT ON BOARD	203612	12.2001	GLOBE	DP	A.B.C	4.5 KG	1,2,3,4
20	COLLECT ON BOARD	203666	12.2001	GLOBE	DP	A.B.C	4.5 KG	1,2,3,4

Comments: Performed and / or Recommended Actions are listed on Service Chart RP1 - "Summary of Actions"



PT. CITRA MARINE SERVICES INTERNATIONAL

Stamp and Signature

Description of Inspection / Test

- Extinguisher body, pressure gauge, discharge head and nozzle are inspected. Where applicable, dip tube checked and cartridge weighed, internal condition and Extinguisher medium inspected. Extinguisher reassembled, sealed and Inspection label attached.
- When hydrostatic tested is required for CO2 extinguisher according to Flag state requirement, the service Chart CS 2 will be filling up NBI Stamping on body of Portable Extinguisher is prohibited, with exemption of CO2 extinguisher, only stickers or label allowed.

The Certificate of Inspection shall be issue by
PT. CITRA MARINE SERVICES INTERNATIONAL

CMSI-CERT-F 2 Rev.1

Batam Office : Komp. Pasar SP Blok D No. 3 Batu Aji - Batam Telp.: (0778) 395 063, Fax. (0778) 395 058

Jakarta Workshop : Komp. Green Sedayu Bizpark Blok GS 8 No.15 - Jakarta Timur Telp. 021-2287 4402

Belawan Workshop : Jl. Jawa No.11 Kelurahan Belawan II, kecamatan Medan Belawan - Kota Medan Telp. 061-42069483

Website : www.citramarine.com, Email : cs@citramarine.com

CERTIFICATE

OF INSPECTION

Date of Inspection: 10 OKTOBER 2020	Vessel name / Unit: ENC RHAYDEN	Job No / Certificate No: CMSI/FFA/4222/10/20
Port of Service: BATAM	Classification Society: ABS	Flag / IMO No: INDONESIA / 9277694

We hereby certify that the Systems and Equipment specified below have been Inspected and Serviced.
The Chart reference states the quantity and the letter code of relevant enclosed Service Charts.

SCOPE OF INSPECTION	SERVICE CHART
<input type="checkbox"/> CO2 High Pressure System	
<input type="checkbox"/> Foam System	
<input type="checkbox"/> Foam Concentrate Test	
<input type="checkbox"/> Dry Powder System	
<input type="checkbox"/> Nitrogen Inert System	
<input type="checkbox"/> Fire Extinguisher	
<input checked="" type="checkbox"/> Self-Content Breathing Apparatus	BA1 & CS1
<input type="checkbox"/> Emergency Escape Breathing Device	
<input type="checkbox"/> Other System and Equipment	
<input type="checkbox"/> Summary Report	
Comments to all Service Charts are summarized on Service Chart RP 1- 'Summary of Actions' where Performed Recommended, Maintenance, Repair & Replacement are Specified.	

This certificate is valid only when certificate and defined Service Charts are duly signed and stamp by
PT. CITRA MARINE SERVICES INTERNATIONAL



AZLI ISHAK

Verified by
COMPANY STAMP AND SIGNATURE

NEXT INSPECTION DATE: 09 OKTOBER 2021

The Certificate of Inspection shall be issue by
PT. CITRA MARINE SERVICES INTERNATIONAL

CMS-CERT-F1 Rev.1

SERVICE CHART – BA 1

SELF CONTENT BREATHING APPARATUS

Date of Inspection: 10 OKTOBER 2020	Vessel name / Unit: ENC RHAYDEN	Job No / Certificate No: CMSI/FFA/4222/10/2020
---	---	--

Technical Description;

No	Type	Maker	Set Serial No	Air Capacity
1	RN	SPASCIANI	3587	1800

Description of Inspection / Test

Serial No	Face Mask	Breathing Valve	Regulator Unit & Hoses	Back Plates & Harness	Function Test	Cylinders Service / Chart reference			Comments
						Inspection CS1	Recharged CS1	Tested CS2	
1800	✓	✓	✓	✓	✓	✓	✓	--	SATISFACTORY

Comments: Performed and / or Recommended Actions are listed on Service Chart RP1 – "Summary of Actions"



CITRA
MARINE SERVICES INTERNATIONAL

PT. CITRA MARINE SERVICES INTERNATIONAL

Stamp and Signature

Description of Inspection / Tests

- Face Mask : Check there no cracks in the rubber face piece or face straps. Check there no cracks or discolor in the visor. Check that the mask is clean and perform leak test.
- Breathing Valve : Check the membrane. Check the inhalation resistant and breathing capacity.
- Regulator Unit & Hoses : Check condition of low and high pressure hoses. Check the connection of hoses / nipple fitting. Check pressure gauge for proper working condition.
- Back Plates & Harness : Check condition of Back Plates and cover. Check condition of waist belt and buckle. Check condition of shoulder straps / pad buckle. Check condition of cylinder attachment and straps.
- Function Test : Function Test by using of approved test equipment and instruction manuals regarding capacity.

The Certificate of Inspection shall be issue by
PT. CITRA MARINE SERVICES INTERNATIONAL

CMS-CERT-F 03

Batam Office : Komp. Pasar SP Blok D No. 3 Batu Aji - Batam Telp.: (0778) 395 063, Fax. (0778) 395 058

Jakarta Workshop : Komp. Green Sedayu Bizpark Blok GS 8 No.15 - Jakarta Timur Telp. 021-2287 4402

Belawan Workshop : Jl. Jawa No.11 Kelurahan Belawan II, kecamatan Medan Belawan - Kota Medan Telp. 061-42069483

Website : www.citramarine.com, Email : cs@citramarine.com

