

Sultant Of Oman
Ministry of Health
Royal Hospital



سلطنة عمان
وزارة الصحة
المستشفى السلطاني

Document Management System

	Sultanate of Oman Ministry of Health The Royal Hospital Department of Dy. DG for admin & fin affairs
Code: DGA-POL-6-Vers.0.1	
Effective Date: 20/10/2019	
Target Review Date: 17/10/2021	
Title: Fire Code Policy	
<u>POLICY & PROCEDURES FOR A CODE RED RESONSE</u> <u>POLICY</u> The Royal Hospital shall have in place at all times a coded system to be initiated in the event of any confirmed fire incident. This shall be known as the CODE RED. The existing Royal Hospital fire emergency telephone extension number 9777 shall remain and serve as the Code Red number. <u>OBJECTIVE</u> The objective is to provide on a permanent 24 hour basis a selected “On Duty” team or managers or otherwise competent persons to respond in the event of a confirmed outbreak of fire. The team shall be known as the CODE RED TEAM and shall respond immediately to the location of an occurrence of fire in order to bring authority and take control of the incident. <u>1. CODE RED TEAM MEMBERS</u> 1.1 The Code Red Team shall be as follows: <u>During Normal Working Hours:</u> D.G or whoever act . Fire Officer.	

Security.

PRO.

Eng Controller.

Outside normal working hours:

Duty Director.

Fire Officer.

Eng Controller.

Duty Nursing Officer. Security.

PRO.

Security.

.Accident & Emergency Dept

1.2 Outside of normal working hours the code red team shall respond to and assess the severity of an incident.

1.3 The code red team having assessed the severity of the incident shall make the decision whether or not to place a call to the Civil Defense Fire & Rescue Services.

1.4 The decision to call the Civil Defense Fire & Rescue Services shall be based solely upon whether or not the fire is in progress and if it is within or beyond the control of staff on duty using the life safety equipment provided.

1.5 If required, the code red team shall initiate a recall of key staff (Key staff to be defined).

1.6 In such circumstances where an evacuation is required, the code red team shall organize and supervise a progressive horizontal evacuation of patients and any casualties to

Place of safety within the hospital.

1.7 The code red team shall terminate any incident based on their decision after arrival and assessment of the incident.

2. ARRANGEMENTS FOR ALERTING THE CODE RED TEAM MEMBERS

2.1 Information that a fire incident may *possibly* be in progress shall be received as an electronic signal by the hospital switchboard operator at the fire alarm panel, and / or by the maintenance operator via the BMS systems.

2.2 Information confirming that a fire is actually in progress shall be received by the switchboard operator via the Code Red Fire Emergency extension . Upon receipt of such information the switchboard operator shall record the location, the name of the caller and details of the fire.

2.3 Information received as described in para 2.1 shall be forwarded directly and immediately to the Fire Officer. The Fire Officer shall respond and investigate on receipt of the information.

2.4 Upon confirmation of any fire incident in progress the switchboard operator shall immediately alert the code red team members by DECT phone announcing the location of the incident.

Code Code Red, Code Red. - Code Red team report immediately to (*location*)“

2.6 The announcement shall be made calmly and clearly in English and Arabic and shall be repeated twice.

2.7 Once the announcement has been made the switchboard operator shall remain vigilant in order to receive or dispatch further information.

3. DEBRIEFING

3.1 A debriefing shall be made at the termination of any fire incident which requires a code red team response.

4. DOCUMENTING THE INCIDENT

4.1 An incident report shall be completed and a written report shall be submitted by the fire officer as soon as possible following any code red response.

5. EVALUATING THE CODE RED VIA A SIMULATED RESPONSE DRILL

5.1 The code red number shall be test called once per Month. All team members shall be alerted via their DECT phone. Upon receipt of the code red test call, each member shall return an immediate acknowledgement call to the telephone operator.

5.2 In order to evaluate the written code red response plan there shall be a quarterly practical evaluation of the code red as per the approved document “Fire Drill Policy & Procedures

5.3 The code red drill shall be initiated by an announcement from the switchboard operator via the DECT phone and the public address system as follows:

Code Red Drill – Code Red Drill – Code Red Drill – Code Red team respond to (Location) immediately.

5.4 The announcement shall be made clearly in English and Arabic and shall be repeated twice.

5.5 The code red drill shall be called at anytime, during or after normal working hours.

5.6 Upon receipt of the code red drill information the code red team members shall respond immediately to the location.

5.7 Upon arrival at the drill location each member shall call the switchboard operator to confirm their attendance.

5.8 A written record of the team members in attendance at the location shall be made. The time from the initial code red announcement to the time of the team member

attending the drill location shall also be recorded.

5.9 The code red drill shall be debriefed and any flaws shall be noted and improved upon.

Written By: Adam Saif Mohammed ALHudaifi

Checked By: ADAM

Authorized by: KHALIL MOHAMMED AL KHARUSI



© Copyright 2018 reserved 'Royal Hospital- Information
Technology Department'