

Sunburst Sensors, LLC 1226 W Broadway Ave Missoula, MT 59802 +1 406 532 3247

$SAMI^2 CO_2$ Calibration Certificate

January 8, 2020

Serial Number:

c64

RMA Number:

082744

Technician:

BW

Reagent:

btb0282

Table 1: SAMI² CO₂ calibration parameters.

| A | В | C | K_{434} | K_{620} | T_{avg} | Range (ppm) |
|--------|--------|---------|-----------|-----------|-----------|-------------|
| 0.0510 | 0.5395 | -1.2961 | 0.7616 | 1.2143 | 9.5229 | 209-1999 |

Table 2: Blank intensities.


| | | and the state of the state of the state of | |
|-------------------|-----------|--|--|
| Source | Reference | Signal | |
| Dark | 39 | 86 | |
| 434 nm | 3230 | 2514 | |
| $620~\mathrm{nm}$ | 1949 | 2403 | |

Build Notes

Pressure Test: 200 psi


Modifications:

Refurbishment with OOI PV cable swap board repaired .5hr extended calibration




INSULATION RESISTANCE TEST: OOI - UW/OSU UNITS

Communications and Power - Ti Bulkhead



| Top view of MCBH(WB)-FS-6-Ti | | | |
|------------------------------|--|-----------------------|----------------------------|
| | | Sw | itch |
| Pin | Connection | L | R |
| 1 2 3 4 5 6 | GND (pwr) Rx (SAMI) Tx (SAMI) V+ (PWR) RTS GND (com) | 1 2 3 4 0 | 0 0 0 0 1 2 |
| | | | |



Pump Bulkhead

Top view of MCBH(WB)-FS-2-Ti

| | | Sw | itch |
|--------|--------------|-----|------|
| Pin | Connection | L, | R |
| 1 2 | GND PWR + | 0 0 | 3 |
| L' | Locate | | |

- 1. Plug test cable(s) into SAMI bulkhead(s) and immerse unit past bulkhead connection. Allow to soak for at least 2 hours.
- 2. Plug anode into Common on Fluke 1507. Black jumper connects 'Insulation' to box banana receptacle.
- 3. Set Fluke 1507 to 50V range and proceed to test each switch position in table below by pressing the 'Test' button. Hold 'Test' button until reading stabilizes. Record the insulation resistance value in table. Note that one of the switches is zero in each condition.
- 4. If out of spec (<10 M Ω), contact customer w/r/t replacement of suspected parts (typically penetrator, bulkhead or biofouling cable).
- 5. Replace suspected part and re-test if needed.

| (@0,009 (@0,009) | මබා(ම) ලෝ | ដៅថ្ងៃដែ មេសាមែន | ដែនថ្លែងក្រុង (ស្រីមួយ១វិធីទ) | RefrestRosideniae (Megr©tinis) |
|---------------------|--------------|---------------------|----------------------------------|-----------------------------------|
| GND | 1 | 0 |) 53 | . >55 |
| Rx | 2 | 0 | >35 | >55 |
| Tx | 3 | 0 | >,55 | 255 |
| ÿ ₊ | 4 | 0 | 155 | >55 |
| RTS | 0 | 1 | >55 | >55 |
| GND. | 0 | 2 | >55 | 755 |
| GND - Pump | 0 | 3 | 757 | >55 |
| V+ - Pump | 0 | 4 | >55 | 755 |

Technician Signature

Notes:

she & 30 hr test