UV-C Lamp Hour Meter - Installation & Operation Manual (IOM)


General

The UV-C Lamp Hour Meter tracks the actual run-time of UV lamp installations. Its purpose is to alert the facility engineer/manager when UV-C lamps should be replaced. It has three output indicators: (1) a direct LCD readout of the elapsed time the UV-C lamps have been running; (2) LED lights of Green, Yellow (30 days until recommended lamp replacement) and Red (lamp replacement recommended); and (3) A 5V relay signal for output to building automation/ management systems (BMS). When the timer reaches 30 days (or 8040 hours) prior to the recommended lamp change, the 5V signal will change to a slow intermittent signal. Once the timer reaches 365 days(8760 hours), the 5V signal will change to a rapid intermittent signal indicating lamps should be changed.

What's Included

1. UV-C Lamp Hour Meter
2. Two self-tapping mounting screws
3. 24Vac wall adapter

UV-C Lamp Hour Meter:



LED indicators:

HOURS	LED Color	5V OUTPUT
0-8040	Green	5V Constant
8041-9000	Yellow	1Hz 5V
9001+	Red	3Hz 5V

Electrical

Ambient Temperature:	50 - 110° F
Relative Humidity:	<90%
Supply Voltage:	24Vac +/-10% - 50/60Hz*
Power Consumption:	<3 Watts
Relay Contact:	5V Signal
Relay Capacity:	24Vac/5A, 30Vdc/5A

***NOTE: UV Resources provides a 24Vac wall adapter power supply/step-down for this product that recommended for use.**

Installation

Using the 2 screws (supplied), level and mount the UV-C Hour Meter in visible and convenient location where 24Vac power is available. At the labeled wiring block (or with the plug), connect isolated 24V power to the "Power" screws (**NOTE: UV Resources supplies a 24Vac wall adapter**).

Operation

1. Apply power to the UV-C Lamp Hour Meter from the isolated 24Vac power source (e.g. 24Vac wall adapter provided).
2. Press “Reset” button until LCD hours read “0” (zero). The Hour Meter is now ready for use.
3. Repeat this procedure each time the lamps are replaced.

Equipment Warranty

UV Resources™ (UVR) warrants to the original buyer that its Products shall be free from defects in material or workmanship under normal use and service for the periods of time set forth below. This warranty is contingent upon proper use of Products and will not apply if adjustment, repair or parts replacement is required because of an accident, unusual physical, electrical or electro-mechanical stress, neglect, misuse, failure of electric power, humidity control, transportation, unauthorized repair actions, or not installed or maintained in accordance with UVRs’ specifications hereunder, or where Product serial numbers have been altered, defaced, or removed. UVRs’ obligation under this warranty shall not arise until the Purchaser of the Product returns the defective part to UVR. This warranty is limited to the repair and/or replacement of parts. This warranty does not cover any labor or subsequent damage incurred as the result of Product failure or indirectly arising from the design, construction, installation, servicing, or operation of Products. UVR and its resellers’ liability under this warranty shall in no event exceed the cost of goods sold under the original sale contract.

Under the conditions specified above, UV Resources warrants this Product for a period of one (1) year from date of purchase. Buyer must provide proof of purchase. This is UVRs’ sole warranty. No warranties are extended beyond those described herein and it is expressly agreed that this warranty will be in lieu of all warranties of fitness and merchantability. UVR neither assumes, nor authorizes any person to assume for it, any obligation in connection with the Products. Buyer shall not return to UVR any allegedly defective goods without UVRs’ prior written authorization. This warranty may not be assigned or transferred.

UV RESOURCES
P.O. Box 800370, Santa Clarita, CA 91380-0370

www.UVResources.com

Specifications subject to change without notice - ©2005-2017, all rights reserved.

90000409
Rev. A 8/17