CAPTIVEAIRE CASLINK

HVAC PERFORMANCE SUMMARY

ARRIGO CDJR SAWGRASS / OCTOBER 12, 2026

8 / 8
CONNECTED UNITS

8 / 8
COOLING STATE

8 / 8
ACTIVE COOLING RESPONSE

SYSTEM OVERVIEW

The CasLink snapshot shows all eight CaptiveAire DOAS units connected and reporting active cooling, with discharge air cooler than the corresponding intake air.

UNIT	DISCHARGE	INTAKE	OUTDOOR	TEMP. DROP	STATE
FAN #1	60.1 F	76.1 F	81.7 F	**16.0 F**	COOLING
FAN #2	57.0 F	81.5 F	86.0 F	**24.5 F**	COOLING
FAN #3	47.5 F	77.5 F	86.4 F	**30.0 F**	COOLING
FAN #4	57.6 F	77.7 F	90.9 F	**20.1 F**	COOLING
FAN #5	50.9 F	76.8 F	85.8 F	**25.9 F**	COOLING
FAN #6	56.3 F	75.0 F	81.3 F	**18.7 F**	COOLING
FAN #7	47.7 F	79.3 F	85.5 F	**31.6 F**	COOLING
FAN #8	61.7 F	76.6 F	82.9 F	**14.9 F**	COOLING

POSITIVE SYSTEM INDICATORS

All eight units show an intake-to-discharge temperature reduction.

Remote monitoring connectivity is active across the reported system.

Source: CaptiveAire CasLink dashboard snapshot provided for review.

Readings describe observed controls data; cooling capacity and commissioning are not field-verified.