COMMONWEALTH

SAFETY AUDIT INSPECTION CHECKLIST/REPORT

Name of Merchant: OFFICE WAREHOUSE Name of Owner: _____

Type: REGULAR NON- FOOD Space Number: _____

Date of Inspection: 1/28/24 Inspection Frequency: Q

In connection with the inspection conducted at the above named merchnt hereunder are the following violations /deficiencies found (marked "X"):

DEFICIENCIES			RECOMMENDED CORRECTIVE ACTIONS
I. GENERAL SAFETY			
A	B		
	☑	1. No fire extinguisher Expired 5 F/E	1. Provide _____units, _____type, _____lbs fire extinnguishers.
		2. Discharged fire extinguisher/s	2. Recharge _____units of fire extinguisher/s
		3. Insufficient no. of fire extinguishers	3. Provide additional _____units of _____type_____ lbs. fire extinguisher
		4. No smoke/heat detector installed on apprpriate location	4. Install smoke/heat detector (submit bond paper size layout plan for approval prior to installation
		5. Insufficient no. of smoke.heat detector	5. Provide additional _____ unit/s of smoke/heat detector on the following locations
		6. Defective/not functionnig smoke/heat detector	6. Repair/replace _____ unit/s of smoke/heat detector
		7. /no portable emergencyl ights	7. Provide _____ unit/s of portable emergency lights
		8. Insufficient no. of portable emergencyl ights	8. Provide additional _____unit/s of portable emergency lights
		9. Improper handling of highly combustible materials and flammable liquids/ chemicals	9.a. Store highly combustible materials and flammable liquids in a safe container and location 9.b. Dispose off all highly combustible materials
		10. Obstructed ingress/egress/fire exits	10. Clear ingress/egress/fire exits from any obstruction at all times
		11. Others (As specified)	11

CamScanner