FORM U-1A MANUFACTURER'S DATA REPORT FOR PRESSURE VESSELS

(Alternative Form for Single Chamber, Completely Shop or Field Fabricated Vessels Only)
As Required by the Provisions of the ASME Code Rules, Section VIII, Division 1

Form U1-A
01

1. Manufactured and certified by Indu trial Service & Fabricators, Inc. 1425 o8th Bu leson Boulevard Burleson, Texas, USA 76028
(Name and address of manufacturer)

2. Manufactured for Sachem, Inc., 2311 Pipeline Rd, C..leburne, TX 76031
(Name and address of purchaser)

3. Location of installation Unknown
(Name and address)

4. Type Horizontal (Horiz. or vert tank) | 05-5987 (Mfgr's serial No.) | --- (CRN) | 7879-1 Rev. 1 (Drawing No.) | 5653 (Nat'l. Bd. No.) | 2005 (Year Built)

5. The chemical and physical properties of all parts meet the requirements of material specifications of the ASME BOILER AND PRESSURE VESSEL CODE. The design, construction, and workmanship conform to ASME Rules, Section VIII, Division 1 2004 Year to --- Addenda (Date) --- Code Case Nos. --- Special Service per UG-120 (d)

6. Shell: SA-240-304 Matl. (Spec. No., Grade) | 0.625" Nom. Thk. (in.) | 0 Corr. Allow. (in.) | 6' 0" OD Diam. I.D. (ft. & in.) | 18' 0" Length (overall) (ft. & in.)

7. Seams: Welded, Dbl. Butt Long (Welded, Dbl., Sngl., Lap, Butt) | Spot R.T. (Spot or Full) | 85% Eff. (%) | --- H.T. Temp. (°F.) | --- Time (hr.) | Welded,Dbl.Butt,Type1 Girth (Welded, Dbl., Sngl., Lap, Butt) | Spot R.T. (Spot, Partial or Full) | 3 No. of Courses

8. Heads: (a) Matl. SA-240-304 (Spec. No., Grade) (b) Matl. (Spec. No., Grade)

	Location (Top, Bottom, Ends)	Minimum Thickness	Corrosion Allowance	Crown Radius	Knuckle Radius	Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side to Pressure (Convex or Concave)
(a)	Ends	0.500"	0	---	---	2:1	---	---	---	Concave,Convex
(b)										

If removable, bolts used (describe other fastenings) (Matl., Spec. No., Gr., Size, No.)

9. MAWP 250 / 15 Ext psi at max. temp. 200 °F

Min. design metal temp. -20 °F at 250 psi. Hydro., ~~Pneu., or Comb.~~ test pressure 325 psi.

10. Nozzles, inspection and safety valve openings:

Purpose (Inlet, Outlet, Drain)	No.	Diam. or Size	Type	Matl.	Nom. Thk.	Reinforcement Matl	How Attached	Location
Manway	1	24"	300#SOFlg	SA-240-304	0.375"	SA-516-70	Welded	Shell
Relief	1	3"	300#SOFlg	SA-312TP304	0.216"	SA-516-70	Welded	Shell
VapOut,Reactor Feed	3	2"	300#SOFlg	SA-312-TP304	0.154"	Inherent	Welded	Shell
Recir, In, Liq In	2	1"	300#SOFlg	SA-312-TP304	0.133"	Inherent	Welded	Shell
Vapor In	1	1"	300#SOFlg	SA-312-TP304	0.133"	Inherent	Welded	Shell
Instruments Misc.	4	1"	300#SOFlg	SA-312-TP304	0.133"	Inherent	Welded	Shell

11. Supports: Skirt No (Yes or no) Lugs ___ (No.) Legs ___ (No.) Other Saddle Supports (2) (Describe) Attached Shell, Welded (Where and how)

12. Remarks: Manufacturer's Partial Data Reports properly identified and signed by Commissioned Inspectors have been furnished for the following items of the report: (Name of part, item number, Mfgr's. name and identifying stamp)

For Non-Corrosive Service
M.D.M.T. Per UHA 51 (d)(1)(a)
Designed Per UG 22(a)

CERTIFICATE OF SHOP/FIELD COMPLIANCE

We certify that the statements made in this report are correct and that all details of design, material, construction, and workmanship of this vessel conform to the ASME Code for Pressure Vessels, Section VIII, Division 1. "U" Certificate of Authorization No. 24,474 expires August 23, 2007

Date 7-28-05 Co. name I ndustrialService & Fabricators, Inc. (Manufacturer) Signed W. D. [signature] (Representative)

CERTIFICATE OF SHOP/FIELD INSPECTION

Vessel constructed by Industrial Service & Fabricators, Inc at Burleson, Texas. I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of Texas and employed by BSIM RE have inspected the component described in this Manufacturer's Data Report on 7-28-05, and state that, to the best of my knowledge and belief, the Manufacturer has constructed this pressure vessel in accordance with ASME Code, Section VIII, Division 1. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in the Manufacturer's Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or loss of any kind arising from or connected with this inspection.

Date 7-28-05 Signed [signature] (Authorized Inspector) Commissions 8414 Dt. Tx. 897 Nat'l. Board (Incl. endorsements, State, Prov. and No.)