FORM U-1A MANUFACTURERS' DATA REPORT FOR PRESSURE VESSELS
(Alternate Form for Single Chamber, Completely Shop-Fabricated Vessels Only)
As Required by the Provisions of the ASME Code Rules, Section VIII, Division 1

1. Manufactured by Riley Beaird, Inc., Shreveport, Louisiana
2. Manufactured for Applied Engineering Company, Orangeburg, South Carolina
3. Location of Installation
4. Type Horiz. Tank (Horiz. or vert. tank) 140435-01-9 (Mfgr's Serial No.) 140435-01-C (CRN) (Drawing No.) 51113 (Nat'l Brd. No.) (Year Built) 1977

5. The chemical and physical properties of all parts meet the requirements of material specifications of the ASME BOILER AND PRESSURE VESSEL CODE. The design, construction, and workmanship conform to ASME Rules, Section VIII, Division 1 1974 (Year) and Addenda to Winter 1976 (Date) and Code Case Nos. N/A

* As Indicated in the Shop Inspector's Log.

Special Service per UG-120(d) N/A

Manufacturers' Partial Data Reports properly identified and signed by Commissioned Inspectors have been furnished for the following items of the report: N/A (Name of part, item number, Mfgr's name and identifying stamp)

6. Shell: Matl. SA-612 (Spec. No., Grade) Nom. Thk 13/16 in. Corr. Allow. 0 in. Diam. 10 ft. 10-1/4 in. Length 36 ft. 0-1/2 in.

7. Seams: Long Dbl. Butt (Welded, Dbl., Sngl., Lap, Butt) R.T. Full (Spot or Full) Efficiency 100 % H.T. Temp. N/A F Time hr.

Girth Dbl. Butt (Welded, Dbl., Sngl., Lap, Butt) R.T. Full (Spot, Partial, or Full) No. of Courses 5

8. Heads: (a) Material SA-612 (Spec. No., Grade) (b) Material (Spec. No., Grade)

Head Seams Spot X-Rayed Joint Eff. 85%

Location (Top, Bottom, Ends)	Min. Thk.	Corr. Allow.	Crown Radius	Knuckle Radius	Ellipse Ratio	Conical Apex Angle	Hemisph. Radius	Flat Diam.	Side to Pressure (Convex or Concave)
Ends	1/2"	0"					65.1317"		Concave

If removable, bolts used (describe other fastenings) (Material, Spec. No., Gr., Size, No.)

9. Constructed for max. allowable working pressure 250 psi at max. temp. 125 F. Min. temp. (when less than -20 F) F. Hydrostatic test pressure 375 psi

10. Safety Valve Outlets Number Size Location

11. Nozzles and Inspection Openings Mwy. (1) 16" Pad SA-516-70 150# Welded Shell

Purpose (Inlet, Outlet, Drain)	No.	Diam. or Size	Type	Matl.	Nom. Thk.	Reinforcement Matl.	How Attached	Location
Liq. In (1)	3" Liq. Out	(1) 3"	Spec. Pad	SA-516-70	300#		Welded	Shell
Vapor	(1)	2"	Spec. Pad	SA-516-70	300#		Welded	Shell
Float Ga.	(1)	2-1/4"	Spec. Pad	SA-516-70	1-7/16"		Welded	Head
Rot. Ga.	(1)	1"	Cplg.	SA-105	3000#		Welded	Head
Fix Tube &	Press. Ga.	(1) 1" X	1/4" Red.	Cplg. SA-105	3000#		Welded	Head
Thermowell	(1)	3/4"	Pipe Stub	SA-106-B	.154"		Welded	Head

12. Supports: Skirt No (Yes or no) Lugs (No.) Legs (No.) Other (Describe) Attached (Where and how)

13. Remarks 130-1/4" I.D. X 46' - 9-7/8" O.A. Length 29,846 W.G. Propane Storage Tank.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and that all details of design, material, construction, and workmanship of this vessel conform to the ASME Code for Pressure Vessels, Section VIII, Division 1.

Date 8/26/77 Signed RILEY BEAIRD, INC. (Manufacturer) by W. Thomas (Representative)

"U" Certificate of Authorization No. 11,840 expires March 12, 19 79

CERTIFICATE OF SHOP INSPECTION

Vessel made by RILEY BEAIRD, INC. at SHREVEPORT, LOUISIANA

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of and employed by COMM. UNION INS. CO. OF BOSTON, MASS. have inspected the pressure vessel described in this Manufacturers' Data Report on * 8/3, 19 77, and state that, to the best of my knowledge and belief, the Manufacturer has constructed this pressure vessel in accordance with ASME Code, Section VIII, Division 1. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied concerning the pressure vessel described in the Manufacturers' Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Signed [illegible] Date 8/26/77 Commissions N. B. Comm. 4497, N. B. Comm. 7167 (Nat'l Board, State, Province and No.)

Note to Buyer: This form may be obtained from the National Board of Boiler and Pressure Vessel Inspectors, Columbus, Ohio.

FORM R-2 REPORT OF ALTERATION

in accordance with provisions of the National Board Inspection Code

1. Work performed by T. F. Tigert Company Inc (name of alteration organization) 5 (Form R No.)

2135 Industrial Street Lancaster Texas 75134 (address) 14983 (P.O. No. Job No. etc.)

2. Owner Sachem Inc. (name)

2311 Pipeline Road Cleburne Texas 76031 (address)

3. Location of installation Same (name)

(address)

4. Unit identification Pressure Vessel (boiler, pressure vessel) Name of original manufacturer Riley Beaird, Inc

5. Identifying nos.: 140435-01- (mfg serial no.) 51113 (National Board No.) (jurisdiction no.) (other) 1977 (year built)

6. NBIC Edition/Addenda: 1998 (edition) 2000 (addenda)

Original Code of Construction for Item: ASME Sect VIII (name/section/division) Unknown (edition/addenda)

Construction Code Used for Alteration Performed: ASME VIII (name/section/division) 98 A 00 (edition/addenda)

7. Description of work: (use supplemental sheet, Form R-4, if necessary)

Install nozzels to shell SA612, One 8" SA 106B Sch 80 with flange 300# sch 80 and reinforcing pad SA-516-GR70 X 14 1/2" dia. X .625", One 3" SA 106B with flange 300# sch 80 and reinforcing pad SA-516-GR70 X 5" dal X 3/8", Two 1" SA-106B Sch 80 with flange 300# sch. 80. All Flanges SA105 RFWN Alt. Based on UT Reading .811"

Pressure Test, if applied 375 psi

8. Replacement Parts: Attached are Manufacturer's Partial Data Reports or Form R-3s properly completed for the following items of this report:

(name of part, item number, data report type, mfr's. name and identifying stamp)

9. Remarks:

NATIONAL BOARD INSPECTION CODE

Form R-2 (back)

5
(Form R No.)

DESIGN CERTIFICATION

I, Gary Radney , certify that to the best of my knowledge and belief the statements in this report are correct and that the Design Change described in this report conforms to the National Board Inspection Code.

National Board 'R' Certificate of Authorization No. 79 expires on 6/17/03.

Date 11/17/01 T F TIGERT COMPANY Inc Signed Gary Radney
(name of design organization) (authorized representative)

CERTIFICATE OF DESIGN CHANGE REVIEW

I, Mike Anderson, holding a valid Commission issued by The National Board of Boiler and Pressure Vessel Inspectors and certificate of competency issued by the jurisdiction of Texas and employed by H.S.B.I. & I. Co. of Hartford, Ct have reviewed the design change as described in this report and state that to the best of my knowledge and belief such change complies with the applicable requirements of the National Board Inspection Code.

By signing this certificate, neither the undersigned nor my employer makes any warranty, expressed or implied, concerning the work described in this report. Furthermore, neither the undersigned nor my employer shall be liable in any manner for any personal injury, property damage or loss of any kind arising from or connected with this inspection.

Date 11/17/01 Signed Mike Anderson Commissions NB11561 A TX 1505
(inspector) (National Board (incl endorsements), and jurisdiction, and no.)

CONTRUCTION CERTIFICATION

I, Gary Radney, certify that to the best of my knowledge and belief the statements in this report are correct and that all material, construction, and workmanship on this Alteration conforms to the National Board Inspection Code.

National Board 'R' Certificate of Authorization No. 79 expires on 6/17/03.

Date 11/17/01 T. F. Tigert Company Inc Signed Gary Radney
(name of alteration organization) (authorized representative)

CERTIFICATE OF INSPECTION

I, Mike Anderson , holding a valid Commission issued by The National Board of Boiler and Pressure Vessel Inspectors and certificate of competency issued by the jurisdiction of Texas and employed by H.S.B.I. & I. Co. of Hartford, Ct. have inspected the work described in this report on 11/17/01 and state that to the best of my knowledge and belief this work complies with the applicable requiremetns of the National Board Inspection Code.

By signing this certificate, neither the undersigned nor my employer makes any warranty, expressed or implied, concerning the work described in this report. Furthermore, neither the undersigned nor my employer shall be liable in any manner for any personal injury, property damage or loss of any kind arising from or connected with this inspection.

Date 11/17/01 Signed Mike Anderson Commissions NB11561 A TX1505
(inspector) (National Board (incl endorsements), and jurisdiction, and no.)