# System

# Two-pump station, system

Project EX-1, revision 1.1.

The station: the pump cabinet +C1 and, external to it (+EXT), the two pump motors, the network switch and the upstream distribution board's terminals, joined by their cables.


| Revision | Date | Description | Created | Checked | Approved |
|---|---|---|---|---|---|
| 1.1 | 2026-09-23 | First issue | SK | | |
| 1.2 | 2026-10-06 | The cabinet is a unit with no place of its own (owner ruling 2026-10-06) | SK | | |
| 1.3 | 2026-10-06 | -W3-W1 prints as -W3 (Fransys 0.11.0, R129 lone cable) | SK | | |

| | | | | | | | |
|---|---|---|---|---|---|---|---|
| Title<br>**Two-pump station** | | | Number<br>EX-1 | Revision<br>1.3 | Revision date<br>2026-10-06 | | |
| Customer<br>Example works | Author<br>fransys-examples | Page title<br>Cover | Scope | Sheet | Page<br>1 of 8 | | |

# Notes


The cable drawings show every core and both ends of each cable outside the cabinet.


| | | | | | |
|---|---|---|---|---|---|
| Title<br>**Two-pump station** | | | Number<br>EX-1 | Revision<br>1.3 | Revision date<br>2026-10-06 |
| Customer<br>Example works | Author<br>fransys-examples | Page title<br>Notes | Scope | Sheet | Page<br>2 of 8 |




| | | | | | |
|---|---|---|---|---|---|
| Title: **Two-pump station** | | | Number: EX-1 | Revision: 1.3 | Revision date: 2026-10-06 |
| Customer: Example works | Author: fransys-examples | Page title: Block diagram | Scope | Sheet: B1 / 1 | Page: 3 of 8 |


## 1119304, OELFLEX CLASSIC 110, 4G1.5, 4 x 1.5 mm²





| Title | | | Number | Revision | Revision date | | |
|---|---|---|---|---|---|---|---|
| **Two-pump station** | | | EX-1 | 1.3 | 2026-10-06 | | |
| Customer | Author | Page title | Scope | Sheet | Page | | |
| Example works | fransys-examples | 1119304 | | | 4 of 8 | | |

## 1119405, OELFLEX CLASSIC 110, 5G2.5, 5 x 2.5 mm²




| | | | | | | |
|---|---|---|---|---|---|---|
| Title: **Two-pump station** | | | Number: EX-1 | Revision: 1.3 | Revision date: 2026-10-06 | |
| Customer: Example works | Author: fransys-examples | Page title: 1119405 | Scope: | Sheet: | Page: 5 of 8 | |

## 2170465, ETHERLINE Cat.6A P, industrial Ethernet cable, S/FTP, 8 x 0.33 mm²




| | | | | | | |
|---|---|---|---|---|---|---|
| Title: **Two-pump station** | | | Number: EX-1 | Revision: 1.3 | Revision date: 2026-10-06 | |
| Customer: Example works | Author: fransys-examples | Page title: 2170465 | Scope: | Sheet: | Page: 6 of 8 | |

| Designation | Mpn | Description | Core count | Gauge mm2 | Length mm | From label | To label |
|---|---|---|---|---|---|---|---|
| -W1 | 1119405 | OELFLEX CLASSIC 110, 5G2.5 | 5 | 2.5 | 10000 | -U1-X1 | +EXT-X0 |
| -W3 | 2170465 | ETHERLINE Cat.6A P, industrial Ethernet cable, S/FTP | 8 | 0.33 | 3000 | +EXT-W3-J1 | +EXT-W3-J2 |
| -W11 | 1119304 | OELFLEX CLASSIC 110, 4G1.5 | 4 | 1.5 | 15000 | -U1-X3 | +EXT-M1 |
| -W21 | 1119304 | OELFLEX CLASSIC 110, 4G1.5 | 4 | 1.5 | 15000 | -U1-X3 | +EXT-M2 |

| | | | | | | |
|---|---|---|---|---|---|---|
| Title<br>**Two-pump station** | | | Number<br>EX-1 | Revision<br>1.3 | Revision date<br>2026-10-06 | |
| Customer<br>Example works | Author<br>fransys-examples | Page title<br>Cable list | Scope | Sheet | Page<br>7 of 8 | |

| Mpn | Revision | Manufacturer | Description | Count | Designations |
|---|---|---|---|---|---|
| 1119304 | | Lapp | OELFLEX CLASSIC 110, 4G1.5 | 2 | -W11; -W21 |
| 1119405 | | Lapp | OELFLEX CLASSIC 110, 5G2.5 | 1 | -W1 |
| 1LE1003-0EB42-2AA4 | | Innomotics | Induction motor, 4-pole, IE3, 400 V Y, frame 90, foot B3; 3.15 A; 1.5 kW | 2 | -M1; -M2 |
| 21700601 | | Lapp | EPIC DATA RJ45, Cat.6A, T568B, field-installable plug | 2 | -W3-J1; -W3-J2 |
| 2170465 | | Lapp | ETHERLINE Cat.6A P, industrial Ethernet cable, S/FTP | 1 | -W3 |
| SKX-PC-2 | 1.7 | | Pump cabinet | 1 | -U1 |

| | | | | | | |
|---|---|---|---|---|---|---|
| Title<br>**Two-pump station** | | | Number<br>EX-1 | Revision<br>1.3 | Revision date<br>2026-10-06 | |
| Customer<br>Example works | Author<br>fransys-examples | Page title<br>BOM | Scope | Sheet | Page<br>8 of 8 | |