System

Two-pump station, system

Project EX-1, revision 1.1.

The station: the pump cabinet +C1 and, external to it (+EXT), the two pump motors, the network switch and the upstream distribution board's terminals, joined by their cables.


Revision	Date	Description	Created	Checked	Approved
1.1	2026-09-23	First issue	SK		
1.2	2026-10-06	The cabinet is a unit with no place of its own (owner ruling 2026-10-06)	SK		
1.3	2026-10-06	-W3-W1 prints as -W3 (Fransys 0.11.0, R129 lone cable)	SK		
1.4	2026-10-25	Pump cabinet 1.8: LADN22 contact blocks (R780)	SK		
1.5	2026-10-26	Pump cabinet 1.9: terminal strip X01 is X4, breaker F01 is F1 (R1114)	SK		
1.6	2026-10-28	Pump cabinet 1.10: no mate, board unit or harness line; the Ethernet link W3 is a cable	SK		

Title	Number	Revision	Revision date	
Two-pump station	EX-1	1.6	2026-10-28	
Customer: Example works	Author: fransys-examples	Page title: Cover	Scope	Sheet	Page: 1 of 8

Notes


The cable drawings show every core and both ends of each cable outside the cabinet.


Title **Two-pump station**			Number EX-1	Revision 1.6	Revision date 2026-10-28
Customer Example works	Author fransys-examples	Page title Notes	Scope	Sheet	Page 2 of 8



Title: **Two-pump station**			Number: EX-1	Revision: 1.6	Revision date: 2026-10-28
Customer: Example works	Author: fransys-examples	Page title: Block diagram	Scope	Sheet: B1 / 1	Page: 3 of 8


1119304, OELFLEX CLASSIC 110, 4G1.5, 4 x 1.5 mm²






Title: **Two-pump station**			Number: EX-1	Revision: 1.6	Revision date: 2026-10-28
Customer: Example works	Author: fransys-examples	Page title: 1119304	Scope:	Sheet:	Page: 4 of 8

1119405, OELFLEX CLASSIC 110, 5G2.5, 5 x 2.5 mm²



Title: **Two-pump station**			Number: EX-1	Revision: 1.6	Revision date: 2026-10-28	
Customer: Example works	Author: fransys-examples	Page title: 1119405	Scope:	Sheet:	Page: 5 of 8	

2170465, ETHERLINE Cat.6A P, industrial Ethernet cable, S/FTP, 8 x 0.33 mm²



Title: **Two-pump station**			Number: EX-1	Revision: 1.6	Revision date: 2026-10-28	
Customer: Example works	Author: fransys-examples	Page title: 2170465	Scope:	Sheet:	Page: 6 of 8	

Designation	Mpn	Description	Core count	Gauge mm2	Length mm	From label	To label
-W1	1119405	OELFLEX CLASSIC 110, 5G2.5	5	2.5	10000	-U1-X1	+EXT-X0
-W3	2170465	ETHERLINE Cat.6A P, industrial Ethernet cable, S/FTP	8	0.33	3000	-U1-C1-X1	+EXT-K1
-W11	1119304	OELFLEX CLASSIC 110, 4G1.5	4	1.5	15000	-U1-X3	+EXT-M1
-W21	1119304	OELFLEX CLASSIC 110, 4G1.5	4	1.5	15000	-U1-X3	+EXT-M2

Title **Two-pump station**			Number EX-1	Revision 1.6	Revision date 2026-10-28		
Customer Example works	Author fransys-examples	Page title Cable list	Scope	Sheet	Page 7 of 8		

Mpn	Revision	Manufacturer	Description	Count	Designations
1119304		Lapp	OELFLEX CLASSIC 110, 4G1.5	2	-W11; -W21
1119405		Lapp	OELFLEX CLASSIC 110, 5G2.5	1	-W1
1LE1003-0EB42-2AA4		Innomotics	Induction motor, 4-pole, IE3, 400 V Y, frame 90, foot B3; 3.15 A; 1.5 kW	2	-M1; -M2
2170465		Lapp	ETHERLINE Cat.6A P, industrial Ethernet cable, S/FTP	1	-W3
SKX-PC-2	1.10		Pump cabinet	1	-U1

Title: **Two-pump station**				Number: EX-1	Revision: 1.6	Revision date: 2026-10-28	
Customer: Example works	Author: fransys-examples	Page title: BOM		Scope:	Sheet:	Page: 8 of 8	