

Computing Infrastructures



POLITECNICO DI MILANO



The Datacenter as a Computer: Building and Infrastructures

POLITECNICO DI MILANO




The topics of the course: what are we going to see today?

2

A. HW Infrastructures:

- **System-level:** Computing Infrastructures and Data Center Architectures, Rack/Structure;
- **Node-level:** Server (computation, HW accelerators), Storage (Type, technology), Networking (architecture and technology);
- **Building-level:** **Cooling systems, power supply, failure recovery**



B. SW Infrastructures:


- **Virtualization:** Process/System VM, Virtualization Mechanisms (Hypervisor, Para/Full virtualization)
- **Computing Architectures:** Cloud Computing (types, characteristics), Edge/Fog Computing, X-as-a service
- **Machine and deep learning-as-a-service**

C. Methods:

- **Reliability and availability of datacenters** (definition, fundamental laws, RBDs)
- **Disk performance** (Type, Performance, RAID)
- **Scalability and performance of datacenters** (definitions, fundamental laws, queuing network theory)



BUILDING AND INFRASTRUCTURE






Aerial view of a Google data center campus in Iowa (US)⁴





A Google data center building





The main components of a typical data center

COOLING SYSTEM





Image taken from Barroso



Not just computation, storage and networking

WSC has other important components related to **power delivery, cooling, and building infrastructure** that also need to be considered






DATA CENTER POWER SYSTEMS

In order to protect against power failure, battery and diesel generators are used to backup the external supply.



Diesel generators




Batteries





DATA CENTER POWER SYSTEMS

In order to protect against power failure, battery and diesel generators are used to backup the external supply.



Diesel generators

The UPS typically combines three functions in one system:

- contains a transfer switch that chooses the active power input (either utility power or generator power)
- contains some form of energy storage (electrical, chemical, or mechanical) to bridge the time between the utility failure and the availability of generator power
- conditions the incoming power feed, removing voltage spikes or sags, or harmonic distortions in the AC feed




DATA CENTER COOLING SYSTEMS

IT equipment generates a lot of heat: the **cooling system** is usually a very expensive component of the datacenter, and it is composed by coolers, heat-exchangers and cold water tanks.



Turbo coolers

Cold water tanks




Heat exchangers





- The simplest topology is fresh air cooling (or air economization)—essentially, opening the windows.
- This is a single «open-loop» system






Open vs Closed Loop

- Free cooling, i.e., **open-loop**, refers to the use of cold outside air to either help the production of chilled water or directly cool servers. It is not completely free in the sense of zero cost, but it involves very low-energy costs compared to chillers.
- **Closed-loop** systems come in many forms, the most common being the air circuit on the data center floor.
 - The goal is to isolate and remove heat from the servers and transport it to a heat exchanger.
 - Cold air flows to the servers, heats up, and eventually reaches a heat exchanger to cool it down again for the next cycle through the servers.



Closed-loop with two loops


- ✓ The airflow through the underfloor plenum, the racks, and back to the CRAC (a 1960s term for *computer room air conditioning*) defines the primary air circuit, i.e., the **first loop**.
- ✓ The **second loop** (the liquid supply inside the CRACs units) leads directly from the CRAC to external heat exchangers (typically placed on the building roof) that discharge the heat to the environment.





A three-loop system commonly used in large-scale data center

14





A water-cooled chiller can be thought of as a water-cooled air conditioner



Cooling towers cool a water stream by evaporating a portion of it into the atmosphere. They do not work as well in very cold climates because they need additional mechanisms to prevent ice formation




A critical comparison

Each topology presents tradeoffs in complexity, efficiency, and cost:

- ✓ **Fresh air cooling** can be very efficient but does not work in all climates, requires filtering of airborne particulates, and can introduce complex control problems.
- ✓ **Two-loop systems** are easy to implement, relatively inexpensive to construct, and offer isolation from external contamination, but typically have lower operational efficiency.
- ✓ **A three-loop system** is the most expensive to construct and has moderately complex controls, but offers contaminant protection and good efficiency.



- **In-rack cooler** adds an air-to-water heat exchanger at the back of a rack so the hot air exiting the servers immediately flows over coils cooled by water, essentially reducing the path between server exhaust and CRAC input
- **In-row cooling** works like in-rack cooling except the cooling coils are not in the rack, but adjacent to the rack.




In-row cooling



Liquid cooling


- We can directly cool server components using cold plates, i.e., local liquid-cooled heat sinks:
 - Impractical to cool all compute components with cold plates.
 - Components with the highest power dissipation are targeted for liquid cooling while other components are air-cooled.
- The liquid circulating through the heat sinks transports the heat to a liquid-to-air or liquid-to-liquid heat exchanger that can be placed close to the tray or rack, or be part of the data center building (such as a cooling tower).

Google TPUs






Container-based Data Centers



Container-based data centers go one step beyond in-row cooling by placing the server racks inside a container (typically 6 to 12 mt long) and integrating heat exchange and power distribution into the container as well.



Container-based Data Centers





Data-center power consumption

- Data-center power consumption is an issue, since it can reach several MWs.
- Cooling usually requires about half the energy required by the IT equipment (servers + network + disks).
- Energy transformation creates also a large amount of energy wasted for running a datacenter.
- DCs consume 3% of global electricity supply (416.2 TWh > UK's 300 TWh).
- DCs produce 2% of total greenhouse gas emissions (same as worldwide air traffic pre-pandemic).
- DCs produce as much CO₂ as The Netherlands or Argentina.



Data-center power consumption

- Data-center power consumption is an issue, since it can reach several MWs.
- Cooling usually requires about half the energy required by the IT equipment (servers + network + disks).
- Energy transformation creates also a large amount of energy wasted for running a datacenter.

Amortized Cost	Component	Sub-Components
~45%	Servers	CPU, memory, disk
~25%	Infrastructure	UPS, cooling, power distribution
~15%	Power draw	Electrical utility costs
~15%	Network	Switches, links, transit




- **Power usage effectiveness (PUE)** is the ratio of the total amount of energy used by a DC facility to the energy delivered to the computing equipment

$$PUE = \frac{\textit{Total Facility Power}}{\textit{IT Equipment power}}$$

- Total facility power = covers IT systems (servers, network, storage) + other equipment (cooling, UPS, switch gear, generators, lights, fans, etc.)
- Data Center infrastructure Efficiency (DCiE): PUE inverse




AVERAGE PUE OF LARGEST DATA CENTER



AVERAGE PUE
1.8 - 1.89

PUE	DCiE	Level of Efficiency
3.0	33%	Very Inefficient
2.5	40%	Inefficient
2.0	50%	Average
1.5	67%	Efficient
1.2	83%	Very Efficient


2012 Study



Google DCs




AVERAGE PUE OF LARGEST DATA CENTER



**AVERAGE
PUE
1.8 - 1.89**

Continuous PUE Improvement Average PUE for all data centers



2012 Study

Google DCs



Data-center tiers

Data-center availability is defined by in four different tier level. Each one has its own requirements.

Tier Level	Requirements
1	<ul style="list-style-type: none">• Single non-redundant distribution path serving the IT equipment• Non-redundant capacity components• Basic site infrastructure with expected availability of 99.671%
2	<ul style="list-style-type: none">• Meets or exceeds all Tier 1 requirements• Redundant site infrastructure capacity components with expected availability of 99.741%
3	<ul style="list-style-type: none">• Meets or exceeds all Tier 2 requirements• Multiple independent distribution paths serving the IT equipment• All IT equipment must be dual-powered and fully compatible with the topology of a site's architecture• Concurrently maintainable site infrastructure with expected availability of 99.982%
4	<ul style="list-style-type: none">• Meets or exceeds all Tier 3 requirements• All cooling equipment is independently dual-powered, including chillers and heating, ventilating and air-conditioning (HVAC) systems• Fault-tolerant site infrastructure with electrical power storage and distribution facilities with expected availability of 99.995%