ORIGINAL ISSUE DATE: May 10, 2011

Recertification due: May 2018

An Activity Sponsored and Administered by Intertek

PROGRAM ADMINISTRATOR
DEPARTMENT ALECP
INTERTEK
3933 U.S. ROUTE 11
CORTLAND, NY 13045-0950

Nexans Energy USA Inc
25 Oakland Ave.
Chester, NY 10918

AIRPORT LIGHTING EQUIPMENT CERTIFICATION PROGRAM

CERTIFICATE OF CONFORMANCE

The product described below is hereby approved for listing in the next issue of the Federal Aviation Administration (FAA) Advisory Circular (AC) 150/5345-53, Appendix 3 Addendum "Airport Lighting Equipment Certification Program. The approval is based on successful completion of tests in accordance with the specifications listed in, and the requirements for approval described in the Advisory Circular, and the reporting to the Program Administrator the results of such tests, accompanied by related documents by an Intertek recognized testing laboratory. The certification is not valid for a product modified with non-OEM replacement parts or non-production components.

L-824 – Underground Electrical Cable for Airport Lighting Circuits (AC 150/5345-7E)			
Manufacturer	Type	Voltage Rating	Manufacturer's Catalog Number
Nexans Energy USA Inc.	C	5000V	611491; 611533; 635290; 660615; 660616

1. This Equipment requires continuing validation in accordance with the requirements of AC 150/5345-53, and the Intertek Airport Lighting Equipment Certification Program.

2. Product tested and Report issued by: Intertek; Cable Technologies

(A) Report No: G100110303CRT-001a; 10-064 (B) Date of Report: 5/2010; 11/2010

NOTE: PLEASE REVIEW, AND ADVISE ADMINISTRATOR AT INTERTEK IMMEDIATELY IF DATA, AS SHOWN, NEED TO BE CORRECTED.

Approved for Certification by:

Jeremy N. Downs, P.E., Program Administrator

Date: May 10, 2011

Form AL-3 1/2006