ATTN:

IN RESPONSE TO YOUR REQUEST FOR SPECS ON 500 MCM GA UL CABLE, PLEASE FIND THE FOLLOWING:

1) **PART #: TBD**
2) **GA: 500 MCM**
3) **STRANDING: 19X266/30 BC**
4) **NOMINAL O.D: 1.16 OD**
5) **WALL THICKNESS: .100**
6) **VOLTAGE: 1000 VOLT**
7) **JACKET TYPE: 105C DEGREE PVC**
8) **PRINT LEGEND: E314968 500 MCM (UL) MTW OR THHW FOR CT USE OR AWM 1339/1284 600V OR 1032/10269 1000V VW-1 SUN RES---240954 CSA AWM I A/B 105C 600/1000V FT1**
9) **RATED FOR CT USE**

THIS IS TO CONFIRM THAT THE 500 MCM GA UL CABLE LISTED MEETS THE ABOVE SPECS.

_____

ANDY HARWOOD
VICE PRESIDENT OF SALES