529 Thomas Drive, Bensenville, IL 60106 | TF: 888.518.8086 | FX: 630.860.5944

Specification Sheet

Lake Cable Part #: TJ168SPOS

Description: 16 AWG 8 pairs type JX thermocouple extension wire, PVC insulation, individually & overall shielded with an overall PVC jacket for PLTC and ITC 105'C

1. **Conductor**
   - 1.1. AWG Size & Stranding: 16 AWG Solid
   - 1.2. Material: Type JP (Iron) & Type JN (Constantan)
   - 1.3. Conductor Count: 8 Pairs

2. **Insulation**
   - 2.1. Material: Polyvinylchloride
   - 2.2. Wall Thickness: 0.016"
   - 2.3. Color Code: White (JP) & Red (JN) Numbered

3. **Assembly**
   - 3.1. Pair Lay Length: 2.50" LHL (4.80 Tw/Ft)
   - 3.2. Pair Drain Wire: 18 AWG, 7 Strand Tinned Copper
   - 3.3. Pair Shield: Foil Free Edged Aluminum/Mylar Tape – 100% coverage
   - 3.4. Cable Lay Length: 7.00" LHL (1.72 Tw/Ft)
   - 3.5. Cable Binder: Clear Mylar
   - 3.6. Cable Shield: Aluminum/Mylar Tape – 100% coverage
   - 3.7. Cable Drain Wire: 16 AWG, 7 Strand Tinned Copper
   - 3.8. Fillers: N/A

4. **Jacket**
   - 4.1. Material: Polyvinylchloride
   - 4.2. Wall Thickness: 0.050"
   - 4.3. Diameter: 0.571" +/- 0.045"
   - 4.4. Color: Black
   - 4.5. Ripcord: Yes
   - 4.6. Weight: 261 Lbs/Mft

5. **Markings**
   - 5.1. Type: Cable permanently identified via surface inkjet print
   - 5.2. Legend: LAKE CABLE E208158 16AWG 8PR 105'C SPOS (UL) ITC TYPE JX THCPL EXTN PVC JACKET SUN RES OR PLTC FT-4 "ROHS II" MADE IN USA
   - 5.3. Footage Markers: Yes

6. **Standards**
   - 6.1. UL listed as type PLTC Sunlight Resistant per UL standard 13 and as type ITC per UL standard 2250
   - 6.2. Cable meets IEEE 383 & UL 1581 (1685) 70,000 BTU/HR flame test requirements
   - 6.3. Meets IEEE 1202 flame test
   - 6.4. All materials used in the manufacture of this cable are RoHS II & REACH compliant
   - 6.5. Made in the USA

Your signature constitutes that you have read and agreed to this specification sheet and upon confirmation of your order; this item may be non-cancelable and non-returnable.

Signature

Company

Date

ALL SPECIFIED PARAMETERS ARE NOMINAL AND SUBJECT TO VERIFICATION