529 Thomas Drive, Bensenville, IL 60106 | TF: 888.518.8086 | FX: 630.860.5944

Specification Sheet

Lake Cable Part #: BT222STFPBRD

Description: 22 AWG 1 pair 7 strand tinned copper wire, Foam PE insulation, an aluminum mylar shield with a stranded tinned copper drain wire, a tinned copper braid and an overall PVC jacket.

1. **Conductor**
   - 1.1. AWG Size & Stranding: 22 AWG 7 Strands Class B
   - 1.2. Material: Annealed Tinned Copper
   - 1.3. Conductor Count: 1 Pair

2. **Insulation**
   - 2.1. Material: Foamed Polyethylene
   - 2.2. Wall Thickness: 0.027”
   - 2.3. Color Code: White/Blue x Blue/White

3. **Assembly**
   - 3.1. Nominal Lay Length: 3.75” LHL (3.2 Tw/Ft)
   - 3.2. Shield: Aluminum/Mylar Tape – 100% Coverage
   - 3.3. Drain Wire: 22 AWG 7 Strand Tinned Copper
   - 3.4. Braid: 36 AWG Tinned Copper – 65% Coverage

4. **Jacket**
   - 4.1. Material: Polyvinylchloride
   - 4.2. Wall Thickness: 0.047”
   - 4.3. Diameter: 0.282”
   - 4.4. Color: Black
   - 4.5. Ripcord: Yes
   - 4.6. Weight: 41 Lbs/Mft

5. **Markings**
   - 5.1. Type: Cable permanently identified via surface inkjet print
   - 5.2. Legend: LAKE CABLE E171202 22AWG 1PR SHLD (UL) PLTC OR (UL) CMG C(UL)US 75’C SUN RES FT-4 “ROHS II” REACH MADE IN USA
   - 5.3. Footage Markers: Yes

6. **Nominal Electrical Characteristics**
   - 6.1. Impedance: 120Ω ± 10%
   - 6.2. Capacitance: 11 pF/ft. ± 10%
   - 6.3. DC Resistance: 17.04Ω/Mft. @ 20°C
   - 6.4. VP: 78%

7. **Standards**
   - 7.1. UL listed as type PLTC per UL standard 13 and as type CMG c(UL)US per UL standard 444
   - 7.2. Cable is UL approved for Sunlight Resistant Applications.
   - 7.3. All materials used in the manufacturing of this cable are RoHS II and REACH compliant
   - 7.4. Maximum Operating Voltage: 300V RMS
   - 7.5. Meets EIA Standard RS485
   - 7.6. Made in the USA

Your signature constitutes that you have read and agreed to this specification sheet and upon confirmation of your order; this item may be non-cancelable and non-returnable.

_____
Signature

_____
Company

ALL SPECIFIED PARAMETERS ARE NOMINAL AND SUBJECT TO VERIFICATION