529 Thomas Drive, Bensenville, IL 60106 | TF: 888.518.8086 | FX: 630.860.5944 | www.lakecable.com

Specification Sheet

Lake Cable Part #: V1624SPOS/22DR

Description: 16 AWG 24 pairs 7 strand bare copper with polyvinylchloride and nylon insulation, aluminum/mylar shields with stranded tinned copper drain wires and an overall PVC jacket 600V tray cable, approved for use in SUN RES DIR BUR 90°C applications.

1. Conductor

1.1. AWG Size & Stranding:	16 AWG 7 Strands Class B
1.2. Material:	Annealed Bare Copper
1.3. Conductor Count:	24 Pairs

2. Insulation

2.1. Material:	Polyvinylchloride & Nylon
2.2. Wall Thickness:	0.015" PVC & 0.005" Nylon
2.3. Color Code:	Black & White numbered pairs

3. Assembly

3.1. Pair/Cable Lay Length:	3.00" / 14.75" LHL
3.2. Pair Drain Wire:	22 AWG, 7 Strand Tinned Copper
3.3. Pair Shield:	Foil Free Edged Aluminum/Mylar Tape – 100% coverage
3.4. Cable Binder:	Clear Mylar
3.5. Cable Shield:	Aluminum/Mylar Tape – 100% coverage
3.6. Cable Drain Wire:	16 AWG, 7 Strand Tinned Copper
3.7. Fillers:	N/A

4. Jacket

4.1. Material:	Polyvinylchloride
4.2. Wall Thickness:	0.080"
4.3. Diameter:	1.141" +/- 0.090"
4.4. Color:	Black
4.5. Ripcord:	Yes
4.6. Cold Bend Rating:	-40°C
4.7. Weight:	810 lbs./Mft.

5. Markings

5.1. Type:	Cable shall be permanently identified via surface inkjet print
5.2. Legend:	LAKE CABLE E208309 16AWG 24PR SPOS (UL) TC-ER PVC/NYLON 600V 90'C DRY/WET PVC JACKET SUN RES DIR BUR FT4 "ROHS II" MADE IN USA
5.3. Footage Markers:	Yes

6. Standards

6.1. Refer to NEC (NFPA 70) article 336 for installation guidelines
6.2. Cable is suitable for use in Class I Division II hazardous locations
6.3. UL listed as Type TC-ER per UL Standard 1277 for tray cables
6.4. UL approved for Direct Burial and Sunlight Resistant applications
6.5. Cable meets UL 1581 & 1202 (FT-4) 70,000 BTU/HR & ICEA T-29-520 210,000 BTU/HR requirements
6.6. Meets ICEA S-73-532, where applicable
6.7. All materials used in the manufacture of this cable are RoHS II & REACH compliant
6.8. Made in the USA

ALL SPECIFIED PARAMETERS ARE NOMINAL AND SUBJECT TO VERIFICATION

Your signature constitutes that you have read and agreed to this specification sheet and upon confirmation of your order; this item may be non-cancelable and non-returnable.

_____
Signature

_____
Company