529 Thomas Drive, Bensenville, IL 60106 | TF: 888.518.8086 | FX: 630.860.5944 | www.lakecable.com

Specification Sheet

Lake Cable Part #: V163S

Description: 16 AWG 3 conductor 7 strand bare copper with polyvinylchloride and nylon insulation, an aluminum/mylar shield with a stranded tinned copper drain wire with an overall PVC jacket 600V control tray cable, approved for use in SUN RES DIR BUR OIL RES I 90°C applications.

1. Conductor

1.1. AWG Size & Stranding:	16 AWG, 7 Strands Class B
1.2. Material:	Annealed Bare Copper
1.3. Conductor Count:	3 Conductors

2. Insulation

2.1. Material:	Polyvinylchloride & Nylon
2.2. Wall Thickness:	0.015" PVC & 0.005" Nylon
2.3. Color Code:	Method 1, Table E-2

3. Assembly

3.1. Lay Length:	Per UL Standard 1277
3.2. Fillers:	N/A
3.3. Binder:	N/A
3.4. Shield:	Aluminum/Mylar Tape - 100% coverage
3.5. Drain Wire:	20 AWG, 7 Strand Tinned Copper

4. Jacket

4.1. Material:	Polyvinylchloride
4.2. Wall Thickness:	0.045"
4.3. Diameter:	0.303"
4.4. Color:	Black
4.5. Ripcord:	Yes
4.6. Cold Bend Rating:	-40°C
4.7. Weight:	64 lbs./Mft.

5. Markings

5.1. Type:	Cable shall be permanently identified via surface inkjet print
5.2. Legend:	LAKE CABLE E208309 16AWG 3C SHIELDED (UL) TC-ER PVC/NYLON 600V 90'C DRY/WET PVC JACKET SUN RES DIR BUR OIL RES I FT4 "ROHS"
5.3. Footage Markers:	Yes

6. Standards

6.1. Refer to NEC (NFPA 70) article 1277 for installation guidelines
6.2. Cable is suitable for use in Class I Division II hazardous locations
6.3. UL listed as Type TC-ER per UL Standard 1277 for tray cables
6.4. UL approved for Direct Burial, Sunlight and Oil I Resistant applications
6.5. Cable meets UL 1581 & 1202 (FT-4) 70,000 BTU/HR & ICEA T-29-520 210,000 BTU/HR requirements
6.6. Meets ICEA S-73-532, where applicable
6.7. All materials used in the manufacture of this cable are RoHS compliant
6.8. Made in the USA

ALL SPECIFIED PARAMETERS ARE NOMINAL AND SUBJECT TO VERIFICATION