Simpull® CT1 - 21ET

35kVU Type MV-105. Copper Conductor.
Thermosetting Conductor and Insulation Shield.EPR Insulation.
Copper Tape Shield. Simpull® PVC Jacket.
RoHS



APPLICATIONS

Southwire SIMpull CT1-21ET Type MV-105 Cable is for use in aerial, direct burial, cable trays, conduit, and underground duct installations as permitted by the National Electrical Code. These cables are capable of operating continuously at a conductor temperature not in excess of 105°C for normal operation, 140°C for emergency overload conditions, and 250°C for short circuit conditions, and are rated at 35,000V, 133% (ungrounded system) . Maximum sidewall pressure is 1000 lbs. This cable can be installed without the need for pulling lubricant.

SPECIFICATIONS

Southwire SIMpull CT1-21ET Type MV-105 Cable is manufactured and tested in accordance with the latest revisions of the following standards and specification:

- UL 1072
- UL 1685 - (AWG 1/0 and larger) - UL-CT Flame Exposure Test.
- ICEA S-93-639 (NEMA WC 74)
- ICEA S-97-682 (when requested)
- IEEE 1202/FT4 Flame Exposure Test with CPE and Solonon jacket.
- AEIC CS-8
- RoHS

CONSTRUCTION

Southwire SIMpull CT1-21ET Type MV-105 Cable offers our patented SIM (Slikqwik ® Infused Membrane) Technology ® for easier pulling, flexible, easy bending insulation, easy cable preparation, fast stripping thermosetting insulation shield, 105°C continuous operating temperature, 100% shield coverage, and it is triple extruded. Cable is sunlight resistant, suitable for direct burial, and listed for cable tray use in sizes AWG 1/0 and larger. SOLONON™ low smoke, non halogen polyolefin jackets and CPE jackets are available upon request.

Southwire NoLube®
One Southwire Drive
Carrollton, Ga. 30119 USA

MADE IN ★ THE USA

greenSpec™
RoHS Compliant

Copyright 2010, Southwire Company.
All Rights Reserved.

®Southwire is a registered trademark of Southwire Company.

CT1-21ET 1c, 35kV, 420mil EPR, TS(133%), PVC, CT Rated

Product Code	Size	Diameter		0.420" (10.67mm) Insulation Diameter		Extruded Insulation Shield Diameter		Min. Point Jacket Thickness		Approximate Overall Diameter		Approximate Net Weight		Allowable Ampacities+	
	AWG or kcmil	inch*	mm	inch	mm	inch	mm	inch	Mm	inch	mm	lb./Mft.	kg/km	Duct	Conduit In Air
CT1-21ET-010	1/0	.362	9.19	1.243	31.56	1.298	32.96	.07	1.78	1.465	37.2	1254	1866	215	215
CT1-21ET-020	2/0	.405	10.29	1.283	32.58	1.338	33.97	.07	1.78	1.505	38.2	1378	2050	245	255
CT1-21ET-040	4/0	.512	13	1.388	35.24	1.443	36.64	.07	1.78	1.61	40.9	1717	2554	315	330
CT1-21ET-250	250	.558	14.17	1.445	36.7	1.5	38.1	.1	2.54	1.73	43.9	1991	2962	345	365
CT1-21ET-350	350	.661	16.79	1.548	39.31	1.603	40.7	.1	2.54	1.833	46.5	2407	3581	415	440
CT1-21ET-500	500	.79	20.07	1.673	42.48	1.735	44.07	.1	2.54	1.965	49.9	3011	4480	500	535
CT1-21ET-750	750	.968	24.59	1.86	47.24	1.923	48.83	.1	2.54	2.153	54.7	3979	5920	610	655
CT1-21ET-100	1000	1.117	28.37	2.005	50.93	2.068	52.51	.1	2.54	2.298	58.4	4898	7288	690	755

*Minimum diameter per ASTM Standards. **±0.030" ***±0.050"
+Ampacities are based on the NEC, 2008 Edition. Duct ampacities are based on Table 310.77 three conductors in one underground duct, 105°C conductor, 20°C earth ambient temperature. Conduit in air ampacities are based on Table 310.73 three cables in isolated conduit in air, 105°C conductor, 40°C ambient temperature.

Scope: This specification covers single conductor EPR (ethylene propylene rubber) insulated, shielded, thermoplastic jacketed power cable for use in aerial, direct burial, cable trays, conduit, and underground duct installations. This cable is capable of operating continuously at a conductor temperature not in excess of 105°C for normal operation, 140°C for emergency overload conditions, and 250°C for short circuit conditions, and are rated at 35,000V, 133% insulation level (ungrounded system).

Standards: The following standards shall form a part of this specification - UL Standard for Medium Voltage Power Cable and ICEA S-93-639 (NEMA WC 74) 5-46 kV Shielded Power Cable for Use in the Transmission and Distribution of Electric Energy.

Conductor: The conductor shall be Class B compressed soft or annealed copper in accordance with ASTM specs B3 and B8 and ICEA Part 2, Section 2.1 and 2.5.

Conductor Shield: The conductor shall be shielded with an extruded semi-conducting thermosetting polymeric layer over the conductor, applied in tandem with and firmly bonded to the insulation.

Insulation: The insulation shall be EPR (ethylene propylene rubber) meeting the requirements of the referenced standards. The nominal thickness shall be 0.420".

Insulation Shield: The insulation shall be shielded with an extruded layer of semi-conducting thermosetting material which shall be identified as being semi-conducting. Over this layer shall be applied a helically-wrapped 5-mil copper tape with 25% overlap.

Jacket: The cable shall be provided with a jacket of black sunlight resistant PVC conforming to the requirements specified for polyvinyl chloride jackets in ICEA. The average thickness shall be in accordance with Table 7-3 of ICEA. Optional SOLONON low smoke, non halogen polyolefin jackets and CPE jackets are available upon request.

Identification: Cable shall be identified by surface printing on the jacket.

Tests: Qualification tests shall be conducted in accordance with the requirements of AEIC.

Southwire NoLube®
One Southwire Drive
Carrollton, Ga. 30119 USA

MADE IN ★ THE USA

greenSpec™ RoHS Compliant

Copyright 2010, Southwire Company. All Rights Reserved.
®Southwire is a registered trademark of Southwire Company.