

## Work Order

<b>Work Order</b>	10039983433	<b>Scheduled Start Date</b>	10/19/2025
	AMER-DAILY FLOOR HEALTH CHECK (DAYS)	<b>Scheduled End Date</b>	10/19/2025
<b>Status</b>	Open	<b>Date Started</b>	09/28/2025 05:37
<b>Created By</b>	R5	<b>Date Completed</b>	
<b>Created</b>	09/28/2025		
<b>WO Type</b>	SC	<b>Parent WO</b>	
	System Check	<b>Class</b>	
<b>Department</b>	RME	<b>Priority</b>	4
	Reliability Maintenance Engineering (RME)	<b>Warranty</b>	
<b>PM Schedule</b>	MIN.AMA.FLRHLTHD.01D	<b>Safety</b>	
	AMER-DAILY FLOOR HEALTH CHECK (DAYS)	<b>Equipment Criticality</b>	1
<b>Problem Code</b>	N.A.	<b>Assigned To</b>	ERWOMACK
	Not Applicable (not allowed to be used in Breakdowns and Corrective)	<b>Reported By</b>	

## Equipment

<b>Equipment</b>	AR	<b>Manufacturer</b>	AMAZON
	AMAZON ROBOTICS SYSTEMS	<b>Model</b>	AR SYSTEM
		<b>Serial Number</b>	

## Activity List

Activity	Task Plan Description	Trade	Start Date	End Date	Supplier
1	LOTO Evidence	TECH	09/28/2025	09/28/2025	

## Checklist

Sequence	Equipment	Description	Result
10	AR	Does this task require LOTO to one or more energy sources?	Yes: ____ No: ____
20	AR	Are photos of applied LOTO devices uploaded to this check (comment if not)?	Yes: ____ No: ____

## Task Plan Instructions

**R5 [02/13/2023 13:46]:**

Photographic Evidence of applied LOTO

"10 - Does the task require LOTO to one or more energy source?"

Confirm if this task requires a LOTO procedure to any energy source by selecting 'Yes'. If the task does not require LOTO select 'No'.

"20 - Are photos of applied LOTO devices uploaded to this check (comment if not)?"

In case LOTO is required for this task photographic evidence should be uploaded to this check (sequence 20). In case there are multiple energy sources to be isolated, upload a photo of every isolation point showing the applied LOTO device.

Steps to upload LOTO photos on APM:

- select the checklist item (sequence 20),
- click 'Actions' on the bottom of the checklist tab,
- select 'Add/Edit Checklist Items Documents'
- select 'Actions' > Create/Upload Document'

Steps to upload LOTO photos on APM Mobile:

- select the checklist item (sequence 20),
- click the camera symbol,

Activity List					
Activity	Task Plan Description	Trade	Start Date	End Date	Supplier
Task Plan Instructions					
- take a photo directly or navigate to saved photos on your device					
Booked Hours					
Employee	Date	Time On	Time Off	Total Time	Type of Hours

Activity	Task Plan Description	Trade	Start Date	End Date	Supplier
10	AMER-DAILY FLOOR HEALTH CHECK	TECH	10/19/2025	10/19/2025	
Checklist					
Sequence	Equipment	Description	Result		
10	AR	I have completed all tasks referenced on the task list of this PM	Yes: _____ No: _____		
20	AR	I have created a follow-up work order for any issues found during this PM	Completed: _____		
Task Plan Instructions					
<p><b>LUKEFLE@AMAZON.COM [11/26/2024 15:02]:</b></p> <p>Find PM tasks on GRU: <a href="https://learning.robotics.amazon.dev/24840#/8207aec2-bbff-44c8-bca4-872cd9e4064e/">https://learning.robotics.amazon.dev/24840#/8207aec2-bbff-44c8-bca4-872cd9e4064e/</a></p> <p>Introduction</p> <p>Or navigate from GRU main page: <a href="https://learning.robotics.amazon.dev/">https://learning.robotics.amazon.dev/</a></p>					
Booked Hours					
Employee	Date	Time On	Time Off	Total Time	Type of Hours

## Work Order

<b>Work Order</b>	10039983451	<b>Scheduled Start Date</b>	10/19/2025
	AMER-AMAZON ROBOTICS PSC 700-0101-002-NA 26 WEEK	<b>Scheduled End Date</b>	10/19/2025
<b>Status</b>	Open	<b>Date Started</b>	09/28/2025 05:37
<b>Created By</b>	R5	<b>Date Completed</b>	
<b>Created</b>	09/28/2025		
<b>WO Type</b>	PM	<b>Parent WO</b>	
	Preventive maintenance	<b>Class</b>	
<b>Department</b>	RME	<b>Priority</b>	5
	Reliability Maintenance Engineering (RME)	<b>Warranty</b>	
<b>PM Schedule</b>	MAJ.AMA.700-0101.26W	<b>Safety</b>	
	AMER-AMAZON ROBOTICS PSC 700-0101-002-NA 26 WEEK	<b>Equipment Criticality</b>	3
<b>Problem Code</b>	N.A.	<b>Assigned To</b>	ERWOMACK
	Not Applicable (not allowed to be used in Breakdowns and Corrective)	<b>Reported By</b>	

## Equipment

<b>Equipment</b>	AR.ZONE.2.FSS.PSC.2305	<b>Manufacturer</b>	AR
	TPA4-paKivaA02 PSC 2305	<b>Model</b>	PERIMETER SAFETY CONTROLLER
		<b>Serial Number</b>	2U6212800855

## Activity List

Activity	Task Plan Description	Trade	Start Date	End Date	Supplier
1	LOTO Evidence	TECH	09/28/2025	09/28/2025	

## Checklist

Sequence	Equipment	Description	Result
10	AR.ZONE.2.FSS.PSC.2305	Does this task require LOTO to one or more energy sources?	No
20	AR.ZONE.2.FSS.PSC.2305	Are photos of applied LOTO devices uploaded to this check (comment if not)?	No

## Task Plan Instructions

**R5 [02/13/2023 13:46]:**

Photographic Evidence of applied LOTO

"10 - Does the task require LOTO to one or more energy source?"

Confirm if this task requires a LOTO procedure to any energy source by selecting 'Yes'. If the task does not require LOTO select 'No'.

"20 - Are photos of applied LOTO devices uploaded to this check (comment if not)?"

In case LOTO is required for this task photographic evidence should be uploaded to this check (sequence 20). In case there are multiple energy sources to be isolated, upload a photo of every isolation point showing the applied LOTO device.

Steps to upload LOTO photos on APM:

- select the checklist item (sequence 20),
- click 'Actions' on the bottom of the checklist tab,
- select 'Add/Edit Checklist Items Documents'
- select 'Actions' > Create/Upload Document'

Steps to upload LOTO photos on APM Mobile:

Activity List					
Activity	Task Plan Description	Trade	Start Date	End Date	Supplier
Task Plan Instructions					
<ul style="list-style-type: none"> <li>- select the checklist item (sequence 20),</li> <li>- click the camera symbol,</li> <li>- take a photo directly or navigate to saved photos on your device</li> </ul>					
Booked Hours					
Employee	Date	Time On	Time Off	Total Time	Type of Hours

Activity	Task Plan Description	Trade	Start Date	End Date	Supplier
10	AMER-AMAZON ROBOTICS PSC 26 WEEK	TECH	10/19/2025	10/19/2025	

Checklist			
Sequence	Equipment	Description	Result
10	AR.ZONE. 2.FSS.PSC. 2305	Is the PSC labelled/marked per the pre-procedure	Yes
20	AR.ZONE. 2.FSS.PSC. 2305	Were there any "PS/Voltage Out of Limits" or "Bad Battery" errors present?	No
30	AR.ZONE. 2.FSS.PSC. 2305	All wiring is neatly dressed and bundled, and free of damage?	Yes
40	AR.ZONE. 2.FSS.PSC. 2305	Light stack remain illuminated for the 20 seconds the PSC was powered off?	Yes
50	AR.ZONE. 2.FSS.PSC. 2305	If there was no voltage monitor, was the voltage measured to be below 25V	Yes
60	AR.ZONE. 2.FSS.PSC. 2305	I have created a follow-up work order for any issues found during this PM	Completed: Yes

Task Plan Instructions					
<b>LUKEFLE@AMAZON.COM [11/26/2024 14:34]:</b> Find PM tasks on GRU: <a href="https://learning.robotics.amazon.dev/38383#/064df043-7310-4b52-8070-e49a13b626eb/FSS-10">https://learning.robotics.amazon.dev/38383#/064df043-7310-4b52-8070-e49a13b626eb/FSS-10</a>  Or navigate from GRU main page: <a href="https://learning.robotics.amazon.dev/">https://learning.robotics.amazon.dev/</a>					
Booked Hours					
Employee	Date	Time On	Time Off	Total Time	Type of Hours

## Work Order

<b>Work Order</b>	10040286485	<b>Scheduled Start Date</b>	10/19/2025
	AMER-AR FLOOR WITH INVENTORY POD SEGMENT 12 WEEK	<b>Scheduled End Date</b>	10/19/2025
<b>Status</b>	Open	<b>Date Started</b>	10/02/2025 05:29
<b>Created By</b>	R5	<b>Date Completed</b>	
<b>Created</b>	10/02/2025		
<b>WO Type</b>	PM	<b>Parent WO</b>	
	Preventive maintenance	<b>Class</b>	
<b>Department</b>	RME	<b>Priority</b>	5
	Reliability Maintenance Engineering (RME)	<b>Warranty</b>	
<b>PM Schedule</b>	MED.AMZ.FLR04.12W	<b>Safety</b>	
	AMER-AR FLOOR WITH INVENTORY POD SEGMENT 12 WEEK	<b>Equipment Criticality</b>	2
<b>Problem Code</b>	N.A.	<b>Assigned To</b>	ERWOMACK
	Not Applicable (not allowed to be used in Breakdowns and Corrective)	<b>Reported By</b>	

## Equipment

<b>Equipment</b>	AR.ZONE.2.A.SECTION.43	<b>Manufacturer</b>	AMAZON
	TPA4-paKivaA02 SECTION 12 25	<b>Model</b>	AR FLOOR SECTION
		<b>Serial Number</b>	43

## Activity List

Activity	Task Plan Description	Trade	Start Date	End Date	Supplier
1	LOTO Evidence	TECH	09/28/2025	09/28/2025	

## Checklist

Sequence	Equipment	Description	Result
10	AR.ZONE.2.A.SECTION.43	Does this task require LOTO to one or more energy sources?	Yes: _____ No: _____
20	AR.ZONE.2.A.SECTION.43	Are photos of applied LOTO devices uploaded to this check (comment if not)?	Yes: _____ No: _____

## Task Plan Instructions

**R5 [02/13/2023 13:46]:**

Photographic Evidence of applied LOTO

"10 - Does the task require LOTO to one or more energy source?"

Confirm if this task requires a LOTO procedure to any energy source by selecting 'Yes'. If the task does not require LOTO select 'No'.

"20 - Are photos of applied LOTO devices uploaded to this check (comment if not)?"

In case LOTO is required for this task photographic evidence should be uploaded to this check (sequence 20). In case there are multiple energy sources to be isolated, upload a photo of every isolation point showing the applied LOTO device.

Steps to upload LOTO photos on APM:

- select the checklist item (sequence 20),
- click 'Actions' on the bottom of the checklist tab,
- select 'Add/Edit Checklist Items Documents'
- select 'Actions' > Create/Upload Document'

Steps to upload LOTO photos on APM Mobile:

Activity List

Activity	Task Plan Description	Trade	Start Date	End Date	Supplier												
	<div>Task Plan Instructions</div> <div><div>- select the checklist item (sequence 20),</div><div>- click the camera symbol,</div><div>- take a photo directly or navigate to saved photos on your device</div></div> <div>Booked Hours</div> <table><tr><th>Employee</th><th>Date</th><th>Time On</th><th>Time Off</th><th>Total Time</th><th>Type of Hours</th></tr><tr><td></td><td></td><td></td><td></td><td></td><td></td></tr></table>					Employee	Date	Time On	Time Off	Total Time	Type of Hours						
Employee	Date	Time On	Time Off	Total Time	Type of Hours												

Activity	Task Plan Description	Trade	Start Date	End Date	Supplier
10	AMER-AR FLOOR WITH INVENTORY POD SEGMENT 12 WEEK	TECH	10/19/2025	10/19/2025	

Checklist

Sequence	Equipment	Description	Result
10	AR.ZONE. 2.A.SECTION. 43	I have completed all tasks referenced on the task list of this PM	Yes: _____ No: _____
20	AR.ZONE. 2.A.SECTION. 43	I have created a follow-up work order for any issues found during this PM	Completed: _____

Task Plan Instructions

ADMAM@AMAZON.COM [03/28/2024 13:50]:

If you would like to request any changes to these tasks please enter a Trouble Ticket using the following CTI RCM>PM Change>RCM-FC

\*\*Attention!\*\* Only individuals holding a valid ARU Certification Badge may perform this task list. If you are not holding a valid ARU Certification Badge for this task STOP! Do not perform this task and escalate to your manager immediately. By completing this PM you are stating that you are ARU PM certified and have followed all steps for the 12 week floor health PM listed on the AR Knowledge Center (link below). Failure to comply may result in corrective action.

☐ 1. Copy and paste this web address into your internet browser:

https://share.amazon.com/sites/aru/SitePages1/kc/preventative-maintenance/floor-health/sortNonQuickDeploy-proc.html

☐ 2. Click the Safety and PPE section. All safety and PPE requirements must be followed at all times.

☐ 3. Before performing floor cleaning check floor scrubber brushes to ensure the correct soft nylon brushes are installed, the brushes have not worn down past the wear indicator and brushes are clean. Replace or clean if necessary.

☐ 4. Ensure the squeegee is in good working order, replace if necessary. If floor scrubber leaves a trail of water while in use, this is indicative of a faulty squeegee.

☐ 5. Click the 12 week floor health PM and follow all procedures without deviation.

☐ 6. If any issues are found other than those addressed by this PM, please create a new Work From PM Work order to make the correction.

\*\*CLEAN UP AREA\*\*

☐ 1. Put away all equipment and tools used

☐ 2. Ensure floor area is clean and dry

☐ 3. Ensure any fiducials replaced have been inspected and the floor is in a normal state before releasing

ADMAM@AMAZON.COM [03/28/2024 13:50]:

The following link is the new website for the floor cleaning instructions. The previous link is no longer functional.

https://share.amazon.com/sites/aru/SitePages1/kc/preventative-maintenance/floor-health/sortNonQuickDeploy-proc.html

Booked Hours

Employee	Date	Time On	Time Off	Total Time	Type of Hours

Activity List						
Activity	Task Plan Description	Trade	Start Date	End Date	Supplier	
	Employee	Date	Time On	Time Off	Total Time	Type of Hours