



IMIS PCBA Calibration Report

PCBA Sr.No. AM122304EL02108044

Date/Time 2023-12-08 10:14:10

Calibrator Certification No. by NABL (ISO/IEC 17025:2005)	
Accredited lab	452
Supervisor Name	Admin
Operator Name	Admin
JIG No.	JIG A
PCBA Type	4 Outlet
Board ERP No	BD-NG-820-R4

Calibration Factors			
Outlet No.	Voltage Factor	Current Factor	Watt Factor
1	0.000039	0.000002	0.000002
2	0.000038	0.000003	0.000002
3	0.000038	0.000002	0.000002
4	0.000038	0.000003	0.000002

Verification Report									
Outlet No.	Vpcba	Vcal	%Error	Ipcba	Ical	%Error	Wpcba	Wcal	%Error
1	228.161	228.317	0.068	3.064	3.064	0.004	0.698	0.699	0.199
2	229.932	230.550	0.268	3.079	3.089	0.302	0.708	0.712	0.578
3	230.243	230.037	0.089	3.079	3.075	0.128	0.709	0.707	0.173
4	228.789	229.300	0.223	3.058	3.063	0.147	0.699	0.702	0.466

Operator Signature

Supervisor Signature