

Control card LB01 (AHU1) ? Norrsken Demo Building (synthetic)

Operation
AHU1 runs weekdays 06:00-18:00, off outside schedule. Night operation only on frost protection or extended-operation override.

Supply air temperature control
Setpoint for GT11 follows an outdoor-compensation curve on GT21:

GT21 outdoor (degC)	GT11 supply setpoint (degC)
-20	21.0
0	19.0
+10	17.5
+20	16.0

The controller modulates SV61 (heating valve) 0-100% in sequence before fan speed reduction. Deadband 0.5 K.

Fans
GP1 and GP2 are VSD fans, pressure-controlled; minimum speed 30%, maximum 100%. GP2 tracks GP1 minus 5 percentage points.

Frost protection
If GT11 falls below 7.0 degC while running, SV61 drives to 100%. If the frost guard contact GX1 trips (2.0 degC at the coil), the unit stops, dampers close, and alarm class A "FROST GUARD LB01" is raised. Manual reset required.