


overflow scuppers along here

w/ 1% slope, there's not much room for a channel drain. That okay?

Also, is the downspout in the wall, for this, or will it be exposed?


try slot drain just on outside of beam line. DS in wall, with overflow scuppers in parapet wall




run of edge or trench drain?

radiant heat in floor?

if so, everywhere throughout 1st floor?





with a concealed gutter, this structural connection might be a little tenuous.

structural engineer thinks it will be okay to cut into these rafter tails with the gutter. Please propose the detail and we'll run it past them, thanks!

