

- Windows

- Same window specs as Staudenmeier?
  - Throughout entire project?

**We expect to use Fleetwood for all doors and windows in this project.**

- Any curtain wall, or storefront windows? Or are they all mulled windows with structural profiles between like Staudenmeier??

**The tall window system at the entry (around the entry door and next to the internal stair) should be expected to be a storefront system at the moment**

- Skylights?

- Spec?  
**Velux**

- Doors

- Same as Staudenmeier?  
**We expect to use Fleetwood for all doors and windows in this project.**
- Wood gate at surf storage
  - Spec? Custom?  
**Custom**


- Louvers

- Spec? Custom? All locations?  
**Custom. TBD.**

- Deck


- [Bison Pedestals](#) at 2nd floor decks
- [Buzon pedestals](#) around pool area  
**Buzon everywhere**
- Stone Pavers
  - Spec?  
**TBD**
- Wood Decking

- Spec?  
**No wood decking proposed. All decks to be stone over Buzon pedestals. Over Westcoat decking:**  
<https://www.westcoat.com/systems/alx-tile-ut/>
- Glass Railing
  - Spec?
- Gutter
  - Integral gutter
    - same design as Staudenmeier?  
**Yes**
- Soffit
  - Wood
    - Spec?  
**Coulson Cedar ceiling 1x6**  
<http://coulsonmanufacturing.com/>
- Roof
  - BUR
    - You actually want BUR roofing? Or could you use EPDM w/ gravel, which I understand is a more common system?
- Stair
  - Tread and stringer like Staudenmeier?  
**No. This will be two side metal stringers with wood treads in between. Structural to follow.**
  - Glass railing
    - Any design direction?  
**Per the structural plans:**






GUARDRAIL / HANDRAIL TO DECK CONN.

49



GUARDRAIL / HANDRAIL TO DECK CONN.

50





stucco to hide stone  
tile. stone tiles/  
buzon pedestals/  
West coat deck  
coating (sent you a  
link) O/ framing

at the edge, do you  
see the stone tile?  
or does the  
stucco/gypsum  
board hide the  
stone?

opening  
@ roof

stone tile  
o/ bison  
pedestals  
o/ sloped  
deck

glass rail  
@ deck

rake

stucco @  
exterior  
Now  
corrected  
in the new  
model

the revit roof object  
has this as 'Gypsum  
Wall Board'  
Is that correct?  
Or stucco?

planter  
and  
drainage

Split stone  
o/ CMU  
wall

were you envisioning  
this split stone over  
a CMU backer wall?  
Or just stacked stone  
w/ mortar?

footing?

will  
confirm  
with  
structural

**A1** Section A - 1  
1/2" = 1'-0"

rake

eave/  
integrated  
gutter

window  
"offset"  
from face  
of  
building

BUR w/  
gravel




stucco w/  
weep  
screed  
and curb


**A2** Section A - 2  
1/2" = 1'-0"

**P1** Section P - 1  
1/2" = 1'-0"












**G1** Wall Section G - 1  
1/2" = 1'-0"



**H1** Wall Section H - 1  
1/2" = 1'-0"




**J1** Wall Section J - 1  
1/2" = 1'-0"




**K1** Wall Section K - 1  
1/2" = 1'-0"







**K2** Wall Section K - 2  
1/2" = 1'-0"



Wall Section L - 1  
1/2" = 1'-0"



**M2** Wall Section M - 2  
1/2" = 1'-0"



**N1** Wall Section N - 1  
1/2" = 1'-0"