



NOTES:

1. REFER TO FIRESTONE WEBSITE FOR MOST CURRENT INFORMATION AT firestonebpco.com.
2. WOOD NAILER MUST BE INSTALLED TO MEET APPLICABLE BUILDING CODES OR 200 LBS PER LINEAR FOOT MINIMUM IN ANY GIVEN DIRECTION.
3. ATTACH NAILER TO DECK WITH SUITABLE FASTENER.
4. THIS DETAIL SHOULD BE USED ONLY WHERE THE DECK IS SUPPORTED BY THE OUTSIDE WALL.
5. ALL SHEET METAL IS TO BE INSTALLED PER SMACNA GUIDELINES.
6. JOINTS IN SHEET METAL COUNTERFLASHING MUST NOT BE SOLDERED OR FASTENED.
7. GRANULES MUST BE EMBEDDED WHEN LAPPING TORCH APPLIED GRANULE SURFACED CAP SHEET.
8. FLASHING LAPS MUST BE OFFSET FROM FIELD LAPS A MINIMUM OF 12" (305mm)
9. IF FLASHING MUST EXTEND ABOVE 24" (610 mm) IN HEIGHT, FLASHING WIDTH MUST NOT EXCEED 39" (991 mm) AND SHALL BE ATTACHED IN SIDE LAPS AT 9" (229 mm) O.C.
10. PARAPETS WITH NAILABLE SUBSTRATES MUST HAVE FIRESTONE MB BASE MECHANICALLY ATTACHED PRIOR TO THE INSTALLATION OF THE FLASHING MEMBRANES.

ASPHALT IS APPLIED UNIFORMLY TO EACH PLY AT A RATE OF APPROXIMATELY 25 LBS PER 100 SQ/FT OF **ROOF SURFACE (±15%)**

MAXIMUM WARRANTY: 20 YEARS

ISSUE/REVISION DATE:

01/17/2014

NOT TO SCALE

DETAIL NO.

BU-BT-11

Firestone
BUILDING PRODUCTS
NOBODY COVERS YOU BETTER.™
www.firestonebpco.com

BASE TIE-IN WITH ROOF EDGE ON A PARAPET

ASPHALT SYSTEMS

ACCEPTABLE SYSTEMS: BUR