



#### NOTES:

1. REFER TO FIRESTONE WEBSITE FOR MOST CURRENT INFORMATION AT [firestonebpco.com](http://firestonebpco.com).
2. ATTACH NAILER TO DECK WITH SUITABLE FASTENER.
3. ALL SHEET METAL TO BE INSTALLED PER SMACNA GUIDELINES
4. GRANULES MUST BE EMBEDDED WHEN USING TORCH APPLIED GRANULE SURFACED CAP SHEETS PRIOR TO COMPLETING SIDE LAPS. FLASHING LAPS MUST BE OFFSET FROM FIELD SHEET LAPS A MIN. 12" (305 mm)
5. IF FLASHING MUST EXTEND ABOVE 24" (610 mm) IN HEIGHT, FLASHING WIDTH MUST NOT EXCEED 39" (991 mm) AND SHALL BE ATTACHED IN SIDE LAPS AT 9" (229 mm) O.C.

ASPHALT IS APPLIED UNIFORMLY TO EACH PLY AT A RATE OF APPROXIMATELY 25 LBS PER 100 SQ/FT OF ROOF SURFACE (±15%)

PARAPET WITH NAILABLE SUBSTRATES MUST HAVE FIRESTONE MB BASE SHEET ATTACHED:  
 LAPS 9" (229 mm) O.C.  
 TOPS 8" (203 mm) O.C.  
 FIELD 1 PER 1 S.F. (11 SQ. M.)

MAXIMUM WARRANTY: 20 YEARS

**Firestone**  
 BUILDING PRODUCTS  
 NOBODY COVERS YOU BETTER.™  
[www.firestonebpco.com](http://www.firestonebpco.com)

METAL PARAPET CAP (COPING) AND BASE FLASHING

ASPHALT SYSTEMS

ACCEPTABLE SYSTEMS: BUR

ISSUE/REVISION  
 DATE:

01/17/2014

NOT TO SCALE

DETAIL NO.

**BU-BT-5**