

# DH152/DR152

## General Features

The model DH152 or DR152 grinder pump station is a complete unit that includes: two grinder pumps, check valve, HDPE (high density polyethylene) tank, controls, and alarm panel. A single DH152 or DR152 is ideal for up to four, average single-family homes and can also be used for up to 12 average single-family homes where codes allow and with consent of the factory.

- Rated for flows of 3000 gpd (11,356 lpd)
- 150 gallons (568 liters) of capacity
- Indoor or outdoor installation
- Standard outdoor heights range from 93 inches to 160 inches

The DH152 is the “hardwired,” or “wired,” model where a cable connects the motor controls to the level controls through watertight penetrations.

The DR152 is the “radio frequency identification” (RFID), or “wireless,” model that uses wireless technology to communicate between the level controls and the motor controls.

## Operational Information

### *Motor*

1 hp, 1,725 rpm, high torque, capacitor start, thermally protected, 120/240V, 60 Hz, 1 phase

### *Inlet Connections*

4-inch inlet grommet standard for DWV pipe. Other inlet configurations available from the factory.

### *Discharge Connections*

Pump discharge terminates in 1.25-inch NPT female thread. Can easily be adapted to 1.25-inch PVC pipe or any other material required by local codes.

### *Discharge*


15 gpm at 0 psig (0.95 lps at 0 m)  
11 gpm at 40 psig (0.69 lps at 28 m)  
7.8 gpm at 80 psig (0.49 lps at 56 m)

## Accessories

E/One requires that the Uni-Lateral, E/One’s own stainless steel check valve, be installed between the grinder pump station and the street main for added protection against backflow.

Alarm panels are available with a variety of options, from basic monitoring to advanced notice of service requirements.

The Remote Sentry is ideal for installations where the alarm panel may be hidden from view.



Patent Numbers: 5,752,315  
5,562,254 5,439,180


FIELD JOINT REQUIRED  
FOR MODELS

OPTIONS : ☐ **DH152**

(HARD WIRED  
LEVEL CONTROLS)

☐ **DR152**

(WIRELESS  
LEVEL CONTROLS)



SEMI-POSITIVE DISPLACEMENT TYPE PUMP  
EACH DIRECTLY DRIVEN BY A 1 HP MOTOR

CONCRETE BALLAST MAY BE REQUIRED  
SEE INSTALLATION INSTRUCTIONS  
FOR DETAILS

NOTE: DIMENSIONS ARE FOR REF ONLY




AD	CH	10/20/10	D	
DR BY	CHK'D	DATE	ISSUE	SCALE



MODEL DH152 / DR152  
DETAIL SHEET

NA0052P02

DH152 -38  
NO BAFFLE



NOTE: DIMENSIONS ARE FOR REF ONLY




CTT	CH	10/19/12	C	
DR BY	CHK'D	DATE	ISSUE	SCALE
MODEL DH152-38, NO BAFFLE				
NA0052P03				

OPTIONS : ☐ **DH152 -93**

(HARD WIRED  
LEVEL CONTROLS)

☐ **DR152 -93**

(WIRELESS  
LEVEL CONTROLS)





CONCRETE BALLAST MAY BE REQUIRED  
SEE INSTALLATION INSTRUCTIONS  
FOR DETAILS

NOTE: DIMENSIONS ARE FOR REF ONLY



AD	CAH	7/13/07	B	1/16
DR BY	CHK'D	DATE	ISSUE	SCALE
MODEL DH152-93 / DR152-93				
NA0052P04				

**OPTIONS :** ☐ **DH152 -129** (HARD WIRED LEVEL CONTROLS)  
☐ **DR152 -129** (WIRELESS LEVEL CONTROLS)



**DETAIL, FIELD JOINT**

SEE INSTALLATION INSTRUCTIONS FOR FURTHER DETAILS

CONCRETE BALLAST MAY BE REQUIRED  
SEE INSTALLATION INSTRUCTIONS FOR DETAILS

NOTE: DIMENSIONS ARE FOR REF ONLY





AD	CAH	7/13/07	B	1/16
DR BY	CHK'D	DATE	ISSUE	SCALE



MODEL DH152-129 / DR152-129

NA0052P05

OPTIONS : ☐ **DH152 -160** (HARD WIRED LEVEL CONTROLS)  
☐ **DR152 -160** (WIRELESS LEVEL CONTROLS)



DETAIL, FIELD JOINT  
 SEE INSTALLATION INSTRUCTIONS  
 FOR FURTHER DETAILS

CONCRETE BALLAST MAY BE REQUIRED  
 SEE INSTALLATION INSTRUCTIONS  
 FOR DETAILS

NOTE: DIMENSIONS ARE FOR REF ONLY



AD	CAH	7/13/07	B	1/16
DR BY	CHK'D	DATE	ISSUE	SCALE




MODEL DH152-160 / DR152-160

NA0052P06


# DH152 -57

## BUILDERS MODEL

STRAIGHT DISCHARGE




NOTE: DIMENSIONS ARE FOR REF ONLY

AD	CAH	06-27-07	B	1/16
DR BY	CHK'D	DATE	ISSUE	SCALE
				
MODEL DH152-57 BUILDERS				
NA0052P07				

# DH152-57


## BUILDERS MODEL

DISCHARGE VALVE



NOTE: DIMENSIONS ARE FOR REF ONLY



AD	CAH	06/27/07	B	1/16
DR BY	CHK'D	DATE	ISSUE	SCALE
				
MODEL DH152-57 BUILDERS				
NA0052P08				