

MASONRY WALL REINFORCING SCHEDULE			
MARK	WALL THICKNESS	VERTICAL REINFORCEMENT & SPACING	REINFORCEMENT LOCATION IN CELL
MW 1	8"	#5 AT 48" o/c MAX	CENTER
MW 2	8"	#6 AT 16" o/c MAX	INSIDE FACE

MASONRY WALL REINFORCING SCHEDULE NOTES:
1. GROUT CONCRETE MASONRY UNITS SOLID FULL HEIGHT OF BUILDING AT REINFORCEMENT LOCATIONS.
2. UNLESS NOTED OTHERWISE, PROVIDE DOWELS INTO FOOTING TO MATCH VERTICAL REINFORCEMENT.
3. PROVIDE CONCRETE MASONRY UNIT WALL REINFORCING ABOVE AND BELOW ALL MASONRY OPENINGS. EXTEND THE LENGTH OF THE REBARS BY 23" OR 40 BAR DIAMETERS PAST THE EDGE OF THE OPENING.
4. REFER TO STRUCTURAL NOTES SHEET FOR LAPS IN STEEL REINFORCEMENT.
5. PROVIDE STANDARD (W17) HORIZONTAL JOINT REINFORCING AT 16" ON CENTER VERTICALLY (8" ON CENTER IN PARAPET WALLS) UNDO REINFORCING TO BE HOT-DIPPED GALVANIZED IN EXTERIOR WALLS AND MILL-GALVANIZED FOR INTERIOR WALLS.
6. MASONRY FIREWALL CONSTRUCTION ASSUMES MASONRY BLOCKS COMPRISED OF LIMESTONE.

MASONRY WALL FOOTING SCHEDULE			
MARK	WIDTH	THICKNESS	LONGITUDINAL
MWF 1	2' - 0"	1' - 0"	(2)#5
MWF 2	2' - 0"	1' - 2"	(3)#5

MASONRY WALL FOOTING SCHEDULE:
1. REFER TO STRUCTURAL NOTES SHEET FOR LAPS IN STEEL REINFORCEMENT.
2. REFER TO FOUNDATION PLAN FOR TOP OF FOOTING ELEVATIONS.
3. ALL FOOTING EXCAVATIONS SHALL BE INSPECTED AND APPROVED BY THE GEOTECHNICAL ENGINEER PRIOR TO PLACING CONCRETE.

THICKENED SLAB SCHEDULE			
MARK	DIMENSIONS	REINFORCEMENT	REMARKS
	WIDTH (xCONT)	THICKNESS	LONGITUDINAL
TS20	2' - 0"	1' - 0"	(2) #5

THICKENED SLAB SCHEDULE NOTES:
1. REFER TO STRUCTURAL NOTES SHEET FOR LAPS IN STEEL REINFORCEMENT.
2. REFER TO FOUNDATION PLAN FOR TOP OF FOOTING ELEVATIONS.
3. ALL FOOTING EXCAVATIONS SHALL BE INSPECTED AND APPROVED BY THE GEOTECHNICAL ENGINEER PRIOR TO PLACING CONCRETE.

WALL FOOTING SCHEDULE			
MARK	DIMENSIONS	REINFORCEMENT	
	WIDTH	THICKNESS	LONGITUDINAL
WF26	2' - 6"	1' - 2"	(3)#5
WF30	3' - 0"	1' - 2"	(3)#5

COLUMN FOOTING SCHEDULE NOTES:
1. REFER TO STRUCTURAL NOTES SHEET FOR MINIMUM COVER REQUIREMENTS.
2. REFER TO FOUNDATION PLAN FOR TOP OF FOOTING ELEVATIONS.
3. ALL FOOTING EXCAVATIONS SHALL BE INSPECTED AND APPROVED BY THE GEOTECHNICAL ENGINEER PRIOR TO PLACING CONCRETE.
4. ALL LAPS IN STEEL REINFORCING SHALL BE CLASS "B" LAP SPLICES UNLESS NOTED OTHERWISE.

COLUMN FOOTING SCHEDULE					
MARK	DIMENSIONS			REINFORCEMENT	
	W	L	D	BOTTOM REINFORCING	COLUMNS
FT90a	9'-0"	9'-0"	1'-8"	(10)#7	A1 A2
FT90b	9'-0"	9'-0"	1'-8"	(10)#8	A3 A4 A5
FT96a	9'-6"	9'-6"	1'-8"	(10)#7	B2
FT96b	9'-6"	9'-6"	1'-8"	(10)#8	B3 B4 B5
FT100	10'-0"	10'-0"	2'-1"	(11)#8	F1 F2 F3 F4 F5
FT106	10'-6"	10'-6"	2'-3"	(11)#8	C1
FT110a	11'-0"	11'-0"	2'-1"	(12)#8	G2 G3 G4 G5
FT110b	11'-0"	11'-0"	2'-3"	(12)#8	D1 G1
FT116	11'-6"	11'-6"	2'-1"	(12)#8	C2 C3 C4 C5
FT120	12'-0"	12'-0"	2'-3"	(13)#8	D2 D3 D4 D5

COLUMN FOOTING SCHEDULE:
1. REFER TO STRUCTURAL NOTES SHEET FOR LAPS IN STEEL REINFORCEMENT.
2. REFER TO FOUNDATION PLAN FOR TOP OF FOOTING ELEVATIONS.
3. ALL FOOTING EXCAVATIONS SHALL BE INSPECTED AND APPROVED BY THE GEOTECHNICAL ENGINEER PRIOR TO PLACING CONCRETE.

CONCRETE WALL REINFORCING SCHEDULE					
MARK	TYPE	THICKNESS	REINFORCEMENT		REMARKS
			VERTICAL	HORIZONTAL	
W1	CONCRETE	10"	5#s AT 18" o.c.	5#s AT 12" o.c.	inside face
W2	CONCRETE	10"	5#s AT 12" o.c.	5#s AT 12" o.c.	inside face
W3	CONCRETE	10"	6#s AT 12" o.c.	5#s AT 12" o.c.	inside face
W4	CONCRETE	8"	4#s AT 12" o.c.	3#s AT 12" o.c.	centered in wall thickness

CONCRETE WALL REINFORCING SCHEDULE NOTES:
1. REFER TO STRUCTURAL NOTES SHEET FOR LAPS IN STEEL REINFORCEMENT.
2. COORDINATE AND VERIFY ALL DIMENSIONS WITH ARCHITECTURAL DRAWINGS AND EXIST. CONDITIONS

FOUNDATION PLAN
CANNERY TRAIL RESIDENCES - 1750 N OXFORD AVE. - EAU CLAIRE, WI

Date	Description
07.08.2019	Footing/Foundation Permit
08.15.2019	75% CD Set
08.21.2019	Permit
09.25.2019	<Progress>

CAPITAL GROUP
Developer: W Capital Group
hyler@wcapitalgroup.com | 608.345.9848

d
Architect: OpeningDesign
316 W Washington Ave | Suite 675
Madison, WI 53703
ryan@openingdesign.com | 773.225.6456

ROYAL CONSTRUCTION
General Contractor: ROYAL CORPORATION
3653 Greenway Street | Eau Claire, WI 54701
jim@royalbuild.com | 715.225.6377

Cedar Corporation
Civil Engineer: CEDAR CORPORATION
604 Wilson Avenue | Menomonie, WI 54751
kevin.olum@cedarcorp.com | 715.235.9081

XC
Structural Engineer: XC Structural Engineering
Calle Apolonia Morales, 628036 Madrid,
l.perezata@xcengineering.xyz | +34 610 56 26 37

Innovation
Engineering Services Incorporated


Structural Engineer of Record: Innovation
4729 Dale-Curtain Dr, McFarland, WI 53558
kfrey@innovationbuild.com

Hovland's
Mechanical Engineer: HOVLAND'S HVAC
10954 E. Melby Street | Chippewa Falls, WI 54729
jhansen@hovlands-inc.com | 715.552.5595

PRISM DESIGN
Electrical Engineer: PRISM DESIGN ELECTRICAL CONSULTANTS INC
E8403 State Rd 85 | Mondovi, WI 54755
bhaigren@prismdesign-electrical.com | 715.797.0602

TAILORED ENGINEERING
Plumbing Engineer: TAILORED ENGINEERING
1600 Aspen Commons | Ste 210 | Middleton, WI 53552
bnovak@tailoredeng.com | 608.209.7500

S100
9/25/2019 10:55:37 PM



S400

9/25/2019 10:55:54 PM