

E

D

C

B

A

CURRENT CODES

- INTERNATIONAL BUILDING CODE - 2015
- ASCE STANDARD ASCE/SEI 7-10 - MINIMUM DESIGN LOADS FOR BUILDINGS AND OTHER STRUCTURES
- 2012 NATIONAL DESIGN SPECIFICATION (NDS) FOR WOOD CONSTRUCTION
- NATIONAL DESIGN SPECIFICATION (NDS) SUPPLEMENT: DESIGN VALUES FOR WOOD CONSTRUCTION 2015 EDITION
- ACI 318-11: BUILDING CODE REQUIREMENTS FOR STRUCTURAL CONCRETE AND COMMENTARY
- S30/S30.1-11: BUILDING CODE REQUIREMENTS AND SPECIFICATION FOR MASONRY STRUCTURES AND RELATED COMMENTARIES
- AWS D1.1/D1.1M:2015 STRUCTURAL WELDING CODE - STEEL
- ANSI/AISC 360-10 - SPECIFICATION FOR STRUCTURAL STEEL BUILDINGS

DESIGN - LOADS & CRITERIA

1-LIVE LOAD	
FLOOR FRAMING (RETAIL, OFFICE, RESTAURANT, RECREATIONAL)	100 PSF
FLOOR FRAMING (RESIDENTIAL AREAS)	40 PSF
STAIRWAYS, EXITS	100 PSF
BALCONIES	75 PSF
PRIVATE GARAGES (PASSENGER VEHICLES ONLY)	40 PSF
INTERIOR PARTITION WALLS (UNIFORMLY DISTRIBUTED WEIGHT)	15 PSF
CORRIDORS FIRST FLOOR	100 PSF
CORRIDORS 2ND AND 3RD FLOORS	40 PSF
CORNICES	60 PSF
2-SNOW LOAD	
DESIGN SNOW LOAD	42 PSF (BALANCED)
(pF) FLAT ROOF SNOW LAOD (pF = 0.7CeCtIspp)	42 PSF
(Ce) SNOW EXPOSURE FACTOR	1.0
(Is) SNOW LOAD IMPORTANCE FACTOR	1.0
(Ct) ROOF THERMAL FACTOR	1.0
(Pg) GROUND SNOW	60 PSF
(Cs) SLOPED ROOF FACTOR	1.0
3-WIND LOADS	
(W) WIND IMPORTANCE FACTOR	1.0
RISK CATEGORY II	
BASIC WIND SPEED (3-SEC. GUST, ULTIMATE)	115 MPH
BASIC WIND SPEED (3-SEC. GUST, NOMINAL)	90 MPH
MEAN ROOF HEIGHT	33FT
WIND EXPOSURE CATEGORY	B
WIND EXPOSURE CLASSIFICATION	ENCLOSED
(Kz) VELOCITY EXPOSURE COEFFICIENT	0.720
(Kzt) TOPOGRAPHIC FACTOR	1.0
DESIGN PROCEDURE	METHOD 1 (SIMPLIFIED)
4-EARTHQUAKE LOADS	
OCCUPANCY CATEGORY	II
(Ie) SEISMIC IMPORTANCE FACTOR	1
(Ss) SHORT PERIOD SPECTRAL ACCELERATION	0.045 g
SPECTRAL RESPONSE ACCELERATIONS SS, AT SHORT PERIODS	0.038 g
SITE CLASSIFICATIONS	B
(Fa) SITE COEFFICIENT	1.0
(Fv) SITE COEFFICIENT	1.0
(Sds) DESIGN SPECTRAL RESPONSE ACCELERATION - SHORT PERIODS	0.030 g
(sd1) DESIGN SPECTRAL RESPONSE ACCELERATION - AT 1 SEC. PERIODS	0.025 g
SEISMIC DESIGN CATEGORY A	
SEISMIC-FORCE-RESISTING SYSTEM	WOOD STRUCTURAL PANEL (WSP) SHEATHED SHEAR WALLS
ANALYSIS PROCEDURE	EQUIVALENT LATERAL FORCE PROCEDURE (ELFP)
5-SOIL	
SOIL UNIT WEIGHT	125 PCF (ASSUMED)
LATERAL EARTH PRESSURE - AT REST (BASEMENT WALLS)	62.5 FPS/FT OF DEPTH (ASSUMED)
LATERAL EARTH PRESSURE - PASSIVE	340 PSF (ASSUMED)
COEFFICIENT OF SLIDING FRICTION	0.30 (ASSUMED)
SUBGRADE MODULUS	260 PCI (ASSUMED)
ALLOWABLE SOIL BEARING: PRESSURE	3000 PSF

DEFLECTION LIMITS			
DESCRIPTION	SNOW OR		DEAD + LIVE OR SNOW
	LIVE LOADS	DEAD LOADS	
EXTERIOR WALLS			
RIGID MATERIALS (BRICK/MASONRY)	N/A	L/600	N/A
FLEXIBLE MATERIALS	N/A	L/360	N/A
FLOOR			
RIGID MATERIALS (BRICK/MASONRY)	L/600	L/600	L/600
WITH GYPSUM BOARD CEILINGS	L/540	N/A	L/360
FLEXIBLE MATERIALS	L/540	N/A	L/360
LINTELS, HEADER, AND/OR BEAM			
RIGID MATERIALS (BRICK/MASONRY)	L/600	L/600	L/600
FLEXIBLE MATERIALS	L/360	L/360	L/240
ROOF			
WITH GYPSUM BOARD CEILINGS	L/360	L/360	L/240
FLEXIBLE CEILINGS	L/360	L/360	L/240
NO CEILING	L/240	L/240	L/180
RIGID MATERIALS (BRICK/MASONRY)	L/600	L/600	L/600

NET PRESSURE COEFFICIENTS C _{net}		
AREA	C _{net} + INTERNAL PRESSURE	C _{net} - INTERNAL PRESSURE
WINDWARD WALL	0.43	0.73
LEEWARD WALL	-0.51	-0.21
SIDEWALL	-0.66	-0.35
PARAPET WINDWARD WALL	1.28	
PARAPET LEEWARD WALL	-0.85	
FLAT ROOF	-1.09	-0.79

NET PRESSURE COEFFICIENTS P _{net}		
AREA	P _{net} + INTERNAL PRESSURE	P _{net} - INTERNAL PRESSURE
WINDWARD WALL	10.5 psf	17.8 psf
LEEWARD WALL	-12.4 psf	-5.1 psf
SIDEWALL	-16.1 psf	-8.5 psf
PARAPET WINDWARD WALL	31.2 psf	
PARAPET LEEWARD WALL	-20.7 psf	
FLAT ROOF	-26.6 psf	-19.3 psf

FOOTINGS, FOUNDATIONS AND EARTHWORK:

- DO NOT POUR ANY FOOTINGS ON FROZEN SOILS
- ALL FOOTINGS POURED BELOW LOCAL FROST LINE
- EXPOSED BEARING STRATUM SHOULD BE VERIFIED BY CONTRACTOR AND SOILS ENGINEER TO SATISFY NET ALLOWABLE SOIL BEARING CAPACITY AS OUTLINED IN THESE CONSTRUCTION DOCUMENTS, AS WELL AS THE PROJECT'S GEO-TECHNICAL REPORT. IF EXCAVATED BEARING SOILS FALL BELOW OUTLINED CAPACITIES, CONTINUE EXCAVATION UNTIL BEARING CAPACITIES ARE MET. EXTEND FOOTINGS DOWN TO NEW BEARING ELEVATION, OR USE ENGINEERED FILL TO MAKE UP THE DIFFERENCE. ALL ENGINEERED FILL TO BE DESIGNED BY SOILS ENGINEER AND TO BE FREE OF DRAINING GRANULAR MATERIAL COMPACTED TO 90% OF MODIFIED PROCTOR DENSITIES.
- SEE DESIGN LOADS AND CRITERIA FOR DETAILS RELATIVE TO ASSUMED SOIL CONDITIONS, AND GEO-TECHNICAL RECOMMENDATIONS. COORDINATE ANY SOIL CAPACITIES THAT FALL BELOW THOSE OUTLINED WITH THE STRUCTURAL ENGINEER.
- WHEN APPLICABLE, BACK-FILLING SHOULD BE DONE SIMULTANEOUSLY ON BOTH SIDE OF A CONCRETE FOUNDATION WALL
- DO NOT PLACE BACK FILL AGAINST BASEMENT WALLS UNTIL 1ST FLOOR FRAMING SYSTEM IS IN PLACE.
- SHORING AND UNDERPINNING DESIGNED TO PREVENT 1/4" MAX MOVEMENT IN EITHER THE VERT/HORZ. DIRECTION
- ALL BACK FILL WITHIN 3FT OF FOUNDATION WALLS TO BE GRANULAR FILL APPROVED BY THE PROJECT'S SOIL'S ENGINEER AND COMPACTED TO 90% OF STANDARD PROCTOR DENSITY

REBAR CONTINUITY:

UNLESS OTHERWISE NOTED, ALL REINFORCING SHOULD BE CONTINUOUS. CONTACT LAPSE SLICING TO BE USED AT CORNERS AND INTERSECTION - SEE TYPICAL DETAIL. ALL SPLICES TO BE CLASS B SPLICES. SHOP DRAWINGS SHOULD SHOW THE LOCATION AND OVERLAP DISTANCE OF ALL LAP SPLICES.

REBAR CONTINUITY								
REBAR LOCATION	#3	#4	#5	#6	#7	#8	#9	#10
3,000 - 3,500 PSI								
TOP BARS	22"	20"	34"	47"	70"	94"	118"	150"
OTHER BARS	17"	22"	28"	34"	55"	71"	115"	143"
4,000 - 4,500 PSI								
TOP BARS	16"	19"	26"	36"	60"	80"	103"	158"
OTHER BARS	16"	16"	19"	28"	48"	63"	78"	100"

TOP BARS ARE HORIZONTAL BARS WITH MORE THAN 12" DEPTH OF CONCRETE CAST BELOW THE REINFORCEMENT. TABLE ABOVE DOES NOT APPLY TO EPOXY COATED REBAR

MECHANICAL CONNECTIONS CAN BE USED IN PLACE OF LAP SPLICES. SHOP DRAWING, WITH APPROPROATE ICC-ES REPORT, TO BE SUBMITTED TO ARCHITECT AND ENGINEER FOR REVIEW. CONNECTIONS SHALL DEVELOP 125 PERCENT OF THE SPECIFIED YIELD STRIGHTH OF THE BAR IN TENSION.



CAPITAL GROUP
Developer: W Capital Group
tyler@wcapitalgroupre.com | 608.345.9848




Architect: OpeningDesign
316 W Washington Ave | Suite 675
Madison, WI 53703
ryon@openingdesign.com | 773.425.6456



General Contractor: ROYAL CONSTRUCTION
3653 Greenway Street | Eau Claire, WI 54701
jim@royalbuilt.com | 715-225-6377



Civil Engineer: CEDAR CORPORATION
604 Wilson Avenue | Menomonie, WI 54751
kevin.olum@cedarcorp.com | 715-235-9081



Structural Engineer: XC Structural Engineering
Calle Apolonia Morales, 628036 Madrid,
l.perezata@xcengineering.xyz | +34 610 56 26 37



Structural Engineer of Record: Ennovation
4729 Dale-Curtain Dr, McFarland, WI 53558
khrey@ennovationbuilt.com



Mechanical Engineer: HOVLAND'S HVAC
10954 E. Wellyby Street | Chippewa Falls, WI 54729
jhansen@hovlands-inc.com | 715.552.5595



Electical Engineer: PRISM DESIGN ELECTRICAL CONSULTANTS INC
E8403 State Rd 85 | Mondovi, WI 54755
bhaigren@prismdesign-electrical.com | 715.797.0602



Plumbing Engineer: TAILORED ENGINEERING
1600 Aspen Commons | Ste 210 | Middleton, WI 53562
bnovak@tailoredeng.com | 608.209.7500