

MASONRY WALL REINFORCING SCHEDULE			
MARK	WALL THICKNESS	VERTICAL REINFORCEMENT & SPACING	REINFORCEMENT LOCATION IN CELL
MW.1	8"	#5 AT 48" o/c MAX	CENTER
MW.2	8"	#6 AT 16" o/c MAX	INSIDE FACE

MASONRY WALL REINFORCING SCHEDULE NOTES:
1. GROUT CONCRETE MASONRY UNITS SOLID FULL HEIGHT OF BUILDING AT REINFORCEMENT LOCATIONS.
2. UNLESS NOTED, USE #5 14" O/C VERT. REINFORCEMENT.
3. PROVIDE CONCRETE MASONRY UNIT WALL REINFORCING ABOVE AND BELOW ALL MASONRY OPENINGS: EXTEND THE LENGTH OF THE REBARS BY 23" OR 40 BAR DIAMETERS PAST THE EDGE OF THE OPENING.
4. REINFORCING TO BE HOT-DIPPED GALVANIZED IN EXTERIOR WALLS AND MILL-GALVANIZED FOR INTERIOR WALLS.
5. PROVIDE STANDARD (W1) HORIZONTAL JOINT REINFORCING AT 10' ON CENTER VERTICALLY (8' ON CENTER IN PARAPET WALLS) UNO.
6. MASONRY FIREWALL CONSTRUCTION ASSUMES MASONRY BLOCKS COMPRISED OF LIMESTONE.

MASONRY WALL FOOTING SCHEDULE			
MARK	WIDTH	THICKNESS	LONGITUDINAL
MWF.1	2'-0"	1'-0"	(2) #5
MWF.2	3'-0"	1'-2"	(3) #5

MASONRY WALL FOOTING SCHEDULE NOTES:
1. REFER TO STRUCTURAL NOTES SHEET FOR LAPS IN STEEL REINFORCEMENT.
2. REFER TO FOUNDATION PLAN FOR TOP OF FOOTING ELEVATIONS.
3. ALL FOOTING EXCAVATIONS SHALL BE INSPECTED AND APPROVED BY THE GEOTECHNICAL ENGINEER PRIOR TO PLACING CONCRETE.

THICKENED SLAB SCHEDULE			
MARK	DIMENSIONS	REINFORCEMENT	REMARKS
TS20	2'-0" X (2)'-0"	1'-0"	(2) #5

THICKENED SLAB SCHEDULE NOTES:
1. REFER TO STRUCTURAL NOTES SHEET FOR LAPS IN STEEL REINFORCEMENT.
2. REFER TO FOUNDATION PLAN FOR TOP OF FOOTING ELEVATIONS.
3. ALL FOOTING EXCAVATIONS SHALL BE INSPECTED AND APPROVED BY THE GEOTECHNICAL ENGINEER PRIOR TO PLACING CONCRETE.

WALL FOOTING SCHEDULE			
MARK	DIMENSIONS	REINFORCEMENT	
WF26	2'-6" X 1'-2"	(3) #5	#5's AT 12" BOTTOM FACE
WF40	3'-0" X 1'-2"	(3) #5	#5's AT 12" BOTTOM FACE

COLUMN FOOTING SCHEDULE NOTES:
1. REFER TO STRUCTURAL NOTES SHEET FOR MINIMUM COVER REQUIREMENTS.
2. REFER TO FOUNDATION PLAN FOR TOP OF FOOTING ELEVATIONS.
3. ALL FOOTING EXCAVATIONS SHALL BE INSPECTED AND APPROVED BY THE GEOTECHNICAL ENGINEER PRIOR TO PLACING CONCRETE.
4. ALL LAPs IN STEEL REINFORCING SHALL BE CLASS "B" LAP SPLICES UNLESS NOTED OTHERWISE.

COLUMN FOOTING SCHEDULE			
MARK	DIMENSIONS	BOTTOM REINFORCING	COLUMNS
FT90a	9'-0" X 9'-0"	1'-8"	(10) #7
FT90b	9'-0" X 9'-0"	1'-8"	(10) #8
FT96a	9'-6" X 9'-6"	1'-8"	(10) #7
FT96b	9'-6" X 9'-6"	1'-8"	(10) #8
FT106	10'-0" X 10'-0"	2'-1"	(11) #8
FT110a	11'-0" X 11'-0"	2'-1"	(12) #8
FT110b	11'-0" X 11'-0"	2'-3"	(12) #8
FT116	11'-6" X 11'-6"	2'-1"	(12) #8
FT120	12'-0" X 12'-0"	2'-3"	(13) #8

COLUMN FOOTING SCHEDULE:
1. REFER TO STRUCTURAL NOTES SHEET FOR LAPS IN STEEL REINFORCEMENT.
2. REFER TO FOUNDATION PLAN FOR TOP OF FOOTING ELEVATIONS.
3. ALL FOOTING EXCAVATIONS SHALL BE INSPECTED AND APPROVED BY THE GEOTECHNICAL ENGINEER PRIOR TO PLACING CONCRETE.

CONCRETE WALL REINFORCING SCHEDULE				
MARK	TYPE	THICKNESS	REINFORCEMENT	REMARKS
W1	CONCRETE	10"	5#'s AT 18" o.c.	Inside face
W2	CONCRETE	10"	5#'s AT 12" o.c.	5#'s AT 12" o.c. inside face
W3	CONCRETE	10"	6#'s AT 12" o.c.	6#'s AT 12" o.c. inside face
W4	CONCRETE	8"	4#'s AT 12" o.c.	3#'s AT 12" o.c. centered in wall thickness

CONCRETE WALL REINFORCING SCHEDULE NOTES:
1. REFER TO STRUCTURAL NOTES SHEET FOR LAPS IN STEEL REINFORCEMENT.
2. COORDINATE AND VERIFY ALL DIMENSIONS WITH ARCHITECTURAL DRAWINGS AND EXIST. CONDITIONS.

Date	Description
07.08.2019	Footing/Foundation Permit
08.15.2019	75% CD Set
08.21.2019	Permit
09.25.2019	<Progress>

6



Developer: W Capital Group
wcapitalgroupre.com | 608.345.9848



Architect: OpeningDesign
316 W Washington Ave | Suite 675
Madison, WI 53703
ryan@openingdesign.com | 773.425.6456



General Contractor: ROYAL CONSTRUCTION
3653 Greenway Street | Eau Claire, WI 54701
jim@royalbuilt.com | 715-225-6377



Civil Engineer: CEDAR CORPORATION
604 Wilson Avenue | Menomonie, WI 54751
kevin.ouim@cedarcorp.com | 715-235-9081



Structural Engineer: XC Structural Engineering
Calle Apolonio Morales, 628036 Madrid,
l.pereztato@xcengineering.xyz | +34 610 56 26 37



Structural Engineer of Record: Ennovation
4729 Dale-Curtain Dr, McFarland, WI 53558



Mechanical Engineer: HOVLAND'S HVAC
10954 E. Melby Street | Chippewa Falls, WI 54729
jhansen@hovlands-inc.com | 715.552.5595



CONSULTANTS INC.



Plumbing Engineer: TAILORED ENGINEERING
1600 Aspen Commons | Ste 210 | Middleton, WI
53562



ELEVATIONS - FOUNDATION CANNERY TRAIL RESIDENCES - 1750 N OXFORD AVE. - EAU CLAIRE, WI

S300

6 2 5 1 4 3 2 1 4



tyler@wcapitalgroupre.com | 608.345.9848

tyler@wcapitalgroupre.com | 608.345.9848

tyler@wcapitalgroupre.com | 608.345.9848



Architect: OpeningDesign
316 W Washington Ave | Suite 675
Madison, WI 53703
ryan@openingdesign.com | 773.425.6456



General Contractor: ROYAL CONSTRUCTION
653 Greenway Street | Eau Claire, WI 54701
jim@royalbuilt.com | 715-225-6377



Civil Engineer: CEDAR CORPORATION
604 Wilson Avenue | Menomonie, WI 54751
kevin.ouim@cedarcorp.com | 715-235-9081




structural Engineer: XC Structural Engineering
Calle Apolonio Morales, 628036 Madrid,
ereztato@xcengineering.xyz | +34 610 56 26 37



Structural Engineer of Record: Ennovation
4729 Dale-Curtain Dr, McFarland, WI 53558
kfrey@ennovationbuilt.com




Mechanical Engineer: HOVLAND'S HVAC
254 E. Melby Street | Chippewa Falls, WI 54729
ihansen@hovlands-inc.com | 715.552.5595



The logo for Prism Design Electrical Consultants Inc. It features a circular graphic composed of several curved, overlapping bands of different shades of blue and grey, resembling a rising sun or a stylized 'P'. Below this graphic, the company name is written in a serif font, with 'ELECTRICAL' on the first line and 'CONSULTANTS INC.' on the second line, separated by a thin horizontal line.



Plumbing Engineer: TAILORED ENGINEERING
100 Aspen Commons | Ste 210 | Middleton, WI
53562
bnovak@tailoredeng.com | 608.209.7500



CANNERY TRAIL RESIDENCES - 1750 N OXFORD AVE. - EAU CLAIRE, WI

S301

9/25/2019 11:15:11

