

Date	Description
07.08.2019	Footing/Foundation Permit
08.21.2019	Permit

STRUCTURAL NOTES

CANNERY TRAIL RESIDENCES - 1750 N OXFORD AVE. - EAU CLAIRE, WI

S000

10/7/2019 10:22:19 PM

DESIGN DATA

APPLICABLE CODES/STANDARDS:
....INTERNATIONAL BUILDING CODE - 2018
....ASCE 7-16 MIN DESIGN LOADS FOR BUILDINGS AND OTHER STRUCTURES, ASCE/SEI

STRUCTURAL DESIGN STANDARDS (DESIGN SHALL CONFORM TO THE CURRENT EDITION UNDER THE APPLICABLE CODE):
....ACI 318 BUILDING CODE REQUIREMENTS FOR STRUCTURAL CONCRETE AND COMMENTARY
....ACI 530/531 BLDG CODE REQUIREMENTS AND SPECS FOR MASONRY STRUCTURES (AND RELATED COMMENTARIES)
....ANSI/AISC 360-16 SPECIFICATIONS FOR STRUCTURAL STEEL BUILDINGS
....AWS D1.1/D1.1M STRUCTURAL WELDING CODE-STEEL

DEFLECTION LIMITS			
MEMBERS	LIVE	SNOW or WIND	DEAD + LIVE or SNOW
ROOF MEMBERS			
SUPPORTING GYPSUM BOARD CEILINGS	L/360	L/360	L/240
SUPPORTING FLEXIBLE CEILINGS	L/360	L/360	L/240
NOT SUPPORTING CEILING	L/240	L/240	L/180
SUPPORTING RIGID MATERIALS (BRICK, MASONRY, ETC.)	L/600	L/600	L/600
FLOOR MEMBERS			
SUPPORTING RIGID MATERIALS (BRICK, MASONRY, ETC.)	L/600	L/600	L/600
SUPPORTING GYPSUM BOARD CEILINGS	L/540	N/A	L/360
SUPPORTING FLEXIBLE MATERIALS	L/540	N/A	L/260
WOOD TRUSSES	L/480	L/360	L/240
LINTEL/HEADER/BEAM MEMBERS			
SUPPORTING RIGID MATERIALS (BRICK, MASONRY, ETC.)	L/600	L/600	L/600
SUPPORTING FLEXIBLE MATERIALS (EIFS, SIDING, ETC.)	L/360	L/360	L/240
EXTERIOR WALLS			
WITH RIGID FINISHES (BRICK, MASONRY, ETC.)	N/A	L/600	N/A
WITH FLEXIBLE FINISHES (EIFS, SIDING, ETC.)	N/A	L/360	N/A

BUILDING DESIGN LOADS/CRITERIA

DESIGN LIVE LOADS:
....FLOOR FRAMING (RETAIL, OFFICE, RESTAURANT, RECREATIONAL) 100 psf

....FLOOR FRAMING (RESIDENTIAL AREAS) 40 psf

....STAIRWAYS, EXITS 100 psf

....BALCONIES 75 psf

....PRIVATE GARAGES (PASSENGER VEHICLES ONLY) 40 psf

....INTERIOR PARTITION WALLS (UNIFORMLY DISTRIBUTED WEIGHT) 15 psf

....CORRIDORS FIRST FLOOR 100 psf

....CORRIDORS 2nd & 3rd FLOORS 40 psf

....CORNICES 60 psf

....SLOPED ROOF FACTOR (Cs) 1.0

SNOW LOADS & DESIGN DATA:
....DESIGN SNOW LOAD 42 psf (BALANCED SNOW LOAD)

....FLAT ROOF SNOW LOAD (Pf) = (0.7Ce'Cl'sPg) 42 psf

....SNOW EXPOSURE FACTOR (Ce) 1.0

....SNOW LOAD IMPORTANCE FACTOR (Is) 1.0

....ROOF THERMAL FACTOR (Ci) 1.0

....GROUND SNOW (Pg) 60 psf

....SLOPED ROOF FACTOR (Cs) 1.0

WIND DESIGN DATA:
....WIND IMPORTANCE FACTOR (Iw) 1.0

....RISK CATEGORY II

....BASIC WIND SPEED (5-SECOND GUST, ULTIMATE) 115 MPH

....BASIC WIND SPEED (5-SECOND GUST, NOMINAL) 90 MPH

....MEAN ROOF HEIGHT 33 FT

....WIND EXPOSURE CATEGORY B

....WIND EXPOSURE CLASSIFICATION ENCLOSED

....VELOCITY EXPOSURE COEFFICIENT Kz 0.720

....TOPOGRAPHIC FACTOR (Kt) 1.0

....DESIGN PROCEDURE METHOD 1 (SIMPLIFIED PROCEDURE)

NET PRESSURE COEFFICIENTS C_{net}		
AREA	C_{net} INTERNAL PRESSURE	C_{net} INTERNAL PRESSURE
WINDWARD WALL	0.43	0.73
LEEWARD WALL	-0.51	-0.21
SIDEWALL	-0.66	-0.35
PARAPET WINDWARD WALL	1.28	
PARAPET LEEWARD WALL	-0.85	
FLAT ROOF	-1.09	-0.79

DESIGN WIND PRESSURES P_{net}		
AREA	P_{net} INTERNAL PRESSURE	P_{net} INTERNAL PRESSURE
WINDWARD WALL	10.5 psf	17.8 psf
LEEWARD WALL	-12.4 psf	-5.1 psf
SIDEWALL	-16.1 psf	-8.5 psf
PARAPET WINDWARD WALL	31.2 psf	
PARAPET LEEWARD WALL	-20.7 psf	
FLAT ROOF	-26.6 psf	-19.3 psf

EARTHQUAKE DESIGN DATA:
....OCCUPANCY CATEGORY II
....SEISMIC IMPORTANCE FACTOR (Ie) 1
....MAPPED SPECTRAL ACCELERATIONS AT SHORT PERIODS (Ss) 0.045 g
....MAPPED SPECTRAL ACCELERATIONS AT (1) SECOND PERIODS (S1) 0.038 g
....SITE CLASSIFICATION B
....SOIL COEFFICIENT (Fs) 1.0
....SITE COEFFICIENT (Fv) 1.0
....DESIGN SPECTRAL RESPONSE COEFFICIENT AT SHORT PERIODS (Sds) 0.030 g
....DESIGN SPECTRAL RESPONSE COEFFICIENT AT (1) SECOND PERIODS (Sd1) 0.025 g
....SEISMIC DESIGN CATEGORY A
....BASIC SEISMIC-FORCE-RESISTING SYSTEM LIGHT FRAME WOOD WALLS WITH STRUCTURAL WOOD SHEAR PANELS EQUIVALENT LATERAL FORCE ANALYSIS
....ANALYSIS PROCEDURE FOR SEISMIC DESIGN

SOIL DESIGN VALUES:
....SOIL UNIT WEIGHT 125 PCF (ASSUMED)
....LATERAL EARTH PRESSURE
....AT-REST (BASEMENT WALLS) 62.5 PSF/FT OF DEPTH (ASSUMED)
....PASSIVE 340 PSF (ASSUMED)
....COEFFICIENT OF SLIDING FRICTION 0.30 (ASSUMED)
....SUBGRADE MODULUS 260 PCI (ASSUMED)
....ALLOWABLE SOIL BEARING PRESSURE 3000 PSF

REFER TO SOILS REPORT NO. 17002 DATED 2/10/2017 PREPARED BY ITCO ALLIED ENGINEERING CO. FOR DESCRIPTION OF SOIL CONDITIONS, GEOTECHNICAL RECOMMENDATIONS, AND DESIGN VALUES

FOUNDATION AND EARTHWORK


1. ALL EXTERIOR FOOTINGS MUST BEAR BELOW LOCAL FROST LINE RELATIVE TO ADJACENT FINISH EXTERIOR GRADE.
2. DO NOT PLACE ANY FOOTINGS ON FROZEN SUBGRADE.
3. BACK FILLING SHALL BE DONE SIMULTANEOUSLY ON BOTH SIDES OF FOUNDATION WALLS.
4. DO NOT PLACE BACK FILL AGAINST BASEMENT WALLS UNTIL THE TOP AND BOTTOM OF THE WALL ARE ADEQUATELY BRACED BY THE SLAB ON GRADE AND THE FLOOR FRAMING AT THE TOP OF THE WALL.
5. REMOVE ANY EXISTING CONCRETE 2'-0" BELOW NEW CONCRETE FOOTINGS AND SLABS ON GRADE, UNLESS NOTED OTHERWISE.
6. SHORING/OR UNDERPINNING SHALL BE DESIGNED TO LIMIT HORIZONTAL AND VERTICAL MOVEMENT OF EXISTING CONSTRUCTION TO 1/4" MAXIMUM IN ANY DIRECTION.
7. CENTER PIER AND COLUMN FOOTINGS ON COLUMN CENTERLINES AND WALL FOOTINGS ON WALL CENTERLINES UNLESS SPECIFICALLY NOTED OTHERWISE.
8. ALL BACK FILL WITHIN 3'-0" OF RETAINING WALLS AND BASEMENT WALLS SHALL BE FREE DRAINING GRANULAR MATERIAL APPROVED BY A SOILS ENGINEER AND COMPAKTED TO 90% STANDARD PROCTOR.
9. TOP OF FOOTING ELEVATIONS SHOWN ON THESE CONSTRUCTION DOCUMENTS REPRESENT MINIMUM FOOTING DEPTHS FOR FROST PROTECTION AND BEST JUDGMENT OF A SUITABLE BEARING STRATUM. ACTUAL GRADE CONDITIONS AND SUITABLE BEARING STRATUM MUST BE VERIFIED BY THE CONTRACTOR AND A SOILS ENGINEER AT THE TIME OF EXCAVATION.
10. FOOTING EXCAVATIONS MUST EXTEND TO COMPETENT BEARING MATERIAL. CONTRACTOR SHALL HIRE A SOILS ENGINEER TO FIELD VERIFY NET ALLOWABLE SOIL BEARING CAPACITY STATED ON THESE CONSTRUCTION DOCUMENTS AND IN GEOTECHNICAL REPORT FOR THIS PROJECT. THE SUITABLE BEARING STRATUM MAY NOT EXIST AT FOOTING ELEVATION STATED ON CONSTRUCTION DOCUMENTS. CONTRACTOR SHALL BE EXTENDED ANOTHER FOOTING DEPTH IF REQUIRED. PLACE CONCRETE FOOTINGS OR EXTEND FOOTINGS DOWN TO SUITABLE BEARING STRATUM. ENGINEERED FILL BELOW SLABS ON GRADE AND FOOTINGS SHALL BE FREE DRAINING GRANULAR MATERIAL COMPAKTED TO 95% MODIFIED PROCTOR AND PLACED PER THE SOIL ENGINEERS RECOMMENDATIONS. ALL FIELD CONDITIONS THAT WILL AFFECT DESIGN AS PRESENTED MUST BE COORDINATED WITH STRUCTURAL ENGINEER.

11. REFER TO DESIGN DATA FOR DESCRIPTION OF SOIL CONDITIONS, GEOTECHNICAL RECOMMENDATIONS, AND DESIGN VALUES.

CONTINUITY:

ALL REINFORCING SHALL BE CONTINUOUS UNLESS NOTED OTHERWISE. CONTINUITY AT CORNERS AND INTERSECTIONS SHALL BE ACHIEVED USING CORNER BARS AND CONTACT LAP SPLICES. SEE TYPICAL DETAIL. CONTINUITY AT OTHER LOCATIONS MAY BE ACHIEVED USING CONTACT LAP SPLICES SHOWN ON APPROVED SHOP DRAWINGS. LOCATION OF LAP SPLICES SHALL BE SHOWN ON THE SHOP DRAWINGS. UNLESS NOTED OTHERWISE, THE FOLLOWING LAP SPLICES SHALL BE USED: (ALL LAP SPLICES ARE CLASS B 3 SPLICES)

LOCATION:	#3	#4	#5	#6	#7	#8	#9	#10	#11
3,000 & 3,500 PSI CONCRETE:									
- TOP BARS (*)	21"	19"	35"	46"	71"	93"	118"	149"	184"
- OTHER BARS:	16"	22"	27"	35"	55"	71"	91"	115"	142"
4,000 & 4,500 PSI CONCRETE:									
- TOP BARS (*)	16"	19"	25"	36"	61"	80"	102"	129"	159"
- OTHER BARS:	16"	16"	19"	28"	47"	62"	78"		



MASONRY WALL REINFORCING SCHEDULE			
MARK	WALL THICKNESS	VERTICAL REINFORCEMENT & SPACING	REINFORCEMENT LOCATION IN CELL
MW.1	8"	#5 AT 48" o/c MAX	CENTER
MW.2	8"	#6 AT 16" o/c MAX	INSIDE FACE

MASONRY WALL REINFORCING SCHEDULE NOTES:
1. GROUT CONCRETE MASONRY UNITS SOLID FULL HEIGHT OF BUILDING AT REINFORCEMENT LOCATIONS.
2. UNLESS NOTED, PROVIDE #6 REINFORCEMENT.
3. PROVIDE CONCRETE MASONRY UNIT WALL REINFORCING ABOVE AND BELOW ALL MASONRY OPENINGS: EXTEND THE LENGTH OF THE REBARS BY 23" OR 40 BAR DIAMETERS PAST THE EDGE OF THE OPENING.
4. REINFORCING TO BE HOT-DIPPED GALVANIZED.
5. PROVIDE STANDARD (W1) HORIZONTAL JOINT REINFORCING AT 10' ON CENTER VERTICALLY (8' ON CENTER IN PARAPET WALLS) UNO.
6. MASONRY FIREWALL CONSTRUCTION ASSUMES MASONRY BLOCKS COMPRISED OF LIMESTONE.

MASONRY WALL FOOTING SCHEDULE			
MARK	WIDTH	THICKNESS	LONGITUDINAL
MWF.1	2'-0"	1'-0"	(2) #5
MWF.2	3'-0"	1'-2"	(3) #5

MASONRY WALL FOOTING SCHEDULE NOTES:
1. REFER TO STRUCTURAL NOTES SHEET FOR LAP'S IN STEEL REINFORCEMENT.
2. REFER TO FOUNDATION PLAN FOR TOP OF FOOTING ELEVATIONS.
3. ALL FOOTING EXCAVATIONS SHALL BE INSPECTED AND APPROVED BY THE GEOTECHNICAL ENGINEER PRIOR TO PLACING CONCRETE.

THICKENED SLAB SCHEDULE			
MARK	DIMENSIONS	REINFORCEMENT	REMARKS
TS20	2'-0" x 10'-0"	1'-0"	(2) #5

THICKENED SLAB SCHEDULE NOTES:
1. REFER TO STRUCTURAL NOTES SHEET FOR LAP'S IN STEEL REINFORCEMENT.
2. REFER TO FOUNDATION PLAN FOR TOP OF FOOTING ELEVATIONS.
3. ALL FOOTING EXCAVATIONS SHALL BE INSPECTED AND APPROVED BY THE GEOTECHNICAL ENGINEER PRIOR TO PLACING CONCRETE.

WALL FOOTING SCHEDULE			
MARK	DIMENSIONS	REINFORCEMENT	
WF26	2'-6" x 10'-0"	1'-2"	(3) #5 @ 12" BOTTOM FACE
WF20	3'-0" x 10'-0"	1'-2"	(3) #5 @ 12" BOTTOM FACE


COLUMN FOOTING SCHEDULE NOTES:
1. REFER TO STRUCTURAL NOTES SHEET FOR MINIMUM COVER REQUIREMENTS.
2. REFER TO FOUNDATION PLAN FOR TOP OF FOOTING ELEVATIONS.
3. ALL FOOTING EXCAVATIONS SHALL BE INSPECTED AND APPROVED BY THE GEOTECHNICAL ENGINEER PRIOR TO PLACING CONCRETE.
4. ALL LAP'S IN STEEL REINFORCING SHALL BE CLASS "B" LAP SPLICES UNLESS NOTED OTHERWISE.

COLUMN FOOTING SCHEDULE							
Type Mark	Type	No.	EI @ Top	Dimensions	Bottom Reinforcing	Type	Comments
FT70	FT70 - 7x7x0x1-8	1	1'-4" x 0"	7'-0" x 7'-0" x 1'-8"	81.67 CF (10) #7 (10) #7		
FT90	FT90 - 9x9x0x2x1	7	1'-4" x 0"	9'-0" x 9'-0" x 2'-1"	168.75 CF (10) #8 (10) #8		
FT96a	FT96a - 9x9x6x2-6	1	1'-4" x 0"	9'-6" x 9'-6" x 2'-6"	225.63 CF (10) #7 (10) #7		
FT100a	FT100a - 10x10x0x2-2	2	1'-4" x 0"	10'-0" x 10'-0" x 2'-2"	208.33 CF (11) #8 (11) #8		
FT100b	FT100b - 10x10x0x2-3	3	1'-4" x 0"	10'-0" x 10'-0" x 2'-3"	225.00 CF (11) #8 (11) #8		
FT106	FT106 - 10x6x10x6x6	10	1'-4" x 0"	10'-6" x 6'-0" x 6'-0" x 6'-0"	275.63 CF (11) #8 (11) #8		
FT110a	FT110a - 11x11x0x2-3	2	1'-4" x 0"	11'-0" x 11'-0" x 2'-3"	272.25 CF (12) #8 (12) #8		
FT110b	FT110b - 11x11x0x2-4	2	1'-4" x 0"	11'-1" x 11'-0" x 2'-4"	302.50 CF (12) #8 (12) #8		
FT116	FT116 - 11x6x11x6x6	1	1'-4" x 0"	11'-6" x 11'-6" x 6'-0"	330.63 CF (12) #8 (12) #8		
FT120a	FT120a - 12x12x12x0x3	4	1'-4" x 0"	12'-0" x 12'-0" x 3'-0"	432.00 CF (13) #8 (13) #8		
FT120b	FT120b - 12x12x12x0x3	3	1'-4" x 0"	12'-0" x 12'-0" x 3'-6"	504.00 CF (13) #8 (13) #8		
FT126	FT126 - 12x12x12x0x6	1	1'-4" x 0"	12'-6" x 12'-6" x 6'-0"	546.88 CF (13) #8 (13) #8		


COLUMN FOOTING SCHEDULE NOTES:
1. REFER TO STRUCTURAL NOTES SHEET FOR LAP'S IN STEEL REINFORCEMENT.
2. REFER TO FOUNDATION PLAN FOR TOP OF FOOTING ELEVATIONS.
3. ALL FOOTING EXCAVATIONS SHALL BE INSPECTED AND APPROVED BY THE GEOTECHNICAL ENGINEER PRIOR TO PLACING CONCRETE.

CONCRETE WALL REINFORCING SCHEDULE					
MARK	TYPE	THICKNESS	REINFORCEMENT	REMARKS	
W1	CONCRETE	14"	5#'s AT 18" o.c.	5#'s AT 12" o.c.	Inside face
W2	CONCRETE	10"	5#'s AT 12" o.c.	5#'s AT 12" o.c.	Inside face
W3	CONCRETE	10"	6#'s AT 12" o.c.	6#'s AT 12" o.c.	Inside face
W4	CONCRETE	8"	4#'s AT 12" o.c.	3#'s AT 12" o.c.	centered in wall thickness
W5	CONCRETE	8"	4#'s AT 12" o.c.	3#'s AT 12" o.c.	Inside face

CONCRETE WALL REINFORCING SCHEDULE NOTES:
1. REFER TO STRUCTURAL NOTES SHEET FOR LAP'S IN STEEL REINFORCEMENT.
2. COORDINATE AND VERIFY ALL DIMENSIONS WITH ARCHITECTURAL DRAWINGS AND EXIST. CONDITIONS



Date	Description
07.08.2019	Footing/Foundation Permit
08.15.2019	75% CD Set
08.21.2019	Permit
09.25.2019	<Progress>



STRUCTURAL DETAILS

CANNERY TRAIL RESIDENCES - 1750 N OXFORD AVE. - EAU CLAIRE, WI

CAPITAL GROUP
Developer: W Capital Group
tyler@wcapitalgroupre.com | 608.345.9848

OpeningDesign
Architect: OpeningDesign
316 W Washington Ave | Suite 675
Madison, WI 53703
ryan@openingdesign.com | 773.425.6457

ROYAL CONSTRUCTION
General Contractor: ROYAL CONSTRUCTION
3453 Greenway Street | Eau Claire, WI 54701
jim@royalbuilt.com | 715-225-6377

Cedar Corporation
Civil Engineer: CEDAR CORPORATION
404 Wilson Avenue | Menomonie, WI 54751
kevin.colm@cedarcorp.com | 715-235-9081

XC Structural Engineering
Colle Apolonia Morales, 628036 Madrid,
l.perezato@xcengineering.xyz | +34 610 56 26 37

Ennovation
Engineering Services Incorporated
4727 Dale-Curtin Dr. McFarland, WI 53558
khsley@innovation-built.com


Hovland's
Heating - Ventilation - Air Conditioning
Mechanical Engineer: HOVLAND'S HVAC
10954 E. Melby Street | Chippewa Falls, WI 54729
jansen@hovlands-inc.com | 715.552.5595


PRISM DESIGN CONSULTANTS INC.
Electrical Engineer: PRISM DESIGN ELECTRICAL CONSULTANTS INC
E8403 State Rd 85 | Mondovi, WI 54755
bhalgren@prismdesign-electrical.com | 715.797.0602


TAILORED ENGINEERING
Plumbing Engineer: TAILORED ENGINEERING
1600 Aspen Commons | Ste 210 | Middleton, WI 53562
bnovak@tailoredeng.com | 608.209.7500

Date	Description
07.08.2019	Footing/Foundation Permit
08.15.2019	75% CD Set
08.21.2019	Permit

Date	Description
07.08.2019	Footing/Foundation Permit
08.21.2019	Permit
09.25.2019	<Progress>







CAPITAL GROUP
Developer: W Capital Group
tyler@wcapitalgroup.com | 608.345.6458

Architect: OpeningDesign
316 W Washington Ave | Suite 675
Madison, WI 53703
ryan@openingdesign.com | 773.425.6456

ROYAL CONSTRUCTION
General Contractor: ROYAL CONSTRUCTION
3453 Greenway Street | Eau Claire, WI 54701
jim@royalbuilt.com | 715-225-6377

Cedar Corporation
Civil Engineer: CEDAR CORPORATION
404 Wilson Avenue | Menomonie, WI 54751
kevin.colm@cedarcorp.com | 715-235-9081

XC
Structural Engineer: XC Structural Engineering
Calle Apolonia Morales, 628036 Madrid,
l.perezato@xcengineering.xyz | +34 610 56 26 37




Innovation
Engineering Services Incorporated
4729 Dale-Curtin Dr. McFarland, WI 53558
khsley@innovation-built.com

Hovland's
Heating - Ventilation - Air Conditioning
Mechanical Engineer: HOVLAND'S HVAC
10954 E. Melby Street | Chippewa Falls, WI 54729
jansen@hovlands-inc.com | 715.552.5595

PRISM DESIGN
ELECTRICAL CONSULTANTS INC.
Electrical Engineer: PRISM DESIGN ELECTRICAL CONSULTANTS INC
EB403 State Rd 85 | Mondovi, WI 54755
bhalgren@prismdesign-electrical.com | 715.797.0602

TAILORED ENGINEERING
Plumbing Engineer: TAILORED ENGINEERING
1600 Aspen Commons | Ste 210 | Middleton, WI 53562
bnovak@tailoredeng.com | 608.209.7500


Date	Description
08.15.2019	75% CD Set
08.21.2019	Permit
09.25.2019	<Progress>



6 FLOOR FRAMING AT SECOND FLOOR, EXTERIOR BEARING WALL
S214


7 CANTILEVER SECTION
S214

8 CANTILEVER, LATERAL VIEW
S214




C15x40 DETAIL

9 FLOOR FRAMING AT LOBBY, COURTYARD STEEL BEAM
S214




11 FLOOR FRAMING AT LOBBY, INTERIOR BEARING WALL
S214


12 METAL BALCONY BASE CONNECTION 2nd FLOOR
S214




Date	Description
08.15.2019	75% CD Set
08.21.2019	Permit
09.25.2019	<Progress>




5 FLOOR FRAMING AT CORRIDOR. INTERIOR BEARING WALL



8 FLOOR FRAMING AT CORRIDOR. PLATFORM FRAMING AT INTERIOR BEARING WALL




11 FLOOR FRAMING AT CORRIDOR. PLATFORM FRAMING AT EXTERIOR BEARING WALL




6 S215 FLOOR FRAMING AT EXTERIOR WALL BEARING ON HEADER

9 S215 FLOOR FRAMING PARALLEL TO EXTERIOR WALL





12 S215 METAL BALCONY BASE CONNECTION AND HANGER ROD CONNECTION. 3rd FLOOR




7 S215 FLOOR FRAMING AT EXTERIOR BEARING WALL

10 S215 FLOOR FRAMING AT CORRIDOR. INTERIOR HEADER



Date	Description
08.15.2019	75% CD Set
08.21.2019	Permit
09.25.2019	<Progress>

WOOD SHEAR WALL SCHEDULE													
Shear wall	Sheathing material	Panel thickness	Bucking	Minimum distance from framing member or blocking	Fastener type and size	Panel edge fastener spacing	Notched or inset panel	Hold-down anchor capacity	Hold down studs	Hold down anchor type	Bottom plate attachment (foundation)	Bottom plate attachment (floor to floor)	
ID		(in)	(in)	(in)	(in)	(in)	(in)	(in)	(in)	(in)	(in)	(in)	(in)
SW_N3A	Wood structural panels - sheathing	3/8	YES	1-3/8	8d 4	840	2	(1)	Simpson HDU4-SDS2.5	-	-	wood screws 20 (d= 0.32 in) at 25 in. o/c; 30 fasteners in 2 rows.	
SW_N3B	Wood structural panels - sheathing	3/8	NO	1-3/8	8d 6	560	-	-	-	-	-	16d (d= 0.268 in) nails at 24 in. o/c; 16 fasteners in 1 row.	
SW_N3C	Wood structural panels - sheathing	3/8	NO	1-3/8	8d 6	560	-	-	-	-	-	16d (d= 0.268 in) nails at 21 in. o/c; 35 fasteners in 2 rows.	
SW_N3D	Wood structural panels - sheathing	3/8	YES	1-3/8	8d 4	840	2	(1)	Simpson HDU4-SDS2.5	-	-	wood screws 20 (d= 0.32 in) at 25 in. o/c; 30 fasteners in 2 rows.	
SW_N2A	Wood structural panels - sheathing	19/32	YES	1-1/2	10d 4	1430	4	(2)	Simpson HDU4-SDS2.5	-	-	wood screws 20 (d= 0.32 in) at 14 in. o/c; 52 fasteners in 2 rows.	
SW_N2B	Wood structural panels - sheathing	19/32	YES	1-1/2	10d 6	950	-	-	-	-	-	16d (d= 0.268 in) nails at 13 in. o/c; 28 fasteners in 1 row.	
SW_N2C	Wood structural panels - sheathing	19/32	YES	1-1/2	10d 6	950	1	(1)	Simpson HDU4-SDS2.5	-	-	16d (d= 0.268 in) nails at 12 in. o/c; 59 fasteners in 2 rows.	
SW_N2D	Wood structural panels - sheathing	19/32	YES	1-1/2	10d 4	1430	4	(2)	Simpson HDU4-SDS2.5	-	-	wood screws 20 (d= 0.32 in) at 14 in. o/c; 52 fasteners in 2 rows.	
SW_N1A	Wood structural panels - sheathing	19/32	YES	1-1/2	10d 3	1860	7	(3)	Simpson HDU11-SDS2.5	10	36	SDWS log screw (d= 0.197 in) at 12 in. o/c; 58 fasteners in 2 rows.	
SW_N1B	Wood structural panels - sheathing	19/32	YES	1-1/2	10d 6	950	-	-	-	-	11	16d (d= 0.268 in) nails at 19 in. o/c; 39 fasteners in 2 rows.	
SW_N1C	Wood structural panels - sheathing	19/32	YES	1-1/2	10d 6	950	3	(1)	Simpson HDU4-SDS2.5	11	36	wood screws 20 (d= 0.32 in) at 19 in. o/c; 40 fasteners in 2 rows.	
SW_N1D	Wood structural panels - sheathing	19/32	YES	1-1/2	10d 3	1860	7	(3)	Simpson HDU11-SDS2.5	10	36	SDWS log screw (d= 0.197 in) at 12 in. o/c; 60 fasteners in 2 rows.	
SW_S3A	Wood structural panels - sheathing	19/32	YES	1-1/2	10d 6	950	2	(1)	Simpson HDU4-SDS2.5	-	-	wood screws 20 (d= 0.32 in) at 21 in. o/c; 36 fasteners in 2 rows.	
SW_S3B	Wood structural panels - sheathing	19/32	YES	1-1/2	10d 6	950	2	(1)	Simpson HDU4-SDS2.5	-	-	wood screws 20 (d= 0.32 in) at 21 in. o/c; 36 fasteners in 2 rows.	
SW_S2A	Wood structural panels - sheathing	19/32	YES	1-1/2	10d 3	1860	6	(2)	Simpson HDU11-SDS2.5	-	-	SDWS log screw (d= 0.197 in) at 13 in. o/c; 54 fasteners in 2 rows.	
SW_S2B	Wood structural panels - sheathing	19/32	YES	1-1/2	10d 3	1860	6	(2)	Simpson HDU11-SDS2.5	-	-	SDWS log screw (d= 0.197 in) at 13 in. o/c; 54 fasteners in 2 rows.	
SW_S1A	Wood structural panels - sheathing	19/32	YES	1-1/2	10d 2	2435	11	(4)	Simpson HD19	10	36	SDWS log screw (d= 0.197 in) at 8 in. o/c; 76 fasteners in 2 rows.	
SW_S1B	Wood structural panels - sheathing	19/32	YES	1-1/2	10d 2	2435	11	(4)	Simpson HD19	10	36	SDWS log screw (d= 0.197 in) at 8 in. o/c; 76 fasteners in 2 rows.	
SW_E3A	Wood structural panels - sheathing	19/32	YES	1-1/2	10d 4	1430	3	(1)	Simpson HDU4-SDS2.5	-	-	wood screws 20 (d= 0.32 in) at 16 in. o/c; 46 fasteners in 2 rows.	
SW_E3B	Wood structural panels - sheathing	3/8	NO	1-3/8	8d 6	560	-	-	-	-	-	16d (d= 0.268 in) nails at 12 in. o/c; 30 fasteners in 1 row.	
SW_E3C	Wood structural panels - sheathing	19/32	YES	1-1/2	10d 4	1430	6	(2)	Simpson HDU11-SDS2.5	-	-	SDWS log screw (d= 0.197 in) at 15 in. o/c; 32 fasteners in 2 rows.	
SW_E2A	Wood structural panels - sheathing	19/32	YES	1-1/2	10d 3	1860	7	(3)	Simpson HDU11-SDS2.5	-	-	SDWS log screw (d= 0.197 in) at 11 in. o/c; 64 fasteners in 2 rows.	
SW_E2B	Wood structural panels - sheathing	3/8	NO	1-3/8	8d 6	560	1	(1)	Simpson HDU4-SDS2.5	-	-	16d (d= 0.268 in) nails at 14 in. o/c; 51 fasteners in 2 rows.	
SW_E2C	Wood structural panels - sheathing	19/32	YES	1-1/2	10d 2	2435	11	(4)	Simpson HD19	-	-	SDWS log screw (d= 0.197 in) at 9 in. o/c; 54 fasteners in 2 rows.	
SW_E1A	Wood structural panels - sheathing	19/32	YES	1-1/2	10d 2	2435	13	(4)	Simpson HD19	7	36	SDWS log screw (d= 0.197 in) at 7 in. o/c; 64 fasteners in 2 rows.	
SW_E1B	Wood structural panels - sheathing	3/8	NO	1-3/8	8d 6	560	-	-	-	-	11	16d (d= 0.268 in) nails at 32 in. o/c; 12 fasteners in 1 row.	
SW_E1C	Wood structural panels - sheathing	19/32	YES	1-1/2	10d 2	2435	9	(3)	Simpson HD19	11	36	SDWS log screw (d= 0.197 in) at 10 in. o/c; 72 fasteners in 2 rows.	
SW_W3A	Wood structural panels - sheathing	19/32	YES	1-1/2	10d 4	1430	3	(1)	Simpson HDU4-SDS2.5	-	-	wood screws 20 (d= 0.32 in) at 16 in. o/c; 46 fasteners in 2 rows.	
SW_W3B	Wood structural panels - sheathing	3/8	NO	1-3/8	8d 6	560	-	-	-	-	-	16d (d= 0.268 in) nails at 12 in. o/c; 30 fasteners in 1 row.	
SW_W3C	Wood structural panels - sheathing	19/32	YES	1-1/2	10d 4	1430	6	(2)	Simpson HDU11-SDS2.5	-	-	SDWS log screw (d= 0.197 in) at 15 in. o/c; 32 fasteners in 2 rows.	
SW_W2A	Wood structural panels - sheathing	19/32	YES	1-1/2	10d 3	1860	7	(3)	Simpson HDU11-SDS2.5	-	-	SDWS log screw (d= 0.197 in) at 11 in. o/c; 64 fasteners in 2 rows.	
SW_W2B	Wood structural panels - sheathing	3/8	NO	1-3/8	8d 6	560	1	(1)	Simpson HDU4-SDS2.5	-	-	16d (d= 0.268 in) nails at 14 in. o/c; 51 fasteners in 2 rows.	
SW_W2C	Wood structural panels - sheathing	19/32	YES	1-1/2	10d 2	2435	11	(4)	Simpson HD19	-	-	SDWS log screw (d= 0.197 in) at 9 in. o/c; 44 fasteners in 2 rows.	
SW_W1A	Wood structural panels - sheathing	19/32	YES	1-1/2	10d 2	2435	13	(4)	Simpson HD19	9	30	SDWS log screw (d= 0.197 in) at 7 in. o/c; 64 fasteners in 2 rows.	
SW_W1B	Wood structural panels - sheathing	3/8	NO	1-3/8	8d 6	560	-	-	-	-	11	16d (d= 0.268 in) nails at 32 in. o/c; 12 fasteners in 1 row.	
SW_W1C	Wood structural panels - sheathing	19/32	YES	1-1/2	10d 2	2435	9	(3)	Simpson HD19	11	36	SDWS log screw (d= 0.197 in) at 10 in. o/c; 72 fasteners in 2 rows.	
SW_EC3A	Wood structural panels - sheathing	19/32	YES	1-1/2	10d 6	950	0	-	-	-	-	16d (d= 0.268 in) nails at 18 in. o/c; 42 fasteners in 2 rows.	
SW_EC3B	Wood structural panels - sheathing	3/8	NO	1-3/8	8d 6	560	-	-	-	-	-	16d (d= 0.268 in) nails at 60 in. o/c; 7 fasteners in 1 row.	
SW_EC3C	Wood structural panels - sheathing	19/32	YES	1-1/2	10d 6	950	3	(1)	Simpson HDU4-SDS2.5	-	-	wood screws 20 (d= 0.32 in) at 19 in. o/c; 40 fasteners in 2 rows.	
SW_EC2A	Wood structural panels - sheathing	19/32	YES	1-1/2	10d 3	1860	2	(1)	Simpson HDU4-SDS2.5	-	-	wood screws 20 (d= 0.32 in) at 21 in. o/c; 36 fasteners in 2 rows.	
SW_EC2B	Wood structural panels - sheathing	3/8	NO	1-3/8	8d 6	560	-	-	-	-	-	16d (d= 0.268 in) nails at 32 in. o/c; 12 fasteners in 1 row.	
SW_EC2C	Wood structural panels - sheathing	19/32	YES	1-1/2	10d 3	1860	6	(2)	Simpson HDU11-SDS2.5	-	-	SDWS log screw (d= 0.197 in) at 12 in. o/c; 58 fasteners in 2 rows.	
SW_EC1A	Wood structural panels - sheathing	19/32	YES	1-1/2	10d 2	2435	11	(4)	Simpson HD19	6	36	SDWS log screw (d= 0.197 in) at 9 in. o/c; 42 fasteners in 2 rows.	
SW_EC1B	Wood structural panels - sheathing	3/8	NO	1-3/8	8d 6	560	-	-	-	-	11	16d (d= 0.268 in) nails at 22 in. o/c; 17 fasteners in 1 row.	
SW_EC1C	Wood structural panels - sheathing	19/32	YES	1-1/2	10d 2	2435	11	(4)	Simpson HD19	11	36	SDWS log screw (d= 0.197 in) at 9 in. o/c; 82 fasteners in 2 rows.	
SW_WC3A	Wood structural panels - sheathing	19/32	YES	1-1/2	10								



CANNERY TRAIL RESIDENCES - 1750 N OXFORD AVE. - EAU CLAIRE, WI

ELEVATIONS - FOUNDATION

