

Date	Description
07.08.2019	Footing/Foundation Permit
08.15.2019	75% CD Set
08.21.2019	Permit

STRUCTURAL DETAILS

CANNERY TRAIL RESIDENCES - 1750 N OXFORD AVE. - EAU CLAIRE, WI

S200
10/3/2019 11:45:59 PM



CAPITAL GROUP
Developer: W Capital Group
tyler@wcapitalgroupre.com | 608.345.9848



Architect: OpeningDesign
316 W Washington Ave | Suite 675
Madison, WI 53703
ryan@openingdesign.com | 773.425.6456




General Contractor: ROYAL CONSTRUCTION
3553 Greenway Street | Eau Claire, WI 54701
jim@royalbuilt.com | 715-225-6377



Civil Engineer: CEDAR CORPORATION
404 Wilson Avenue | Menomonie, WI 54751
kevin.colm@cedarcorp.com | 715-235-9081



Structural Engineer: XC Structural Engineering
Calle Apolonia Morales, 628036 Madrid,
l.perezato@xcengineering.xyz | +34 610 56 26 37



Structural Engineer of Record: Innovation
4729 Dale-Curtin Dr. McFarland, WI 53558
khsay@innovation-built.com



Mechanical Engineer: HOVLAND'S HVAC
10954 E Melby Street | Chippewa Falls, WI 54729
jhansen@hovlands-inc.com | 715.552.5595









Electrical Engineer: PRISM DESIGN ELECTRICAL CONSULTANTS INC
E8403 State Rd 85 | Mondovi, WI 54755
bhalgren@prismdesign-electrical.com | 715.797.0602



Plumbing Engineer: TAILORED ENGINEERING
1600 Aspen Commons | Ste 210 | Middleton, WI 53562
bnovak@tailoredeng.com | 608.209.7500

Date	Description
07.08.2019	Footing/Foundation Permit
08.21.2019	Permit
09.25.2019	<Progress>




STRUCTURAL DETAILS rev01
CANNERY TRAIL RESIDENCES - 1750 N OXFORD AVE. - EAU CLAIRE, WI


S201

10/3/2019 11:45:10 PM

6 | 5 | 4 | 3 | 2 | 1




Date	Description
08.15.2019	75% CD Set
08.21.2019	Permit
09.25.2019	<Progress>




0 FRAMING PLAN - 3RD FLOOR
S212 1/8" = 1'-0"


FRAMING PLAN - 3RD FLOOR CANNERY TRAIL RESIDENCES - 1750 N OXFORD AVE. - EAU CLAIRE, WI




1 FLOOR FRAMING. INTERIOR SHEAR WALL




2 FLOOR FRAMING. INTERIOR BEARING WALL



3 FLOOR FRAMING. INTERIOR SHEAR WALL



4 FLOOR FRAMING. INTERIOR PARTITION WALL



Date	Description
08.15.2019	75% CD Set
08.21.2019	Permit
09.25.2019	<Progress>

Date	Description
08.15.2019	75% CD Set
08.21.2019	Permit
09.25.2019	<Progress>

WOOD SHEAR WALL SCHEDULE													
Shear wall	Sheathing material	Panel thickness	Bucking	Minimum distance from framing member or blocking	Fastener type and size	Panel edge fastener spacing	Notched or inset panel capacity	Hold-down anchor capacity	Hold down studs	Hold down anchor type	Bottom plate attachment (foundation)	Bottom plate attachment (floor to floor)	
ID		(in)		(in)	(in)	(in)	(in)	(in)	(in)	(in)			
SW_N3A	Wood structural panels - sheathing	3/8	YES	1-3/8	8d	4	840	2	(1)	Simpson HDU4-SDS2.5	-	-	wood screws 20 (d= 0.32 in) at 25 in. o/c; 30 fasteners in 2 rows.
SW_N3B	Wood structural panels - sheathing	3/8	NO	1-3/8	8d	6	560	-	-	-	-	-	16d (d= 0.268 in) nails at 24 in. o/c; 16 fasteners in 1 row.
SW_N3C	Wood structural panels - sheathing	3/8	NO	1-3/8	8d	6	560	-	-	-	-	-	16d (d= 0.268 in) nails at 21 in. o/c; 35 fasteners in 2 rows.
SW_N3D	Wood structural panels - sheathing	3/8	YES	1-3/8	8d	4	840	2	(1)	Simpson HDU4-SDS2.5	-	-	wood screws 20 (d= 0.32 in) at 25 in. o/c; 30 fasteners in 2 rows.
SW_N2A	Wood structural panels - sheathing	19/32	YES	1-1/2	10d	4	1430	4	(2)	Simpson HDU4-SDS2.5	-	-	wood screws 20 (d= 0.32 in) at 14 in. o/c; 52 fasteners in 2 rows.
SW_N2B	Wood structural panels - sheathing	19/32	YES	1-1/2	10d	6	950	-	-	-	-	-	16d (d= 0.268 in) nails at 13 in. o/c; 28 fasteners in 1 row.
SW_N2C	Wood structural panels - sheathing	19/32	YES	1-1/2	10d	6	950	1	(1)	Simpson HDU4-SDS2.5	-	-	16d (d= 0.268 in) nails at 12 in. o/c; 59 fasteners in 2 rows.
SW_N2D	Wood structural panels - sheathing	19/32	YES	1-1/2	10d	4	1430	4	(2)	Simpson HDU4-SDS2.5	-	-	wood screws 20 (d= 0.32 in) at 14 in. o/c; 52 fasteners in 2 rows.
SW_N1A	Wood structural panels - sheathing	19/32	YES	1-1/2	10d	3	1860	7	(3)	Simpson HDU11-SDS2.5	10	36	SDWS log screw (d= 0.197 in) at 12 in. o/c; 58 fasteners in 2 rows.
SW_N1B	Wood structural panels - sheathing	19/32	YES	1-1/2	10d	6	950	-	-	-	11	36	16d (d= 0.268 in) nails at 19 in. o/c; 39 fasteners in 2 rows.
SW_N1C	Wood structural panels - sheathing	19/32	YES	1-1/2	10d	6	950	3	(1)	Simpson HDU4-SDS2.5	11	36	wood screws 20 (d= 0.32 in) at 19 in. o/c; 40 fasteners in 2 rows.
SW_N1D	Wood structural panels - sheathing	19/32	YES	1-1/2	10d	3	1860	7	(3)	Simpson HDU11-SDS2.5	10	36	SDWS log screw (d= 0.197 in) at 12 in. o/c; 60 fasteners in 2 rows.
SW_S3A	Wood structural panels - sheathing	19/32	YES	1-1/2	10d	6	950	2	(1)	Simpson HDU4-SDS2.5	-	-	wood screws 20 (d= 0.32 in) at 21 in. o/c; 36 fasteners in 2 rows.
SW_S3B	Wood structural panels - sheathing	19/32	YES	1-1/2	10d	6	950	2	(1)	Simpson HDU4-SDS2.5	-	-	wood screws 20 (d= 0.32 in) at 21 in. o/c; 36 fasteners in 2 rows.
SW_S2A	Wood structural panels - sheathing	19/32	YES	1-1/2	10d	3	1860	6	(2)	Simpson HDU11-SDS2.5	-	-	SDWS log screw (d= 0.197 in) at 13 in. o/c; 54 fasteners in 2 rows.
SW_S2B	Wood structural panels - sheathing	19/32	YES	1-1/2	10d	3	1860	6	(2)	Simpson HDU11-SDS2.5	-	-	SDWS log screw (d= 0.197 in) at 13 in. o/c; 54 fasteners in 2 rows.
SW_S1A	Wood structural panels - sheathing	19/32	YES	1-1/2	10d	2	2435	11	(4)	Simpson HD19	10	36	SDWS log screw (d= 0.197 in) at 8 in. o/c; 76 fasteners in 2 rows.
SW_S1B	Wood structural panels - sheathing	19/32	YES	1-1/2	10d	2	2435	11	(4)	Simpson HD19	10	36	SDWS log screw (d= 0.197 in) at 8 in. o/c; 76 fasteners in 2 rows.
SW_E3A	Wood structural panels - sheathing	19/32	YES	1-1/2	10d	4	1430	3	(1)	Simpson HDU4-SDS2.5	-	-	wood screws 20 (d= 0.32 in) at 16 in. o/c; 46 fasteners in 2 rows.
SW_E3B	Wood structural panels - sheathing	3/8	NO	1-3/8	8d	6	560	-	-	-	-	-	16d (d= 0.268 in) nails at 12 in. o/c; 30 fasteners in 1 row.
SW_E3C	Wood structural panels - sheathing	19/32	YES	1-1/2	10d	4	1430	6	(2)	Simpson HDU11-SDS2.5	-	-	SDWS log screw (d= 0.197 in) at 15 in. o/c; 32 fasteners in 2 rows.
SW_E2A	Wood structural panels - sheathing	19/32	YES	1-1/2	10d	3	1860	7	(3)	Simpson HDU11-SDS2.5	-	-	SDWS log screw (d= 0.197 in) at 11 in. o/c; 64 fasteners in 2 rows.
SW_E2B	Wood structural panels - sheathing	3/8	NO	1-3/8	8d	6	560	1	(1)	Simpson HDU4-SDS2.5	-	-	16d (d= 0.268 in) nails at 14 in. o/c; 51 fasteners in 2 rows.
SW_E2C	Wood structural panels - sheathing	19/32	YES	1-1/2	10d	2	2435	11	(4)	Simpson HD19	-	-	SDWS log screw (d= 0.197 in) at 9 in. o/c; 54 fasteners in 2 rows.
SW_E1A	Wood structural panels - sheathing	19/32	YES	1-1/2	10d	2	2435	13	(4)	Simpson HD19	7	36	SDWS log screw (d= 0.197 in) at 7 in. o/c; 64 fasteners in 2 rows.
SW_E1B	Wood structural panels - sheathing	3/8	NO	1-3/8	8d	6	560	-	-	-	11	36	16d (d= 0.268 in) nails at 32 in. o/c; 12 fasteners in 1 row.
SW_E1C	Wood structural panels - sheathing	19/32	YES	1-1/2	10d	2	2435	9	(3)	Simpson HD19	11	36	SDWS log screw (d= 0.197 in) at 10 in. o/c; 72 fasteners in 2 rows.
SW_W3A	Wood structural panels - sheathing	19/32	YES	1-1/2	10d	4	1430	3	(1)	Simpson HDU4-SDS2.5	-	-	wood screws 20 (d= 0.32 in) at 16 in. o/c; 46 fasteners in 2 rows.
SW_W3B	Wood structural panels - sheathing	3/8	NO	1-3/8	8d	6	560	-	-	-	-	-	16d (d= 0.268 in) nails at 12 in. o/c; 30 fasteners in 1 row.
SW_W3C	Wood structural panels - sheathing	19/32	YES	1-1/2	10d	4	1430	6	(2)	Simpson HDU11-SDS2.5	-	-	SDWS log screw (d= 0.197 in) at 15 in. o/c; 32 fasteners in 2 rows.
SW_W2A	Wood structural panels - sheathing	19/32	YES	1-1/2	10d	3	1860	7	(3)	Simpson HDU11-SDS2.5	-	-	SDWS log screw (d= 0.197 in) at 11 in. o/c; 64 fasteners in 2 rows.
SW_W2B	Wood structural panels - sheathing	3/8	NO	1-3/8	8d	6	560	1	(1)	Simpson HDU4-SDS2.5	-	-	16d (d= 0.268 in) nails at 14 in. o/c; 51 fasteners in 2 rows.
SW_W2C	Wood structural panels - sheathing	19/32	YES	1-1/2	10d	2	2435	11	(4)	Simpson HD19	-	-	SDWS log screw (d= 0.197 in) at 9 in. o/c; 44 fasteners in 2 rows.
SW_W1A	Wood structural panels - sheathing	19/32	YES	1-1/2	10d	2	2435	13	(4)	Simpson HD19	9	30	SDWS log screw (d= 0.197 in) at 7 in. o/c; 64 fasteners in 2 rows.
SW_W1B	Wood structural panels - sheathing	3/8	NO	1-3/8	8d	6	560	-	-	-	11	36	16d (d= 0.268 in) nails at 32 in. o/c; 12 fasteners in 1 row.
SW_W1C	Wood structural panels - sheathing	19/32	YES	1-1/2	10d	2	2435	9	(3)	Simpson HD19	11	36	SDWS log screw (d= 0.197 in) at 10 in. o/c; 72 fasteners in 2 rows.
SW_EC3A	Wood structural panels - sheathing	19/32	YES	1-1/2	10d	6	950	0	-	-	-	-	16d (d= 0.268 in) nails at 18 in. o/c; 42 fasteners in 2 rows.
SW_EC3B	Wood structural panels - sheathing	3/8	NO	1-3/8	8d	6	560	-	-	-	-	-	16d (d= 0.268 in) nails at 60 in. o/c; 7 fasteners in 1 row.
SW_EC3C	Wood structural panels - sheathing	19/32	YES	1-1/2	10d	6	950	3	(1)	Simpson HDU4-SDS2.5	-	-	wood screws 20 (d= 0.32 in) at 19 in. o/c; 40 fasteners in 2 rows.
SW_EC2A	Wood structural panels - sheathing	19/32	YES	1-1/2	10d	3	1860	2	(1)	Simpson HDU4-SDS2.5	-	-	wood screws 20 (d= 0.32 in) at 21 in. o/c; 36 fasteners in 2 rows.
SW_EC2B	Wood structural panels - sheathing	3/8	NO	1-3/8	8d	6	560	-	-	-	-	-	16d (d= 0.268 in) nails at 32 in. o/c; 12 fasteners in 1 row.
SW_EC2C	Wood structural panels - sheathing	19/32	YES	1-1/2	10d	3	1860	6	(2)	Simpson HDU11-SDS2.5	-	-	SDWS log screw (d= 0.197 in) at 12 in. o/c; 58 fasteners in 2 rows.
SW_EC1A	Wood structural panels - sheathing	19/32	YES	1-1/2	10d	2	2435	11	(4)	Simpson HD19	6	36	SDWS log screw (d= 0.197 in) at 9 in. o/c; 42 fasteners in 2 rows.
SW_EC1B	Wood structural panels - sheathing	3/8	NO	1-3/8	8d	6	560	-	-	-	11	36	16d (d= 0.268 in) nails at 22 in. o/c; 17 fasteners in 1 row.
SW_EC1C	Wood structural panels - sheathing	19/32	YES	1-1/2	10d	2	2435	11	(4)	Simpson HD19	11	36	SDWS log screw (d= 0.197 in) at 9 in. o/c; 82 fasteners in 2 rows.</



CAPITAL GROUP
Developer: W Capital Group
tyler@wcapitalgroupre.com | 608.345.9848



Architect: OpeningDesign
316 W Washington Ave | Suite 675
Madison, WI 53703
ryan@openingdesign.com | 773.425.6456



General Contractor: ROYAL CONSTRUCTION
3453 Greenway Street | Eau Claire, WI 54701
jim@royalbuilt.com | 715-225-6377



Civil Engineer: CEDAR CORPORATION
404 Wilson Avenue | Menomonie, WI 54751
kevin.colm@cedarcorp.com | 715-235-9081



Structural Engineer: XC Structural Engineering
Calle Apolonia Morales, 628036 Madrid,
l.perezato@xcengineering.xyz | +34 610 56 26 37



Structural Engineer of Record: Innovation
4729 Dale-Curtain Dr. McFarland, WI 53558
khsay@innovation-built.com




Mechanical Engineer: HOVLAND'S HVAC
10954 E Melby Street | Chippewa Falls, WI 54755
jhansen@hovlands-inc.com | 715.552.5595




Electrical Engineer: PRISM DESIGN ELECTRICAL CONSULTANTS INC
88403 State Rd 85 | Mondovi, WI 54755
bhalgren@prismdesign-electrical.com | 715.797.0602



Plumbing Engineer: TAILORED ENGINEERING
1600 Aspen Commons | Ste 210 | Middleton, WI 53562
bnovak@tailoredeng.com | 608.209.7500





CANNERY TRAIL RESIDENCES - 1750 N OXFORD AVE. - EAU CLAIRE, WI

yler@wcapitalgroupre.com | 608.345.9848

1

10



Architect: OpeningDesign
316 W Washington Ave | Suite 675
Madison, WI 53703
yan@openingdesign.com | 773.425.6456

The logo consists of a stylized red 'X' and 'C' intertwined, forming a single graphic element.

The logo for Prism Design Electrical Consultants Inc. features a large, stylized, light-colored cloud shape on the left side of the page. Inside the cloud, the word "PRISM" is written in a bold, serif font, and below it, "DESIGN" is written in a slightly smaller, bold, serif font. To the right of the cloud is a dark, three-dimensional pyramid. The background of the slide has a subtle, radiating grid pattern.


The logo for Tailored Engineering features a blue circular icon containing a stylized 'T' and 'E'. To the right of the icon, the word 'TAILORED' is written in large, bold, blue capital letters, and 'ENGINEERING' is written below it in a slightly smaller, bold, blue capital letters.

Plumbing Engineer: TAILORED ENGINEERING
10 Aspen Commons | Ste 210 | Middleton, WI
53562
bnovak@tailoredeng.com | 608.209.7500



2 FOUNDATION - 3D - VIEW 1

S400



3 FOUNDATION - 3D - VIEW 2
S400

CANNERY TRAIL RESIDENCES - 1750 N OXFORD AVE. - EAU CLAIRE, WI

ENLARGED PLANS