

Date	Description
07.08.2019	Footing/Foundation Permit
08.21.2019	Permit

# STRUCTURAL NOTES

## CANNERY TRAIL RESIDENCES - 1750 N OXFORD AVE. - EAU CLAIRE, WI

5000  
10/7/2019 10:22:19 PM

### DESIGN DATA

APPLICABLE CODES/STANDARDS:  
....INTERNATIONAL BUILDING CODE - 2018  
....ASCE 7-16 MIN DESIGN LOADS FOR BUILDINGS AND OTHER STRUCTURES, ASCE/SEI

STRUCTURAL DESIGN STANDARDS (DESIGN SHALL CONFORM TO THE CURRENT EDITION UNDER THE APPLICABLE CODE):  
....ACI 318 BUILDING CODE REQUIREMENTS FOR STRUCTURAL CONCRETE AND COMMENTARY  
....ACI 530/531 BLDG CODE REQUIREMENTS AND SPECS FOR MASONRY STRUCTURES (AND RELATED COMMENTARIES)  
....ANSI/AISC 360-16 SPECIFICATIONS FOR STRUCTURAL STEEL BUILDINGS  
....AWS D1.1/D1.1M STRUCTURAL WELDING CODE-STEEL

DEFLECTION LIMITS			
MEMBERS	LIVE	SNOW or WIND	DEAD + LIVE or SNOW
ROOF MEMBERS			
SUPPORTING GYPSUM BOARD CEILINGS	L/360	L/360	L/240
SUPPORTING FLEXIBLE CEILINGS	L/360	L/360	L/240
NOT SUPPORTING CEILING	L/240	L/240	L/180
SUPPORTING RIGID MATERIALS (BRICK, MASONRY, ETC.)	L/600	L/600	L/600
FLOOR MEMBERS			
SUPPORTING RIGID MATERIALS (BRICK, MASONRY, ETC.)	L/600	L/600	L/600
SUPPORTING GYPSUM BOARD CEILINGS	L/540	N/A	L/360
SUPPORTING FLEXIBLE MATERIALS	L/540	N/A	L/260
WOOD TRUSSES	L/480	L/360	L/240
LINTEL/HEADER/BEAM MEMBERS			
SUPPORTING RIGID MATERIALS (BRICK, MASONRY, ETC.)	L/600	L/600	L/600
SUPPORTING FLEXIBLE MATERIALS (EIFS, SIDING, ETC.)	L/360	L/360	L/240
EXTERIOR WALLS			
WITH RIGID FINISHES (BRICK, MASONRY, ETC.)	N/A	L/600	N/A
WITH FLEXIBLE FINISHES (EIFS, SIDING, ETC.)	N/A	L/360	N/A

### BUILDING DESIGN LOADS/CRITERIA

DESIGN LIVE LOADS:  
....FLOOR FRAMING (RETAIL, OFFICE, RESTAURANT, RECREATIONAL) 100 psf

....FLOOR FRAMING (RESIDENTIAL AREAS) 40 psf  
....STAIRWAYS, EXITS 100 psf  
....BALCONIES 75 psf  
....PRIVATE GARAGES (PASSENGER VEHICLES ONLY) 40 psf  
....INTERIOR PARTITION WALLS (UNIFORMLY DISTRIBUTED WEIGHT) 15 psf  
....CORRIDORS FIRST FLOOR 100 psf  
....CORRIDORS 2nd 3rd FLOORS 40 psf  
....CORNICES 60 psf

SNOW LOADS & DESIGN DATA:  
....DESIGN SNOW LOAD 42 psf (BALANCED SNOW LOAD)  
....FLAT ROOF SNOW LOAD (P) =  $(0.7 \cdot C_e \cdot C_l \cdot s \cdot P_g)$  42 psf  
....SNOW EXPOSURE FACTOR (Ce) 1.0  
....SNOW LOAD IMPORTANCE FACTOR (Is) 1.0  
....ROOF THERMAL FACTOR (Ci) 1.0  
....GROUND SNOW (Pg) 60 psf  
....SLOPED ROOF FACTOR (Cs) 1.0

WIND DESIGN DATA:  
....WIND IMPORTANCE FACTOR (Iw) 1.0  
....RISK CATEGORY II  
....BASIC WIND SPEED (5-SECOND GUST, ULTIMATE) 115 MPH  
....BASIC WIND SPEED (5-SECOND GUST, NOMINAL) 90 MPH  
....MEAN ROOF HEIGHT 33 FT  
....WIND EXPOSURE CATEGORY B  
....WIND EXPOSURE CLASSIFICATION ENCLOSED  
....VELOCITY EXPOSURE COEFFICIENT Kz 0.720  
....TOPOGRAPHIC FACTOR (Kt) 1.0  
....DESIGN PROCEDURE METHOD 1 (SIMPLIFIED PROCEDURE)

NET PRESSURE COEFFICIENTS $C_{net}$		
AREA	$C_{net}$ INTERNAL PRESSURE	$C_{net}$ INTERNAL PRESSURE
WINDWARD WALL	0.43	0.73
LEEWARD WALL	-0.51	-0.21
SIDEWALL	-0.66	-0.35
PARAPET WINDWARD WALL	1.28	
PARAPET LEEWARD WALL	-0.85	
FLAT ROOF	-1.09	-0.79

DESIGN WIND PRESSURES $P_{net}$		
AREA	$P_{net}$ INTERNAL PRESSURE	$P_{net}$ INTERNAL PRESSURE
WINDWARD WALL	10.5 psf	17.8 psf
LEEWARD WALL	-12.4 psf	-5.1 psf
SIDEWALL	-16.1 psf	-8.5 psf
PARAPET WINDWARD WALL	31.2 psf	
PARAPET LEEWARD WALL	-20.7 psf	
FLAT ROOF	-26.6 psf	-19.3 psf

EARTHQUAKE DESIGN DATA:  
....OCCUPANCY CATEGORY II  
....SEISMIC IMPORTANCE FACTOR (Ie) 1  
....MAPPED SPECTRAL ACCELERATIONS AT SHORT PERIODS (Ss) 0.045 g  
....MAPPED SPECTRAL ACCELERATIONS AT (1) SECOND PERIODS (S1) 0.038 g  
....SITE CLASSIFICATION B  
....SITE COEFFICIENT (Ps) 1.0  
....DESIGN SPECTRAL RESPONSE COEFFICIENT AT SHORT PERIODS (Sds) 0.030 g  
....DESIGN SPECTRAL RESPONSE COEFFICIENT AT (1) SECOND PERIODS (Sd1) 0.025 g  
....SEISMIC DESIGN CATEGORY A  
....BASIC SEISMIC-FORCE-RESISTING SYSTEM LIGHT FRAME WOOD WALLS WITH STRUCTURAL WOOD SHEAR PANELS EQUIVALENT LATERAL FORCE ANALYSIS  
....ANALYSIS PROCEDURE FOR SEISMIC DESIGN

SOIL DESIGN VALUES:  
....SOIL UNIT WEIGHT 125 PCF (ASSUMED)  
....LATERAL EARTH PRESSURE  
....AT-REST (BASEMENT WALLS) 62.5 PSF/FT OF DEPTH (ASSUMED)  
....PASSIVE 340 PSF (ASSUMED)  
....COEFFICIENT OF SLIDING FRICTION 0.30 (ASSUMED)  
....SUBGRADE MODULUS 260 PCI (ASSUMED)  
....ALLOWABLE SOIL BEARING PRESSURE 3000 PSF

REFER TO SOILS REPORT NO. 17002 DATED 2/10/2017 PREPARED BY ITCO ALLIED ENGINEERING CO. FOR DESCRIPTION OF SOIL CONDITIONS, GEOTECHNICAL RECOMMENDATIONS, AND DESIGN VALUES

### FOUNDATION AND EARTHWORK

- ALL EXTERIOR FOOTINGS MUST BEAR BELOW LOCAL FROST LINE RELATIVE TO ADJACENT FINISH EXTERIOR GRADE.
- DO NOT PLACE ANY FOOTINGS ON FROZEN SUBGRADE.
- BACK FILLING SHALL BE DONE SIMULTANEOUSLY ON BOTH SIDES OF FOUNDATION WALLS.
- DO NOT PLACE BACK FILL AGAINST BASEMENT WALLS UNTIL THE TOP AND BOTTOM OF THE WALL ARE ADEQUATELY BRACED BY THE SLAB ON GRADE AND THE FLOOR FRAMING AT THE TOP OF THE WALL.
- REMOVE ANY EXISTING CONCRETE 2'-0" BELOW NEW CONCRETE FOOTINGS AND SLABS ON GRADE, UNLESS NOTED OTHERWISE.
- SHORING/OR UNDERPINNING SHALL BE DESIGNED TO LIMIT HORIZONTAL AND VERTICAL MOVEMENT OF EXISTING CONSTRUCTION TO 1/4" MAXIMUM IN ANY DIRECTION.
- CENTER PIER AND COLUMN FOOTINGS ON COLUMN CENTERLINES AND WALL FOOTINGS ON WALL CENTERLINES UNLESS SPECIFICALLY NOTED OTHERWISE.
- ALL BACK FILL WITHIN 3'-0" OF RETAINING WALLS AND BASEMENT WALLS SHALL BE FREE DRAINING GRANULAR MATERIAL APPROVED BY A SOILS ENGINEER AND COMPAKTED TO 90% STANDARD PROCTOR.
- TOP OF FOOTING ELEVATIONS SHOWN ON THESE CONSTRUCTION DOCUMENTS REPRESENT MINIMUM FOOTING DEPTHS FOR FROST PROTECTION AND BEST JUDGMENT OF A SUITABLE BEARING STRATUM. ACTUAL GRADE CONDITIONS AND SUITABLE BEARING STRATUM MUST BE VERIFIED BY THE CONTRACTOR AND A SOILS ENGINEER AT THE TIME OF EXCAVATION.

10. FOOTING EXCAVATIONS MUST EXTEND TO COMPETENT BEARING MATERIAL. CONTRACTOR SHALL HIRE A SOILS ENGINEER TO FIELD VERIFY NET ALLOWABLE SOIL BEARING CAPACITY STATED ON THESE CONSTRUCTION DOCUMENTS AND IN GEOTECHNICAL REPORT FOR THIS PROJECT. THE SUITABLE BEARING STRATUM DOES NOT EXIST AT FOOTING ELEVATION STATED ON CONSTRUCTION DOCUMENTS. EXCAVATION SHOULD BE EXTENDED UNTIL SOIL WITH APPROPRIATE BEARING CAPACITY IS REACHED. PLACE GRANULAR MATERIAL ON TOP OF FOOTINGS OR EXTEND FOOTINGS DOWN TO SUITABLE BEARING STRATUM. ENGINEERED FILL BELOW SLABS ON GRADE AND FOOTINGS SHALL BE FREE DRAINING GRANULAR MATERIAL COMPAKTED TO 95% MODIFIED PROCTOR AND PLACED PER THE SOIL ENGINEERS RECOMMENDATIONS. ALL FIELD CONDITIONS THAT WILL AFFECT DESIGN AS PRESENTED MUST BE COORDINATED WITH STRUCTURAL ENGINEER.

11. REFER TO DESIGN DATA FOR DESCRIPTION OF SOIL CONDITIONS, GEOTECHNICAL RECOMMENDATIONS, AND DESIGN VALUES.

### CONTINUITY:

ALL REINFORCING SHALL BE CONTINUOUS UNLESS NOTED OTHERWISE. CONTINUITY AT CORNERS AND INTERSECTIONS SHALL BE ACHIEVED USING CORNER BARS AND CONTACT LAP SPLICES. SEE TYPICAL DETAIL. CONTINUITY AT OTHER LOCATIONS MAY BE ACHIEVED USING CONTACT LAP SPLICES SHOWN ON APPROVED SHOP DRAWINGS. LOCATION OF LAP SPLICES SHALL BE SHOWN ON THE SHOP DRAWINGS. UNLESS NOTED OTHERWISE, THE FOLLOWING LAP SPLICES SHALL BE USED: (ALL LAP SPLICES ARE CLASS B 3 SPLICES)

LOCATION:	#3	#4	#5	#6	#7	#8	#9	#10	#11
3,000 & 3,500 PSI CONCRETE:									
- TOP BARS (*)	21"	19"	35"	46"	71"	93"	118"	149"	184"
- OTHER BARS:	16"	22"	27"	35"	55"	71"	91"	115"	142"
4,000 & 4,500 PSI CONCRETE:									
- TOP BARS (*)	16"	19"	25"	36"	61"	80"	102"	129"	159"
- OTHER BARS:	16"	16"	19"	28"	47"	62"	78"	99"	123"

(\* TOP BARS ARE HORIZONTAL REINFORCING WHERE MORE THAN 12" OF CONCRETE IS CAST IN THE MEMBER BELOW THE REINFORCING.

(\*\*) FOR 44 EPOXY COATED REBAR, USE 27" SPLICE LENGTH AT 3,000 AND 3,500 PSI CONC. AND 19" AT 4,000 AND 4,500 PSI.


MECHANICAL CONNECTIONS MAY BE USED IN LIEU OF LAP SPLICES PROVIDED APPROVAL IS OBTAINED FROM THE ARCHITECT/ENGINEER. CONNECTIONS SHALL DEVELOP IN TENSION 125 PERCENT OF THE SPECIFIED YIELD STRENGTH OF THE REINFORCING. MECHANICAL SPLICES SHALL BE SHOWN ON THE SHOP DRAWINGS AND BE INSTALLED IN ACCORDANCE WITH THE MANUFACTURER'S WRITTEN INSTRUCTIONS AND THE PRODUCT'S ICC-ES REPORT. SUBMIT THE PRODUCT'S ICC-ES REPORT FOR MECHANICAL SPLICE PRODUCTS WITH SHOP DRAWINGS.

### STEEL/METAL:

REINFORCING STEEL:  
....ALL ASTM A615, GRADE 60, DEFORMED Fy = 60,000 PSI  
....STEEL WELDED WIRE REINFORCEMENT, FLAT SHEETS Fy = 60,000 PSI

### STRUCTURAL STEEL:

....ROLLED WIDE FLANGE SHAPES, ASTM A992 GRADE 50 Fy = 50,000 PSI  
....CHANNELS, ANGLES, AND S SHAPES, ASTM A36 Fy = 36,000 PSI  
....PLATE AND BAR, ASTM A36 Fy = 36,000 PSI  
....TUBE SHAPES, ASTM A505 GRADE B Fy = 46,000 PSI  
....PIPE ASTM A53, TYPE E or S, GRADE B Fy = 46,000 PSI  
....ALL OTHER ROLLED SHAPES, ASTM A36 Fy = 36,000 PSI



# CANNERY TRAIL RESIDENCES - 1750 N OXFORD AVE. - EAU CLAIRE, WI

FOR EXTERIOR  
CONCRETE STAIR --  
SEE CIVIL FOR  
ELEVATION

## MASONRY WALL REINFORCING SCHEDULE

MARK	WALL THICKNESS	VERTICAL REINFORCEMENT & SPACING	REINFORCEMENT LOCATION IN CELL
MW.1	8"	#5 AT 48" o/c MAX	CENTER
MW.2	8"	#6 AT 16" o/c MAX	INSIDE FACE

MASONRY WALL REINFORCEMENT SCHEDULE NOTES:

1. GROUT CONCRETE MANSORY UNITS SOLID FULL HEIGHT OF BUILDING AT REINFORCEMENT LOCATIONS.
2. UNLESS NOTED OTHERWISE, PROVIDE DOWELS INTO FOOTING TO MATCH VERTICAL REINFORCEMENT.
3. PROVIDE CONCRETE MANSORY UNIT WALL REINFORCING ABOVE AND BELOW ALL MANSORY OPENINGS. EXTEND THE LENGTH OF THE REBARS BY 23" OR 40 BAR DIAMETERS PAST THE EDGE OF THE OPENING.
4. REFER TO STRUCTURAL NOTES SHEET FOR LAPS IN STEEL REINFORCEMENT.
5. PROVIDE STANDARD (W1.7) HORIZONTAL JOINT REINFORCING AT 16" ON CENTER VERTICALLY (8" ON CENTER IN PARAPET WALLS) UNO. REINFORCING TO BE HOT-DIPPED GALVANIZED IN EXTERIOR WALLS AND MILL-GALVANIZED FOR INTERIOR WALLS.
6. MANSORY FIREWALL CONSTRUCTION ASSUMES MASONRY BLOCKS COMPRISED OF LIMESTONE.

## MASONRY WALL FOOTING SCHEDULE

<b>MARK</b>	<b>WIDTH</b>	<b>THICKNESS</b>	<b>LONGITUDINAL</b>
MWF.1	2' - 0"	1' - 0"	(2)#5
MWF.2	3' - 0"	1' - 2"	(3)#5

MASONRY WALL FOOTING SCHEDULE:  
1. REFER TO STRUCTURAL NOTES SHEET FOR LAPS IN STEEL REINFORCEMENT.  
2. REFER TO FUNDATION PLAN FOR TOP OF FOOTING ELEVATIONS.  
3. ALL FOOTING EXCAVATIONS SHALL BE INSPECTED AND APPROVED BY THE GEOTECHNICAL ENGINEER PRIOR TO PLACING CONCRETE

## **THICKENED SLAB SCHEDULE**

MARK	DIMENSIONS		REINFORCEMENT	REMARKS
	WIDTH (xCONT)	THICKNESS		
TS20	2' - 0"	1' - 0"	(2) #5	THICKENED SLAB, REFER TO 11/

**THICKENED SLAB SCHEDULE NOTES:**

1. REFER TO STRUCTURAL NOTES SHEET FOR LAPS IN STEEL REINFORCEMENT.
2. REFER TO FOUNDATION PLAN FOR TOP OF FOOTING ELEVATIONS.
3. ALL FOOTING EXCAVATIONS SHALL BE INSPECTED AND APPROVED BY THE GEOTECHNICAL ENGINEER PRIOR TO PLACING CONCRETE

## **WALL FOOTING SCHEDULE**

<b>DIMENSIONS</b>	<b>REINFORCEMENT</b>
-------------------	----------------------

MARK	DIMENSIONS		REINFORCEMENT	
	WIDTH	THICKNESS	LONGITUDINAL	TRANSVERSE
WF26	2' - 6"	1' - 2"	(3)-#5	#5's AT 12" BOTTOM FACE
WF30	3' - 0"	1' - 2"	(3)-#5	#5's AT 12" BOTTOM FACE

COLUMN FOOTING SCHEDULE NOTES:

1. REFER TO STRUCTURAL NOTES SHEET FOR MINIMUM COVER REQUIREMENTS.
2. REFER TO FOUNDATION PLAN FOR TOP OF FOOTING ELEVATIONS.
3. ALL FOOTING EXCAVATIONS SHALL BE INSPECTED AND APPROVED BY THE GEOTECHNICAL ENGINEER PRIOR TO PLACING CONCRETE
4. ALL LAPS IN STEEL REINFORCING SHALL BE CLASS "B" LAP SPLICES UNLESS NOTED OTHERWISE.


COLUMN FOOTING SCHEDULE

FT70	FT70 - 7-0x7-0x1-8	1	-14' - 0"	7' - 0"	7' - 0"	1' - 8"	81.67 CF	(10)-#7	(10)-#7	
FT70	FT70 - 0-0-0-0x2-1	7	-14' - 0"	0' - 0"	0' - 0"	0' - 1"	168.75 CF	(10)-#8	(10)-#8	

## **CONCRETE WALL REINFORCING SCHEDULE**


CONCRETE WALL REINFORCING SCHEDULE					
MARK	TYPE	THICKNESS	REINFORCEMENT		REMARKS
			VERTICAL	HORIZONTAL	
W1	CONCRETE	14"	5#'s AT 18"o.c.	5#'s AT 12"o.c.	inside face
W2	CONCRETE	10"	5#'s AT 12"o.c.	5#'s AT 12"o.c.	inside face
W3	CONCRETE	10"	6#'s AT 12"o.c.	5#'s AT 12"o.c.	inside face
W4	CONCRETE	8"	4#'s AT 12"o.c.	3#'s AT 12"o.c.	centered in wall thickness

W5	CONCRETE	8"	4#'s AT 12"o.c.	3#'s AT 12"o.c.	inside
CONCRETE WALL REINFORCING SCHEDULE NOTES:					
1. REFER TO STRUCTURAL NOTES SHEET FOR LAPS IN STEEL REINFORCEMENT.					



Date	Description
07.08.2019	Footing/Foundation Permit
08.15.2019	75% CD Set
08.21.2019	Permit
09.05.2019	Permit

# S100



**CAPITAL GROUP**  
Developer: W Capital Group  
tyler@wcapitalgroup.com | 608.345.9848

**OpeningDesign**  
Architect: OpeningDesign  
316 W Washington Ave | Suite 675  
Madison, WI 53703  
ryan@openingdesign.com | 773.425.6457

**ROYAL CONSTRUCTION**  
General Contractor: ROYAL CONSTRUCTION  
3453 Greenway Street | Eau Claire, WI 54701  
jim@royalbuilt.com | 715-225-6377

**Cedar Corporation**  
Civil Engineer: CEDAR CORPORATION  
404 Wilson Avenue | Menomonie, WI 54751  
kevin.colm@cedarcorp.com | 715-235-9081

**XC Structural Engineering**  
Colle Apolonia Morales, 628036 Madrid,  
l.perezato@xcengineering.xyz | +34 610 56 26 37

**Ennovation**  
Engineering Services Incorporated  
4727 Dale-Curtin Dr. McFarland, WI 53558  
khsley@ennovation-built.com











**Hovland's**  
Heating • Ventilation • Air Conditioning  
Mechanical Engineer: HOVLAND'S HVAC  
10954 E. Melby Street | Chippewa Falls, WI 54729  
jansen@hovlands-inc.com | 715.552.5595

**PRISM DESIGN**  
ELECTRICAL CONSULTANTS INC.  
Electrical Engineer: PRISM DESIGN ELECTRICAL CONSULTANTS INC  
EB403 State Rd 85 | Mondovi, WI 54755  
bholgren@prismdesign-electrical.com | 715.797.0602


**TAILORED ENGINEERING**  
Plumbing Engineer: TAILORED ENGINEERING  
1600 Aspen Commons | Ste 210 | Middleton, WI 53562  
bnovak@tailoredeng.com | 608.209.7500


Date	Description
07.08.2019	Footing/Foundation Permit
08.15.2019	75% CD Set
08.21.2019	Permit


Date	Description
07.08.2019	Footing/Foundation Permit
08.21.2019	Permit
09.25.2019	<Progress>



Date	Description
07.08.2019	Footing/Foundation Permit
08.21.2019	Permit
09.25.2019	<Progress>







# CANNERY TRAIL RESIDENCES - 1750 N OXFORD AVE. - EAU CLAIRE, WI

6

5

4

3

2

1

E



Developer: W Capital Group  
tyler@wcapitalgroupre.com | 608.345.9848



Architect: OpeningDesign  
316 W Washington Ave | Suite 675  
Madison, WI 53703  
ryan@openingdesign.com | 773.425.6456



General Contractor: ROYAL CONSTRUCTION  
3453 Greenway Street | Eau Claire, WI 54701  
jim@royalbuilt.com | 715-225-6377



Civil Engineer: CEDAR CORPORATION  
404 Wilson Avenue | Menomonie, WI 54751  
kevin.colm@cedarcorp.com | 715-235-9081



Structural Engineer: XC Structural Engineering  
Colle Apolonia Morales, 628036 Madrid,  
l.perezato@xcengineering.xyz | +34 610 56 26 37



Structural Engineer of Record: Ennovation  
4727 Dale-Curtin Dr. McFarland, WI 53558  
khsley@innovation-built.com



Mechanical Engineer: HOVLAND'S HVAC  
10954 E. Melby Street | Chippewa Falls, WI 54729  
jansen@hovlands-inc.com | 715.552.5595




Electrical Engineer: PRISM DESIGN ELECTRICAL CONSULTANTS INC  
EB403 State Rd 85 | Mondovi, WI 54755  
bhalgren@prismdesign-electrical.com | 715.797.0602




Plumbing Engineer: TAILORED ENGINEERING  
1600 Aspen Commons | Ste 210 | Middleton, WI 53562  
bnovak@tailoredeng.com | 608.209.7500


6 FLOOR FRAMING AT SECOND FLOOR, EXTERIOR BEARING WALL




7 CANTILEVER SECTION




8 CANTILEVER, LATERAL VIEW




9 FLOOR FRAMING AT LOBBY, COURTYARD STEEL BEAM



C15x40 DETAIL




10 FLOOR FRAMING AT LOBBY, CORRIDOR STEEL BEAM




11 FLOOR FRAMING AT LOBBY, INTERIOR BEARING WALL

12 METAL BALCONY BASE CONNECTION 2nd FLOOR


Date	Description
08.15.2019	75% CD Set
08.21.2019	Permit
09.25.2019	<Progress>




5 FLOOR FRAMING AT CORRIDOR. INTERIOR BEARING WALL



8 FLOOR FRAMING AT CORRIDOR. PLATFORM FRAMING AT INTERIOR BEARING WALL




11 FLOOR FRAMING AT CORRIDOR. PLATFORM FRAMING AT EXTERIOR BEARING WALL




6 S215 FLOOR FRAMING AT EXTERIOR WALL BEARING ON HEADER

6 S215 FLOOR FRAMING AT EXTERIOR WALL BEARING ON HEADER

9 S215 FLOOR FRAMING PARALLEL TO EXTERIOR WALL





12 S215 METAL BALCONY BASE CONNECTION AND HANGER ROD CONNECTION. 3rd FLOOR



7 S215 FLOOR FRAMING AT EXTERIOR BEARING WALL

10 S215 FLOOR FRAMING AT CORRIDOR. INTERIOR HEADER



Date	Description
08.15.2019	75% CD Set
08.21.2019	Permit
09.25.2019	<Progress>

WOOD SHEAR WALL SCHEDULE													
Shear wall	Sheathing material	Panel thickness	Bucking	Minimum distance from framing member or blocking	Fastener type and size	Panel edge fastener spacing	Notched or inset panel capacity	Hold-down anchor capacity	Hold down studs	Hold down anchor type	Bottom plate attachment (foundation)	Bottom plate attachment (floor to floor)	
ID		(in)	(in)	(in)	(in)	(in)	(in)	(in)	(in)	(in)	(in)	(in)	(in)
SW_N3A	Wood structural panels - sheathing	3/8	YES	1-3/8	8d 4	840	2 (1)	Simpson HDU4-SDS2.5	-	-	wood screws 20 (d= 0.32 in) at 25 in. o/c; 30 fasteners in 2 rows.		
SW_N3B	Wood structural panels - sheathing	3/8	NO	1-3/8	8d 6	560	-	-	-	-	16d (d= 0.268 in) nails at 24 in. o/c; 16 fasteners in 1 row.		
SW_N3C	Wood structural panels - sheathing	3/8	NO	1-3/8	8d 6	560	-	-	-	-	16d (d= 0.268 in) nails at 21 in. o/c; 35 fasteners in 2 rows.		
SW_N3D	Wood structural panels - sheathing	3/8	YES	1-3/8	8d 4	840	2 (1)	Simpson HDU4-SDS2.5	-	-	wood screws 20 (d= 0.32 in) at 25 in. o/c; 30 fasteners in 2 rows.		
SW_N2A	Wood structural panels - sheathing	19/32	YES	1-1/2	10d 4	1430	4 (2)	Simpson HDU4-SDS2.5	-	-	wood screws 20 (d= 0.32 in) at 14 in. o/c; 52 fasteners in 2 rows.		
SW_N2B	Wood structural panels - sheathing	19/32	YES	1-1/2	10d 6	950	-	-	-	-	16d (d= 0.268 in) nails at 13 in. o/c; 28 fasteners in 1 row.		
SW_N2C	Wood structural panels - sheathing	19/32	YES	1-1/2	10d 6	950	1 (1)	Simpson HDU4-SDS2.5	-	-	16d (d= 0.268 in) nails at 12 in. o/c; 59 fasteners in 2 rows.		
SW_N2D	Wood structural panels - sheathing	19/32	YES	1-1/2	10d 4	1430	4 (2)	Simpson HDU4-SDS2.5	-	-	wood screws 20 (d= 0.32 in) at 14 in. o/c; 52 fasteners in 2 rows.		
SW_N1A	Wood structural panels - sheathing	19/32	YES	1-1/2	10d 3	1860	7 (3)	Simpson HDU11-SDS2.5	10	36	SDWS log screw (d= 0.197 in) at 12 in. o/c; 58 fasteners in 2 rows.		
SW_N1B	Wood structural panels - sheathing	19/32	YES	1-1/2	10d 6	950	-	-	-	-	16d (d= 0.268 in) nails at 19 in. o/c; 39 fasteners in 2 rows.		
SW_N1C	Wood structural panels - sheathing	19/32	YES	1-1/2	10d 6	950	3 (1)	Simpson HDU4-SDS2.5	11	36	wood screws 20 (d= 0.32 in) at 19 in. o/c; 40 fasteners in 2 rows.		
SW_N1D	Wood structural panels - sheathing	19/32	YES	1-1/2	10d 3	1860	7 (3)	Simpson HDU11-SDS2.5	10	36	SDWS log screw (d= 0.197 in) at 12 in. o/c; 60 fasteners in 2 rows.		
SW_S3A	Wood structural panels - sheathing	19/32	YES	1-1/2	10d 6	950	2 (1)	Simpson HDU4-SDS2.5	-	-	wood screws 20 (d= 0.32 in) at 21 in. o/c; 36 fasteners in 2 rows.		
SW_S3B	Wood structural panels - sheathing	19/32	YES	1-1/2	10d 6	950	2 (1)	Simpson HDU4-SDS2.5	-	-	wood screws 20 (d= 0.32 in) at 21 in. o/c; 36 fasteners in 2 rows.		
SW_S2A	Wood structural panels - sheathing	19/32	YES	1-1/2	10d 3	1860	6 (2)	Simpson HDU11-SDS2.5	-	-	SDWS log screw (d= 0.197 in) at 13 in. o/c; 54 fasteners in 2 rows.		
SW_S2B	Wood structural panels - sheathing	19/32	YES	1-1/2	10d 3	1860	6 (2)	Simpson HDU11-SDS2.5	-	-	SDWS log screw (d= 0.197 in) at 13 in. o/c; 54 fasteners in 2 rows.		
SW_S1A	Wood structural panels - sheathing	19/32	YES	1-1/2	10d 2	2435	11 (4)	Simpson HD19	10	36	SDWS log screw (d= 0.197 in) at 8 in. o/c; 76 fasteners in 2 rows.		
SW_S1B	Wood structural panels - sheathing	19/32	YES	1-1/2	10d 2	2435	11 (4)	Simpson HD19	10	36	SDWS log screw (d= 0.197 in) at 8 in. o/c; 76 fasteners in 2 rows.		
SW_E3A	Wood structural panels - sheathing	19/32	YES	1-1/2	10d 4	1430	3 (1)	Simpson HDU4-SDS2.5	-	-	wood screws 20 (d= 0.32 in) at 16 in. o/c; 46 fasteners in 2 rows.		
SW_E3B	Wood structural panels - sheathing	3/8	NO	1-3/8	8d 6	560	-	-	-	-	16d (d= 0.268 in) nails at 12 in. o/c; 30 fasteners in 1 row.		
SW_E3C	Wood structural panels - sheathing	19/32	YES	1-1/2	10d 4	1430	6 (2)	Simpson HDU11-SDS2.5	-	-	SDWS log screw (d= 0.197 in) at 15 in. o/c; 32 fasteners in 2 rows.		
SW_E2A	Wood structural panels - sheathing	19/32	YES	1-1/2	10d 3	1860	7 (3)	Simpson HDU11-SDS2.5	-	-	SDWS log screw (d= 0.197 in) at 11 in. o/c; 64 fasteners in 2 rows.		
SW_E2B	Wood structural panels - sheathing	3/8	NO	1-3/8	8d 6	560	1 (1)	Simpson HDU4-SDS2.5	-	-	16d (d= 0.268 in) nails at 14 in. o/c; 51 fasteners in 2 rows.		
SW_E2C	Wood structural panels - sheathing	19/32	YES	1-1/2	10d 2	2435	11 (4)	Simpson HD19	-	-	SDWS log screw (d= 0.197 in) at 9 in. o/c; 54 fasteners in 2 rows.		
SW_E1A	Wood structural panels - sheathing	19/32	YES	1-1/2	10d 2	2435	13 (4)	Simpson HD19	7	36	SDWS log screw (d= 0.197 in) at 7 in. o/c; 64 fasteners in 2 rows.		
SW_E1B	Wood structural panels - sheathing	3/8	NO	1-3/8	8d 6	560	-	-	-	-	16d (d= 0.268 in) nails at 32 in. o/c; 12 fasteners in 1 row.		
SW_E1C	Wood structural panels - sheathing	19/32	YES	1-1/2	10d 2	2435	9 (3)	Simpson HD19	11	36	SDWS log screw (d= 0.197 in) at 10 in. o/c; 72 fasteners in 2 rows.		
SW_W3A	Wood structural panels - sheathing	19/32	YES	1-1/2	10d 4	1430	3 (1)	Simpson HDU4-SDS2.5	-	-	wood screws 20 (d= 0.32 in) at 16 in. o/c; 46 fasteners in 2 rows.		
SW_W3B	Wood structural panels - sheathing	3/8	NO	1-3/8	8d 6	560	-	-	-	-	16d (d= 0.268 in) nails at 12 in. o/c; 30 fasteners in 1 row.		
SW_W3C	Wood structural panels - sheathing	19/32	YES	1-1/2	10d 4	1430	6 (2)	Simpson HDU11-SDS2.5	-	-	SDWS log screw (d= 0.197 in) at 15 in. o/c; 32 fasteners in 2 rows.		
SW_W2A	Wood structural panels - sheathing	19/32	YES	1-1/2	10d 3	1860	7 (3)	Simpson HDU11-SDS2.5	-	-	SDWS log screw (d= 0.197 in) at 11 in. o/c; 64 fasteners in 2 rows.		
SW_W2B	Wood structural panels - sheathing	3/8	NO	1-3/8	8d 6	560	1 (1)	Simpson HDU4-SDS2.5	-	-	16d (d= 0.268 in) nails at 14 in. o/c; 51 fasteners in 2 rows.		
SW_W2C	Wood structural panels - sheathing	19/32	YES	1-1/2	10d 2	2435	11 (4)	Simpson HD19	-	-	SDWS log screw (d= 0.197 in) at 9 in. o/c; 54 fasteners in 2 rows.		
SW_W1A	Wood structural panels - sheathing	19/32	YES	1-1/2	10d 2	2435	13 (4)	Simpson HD19	9	30	SDWS log screw (d= 0.197 in) at 7 in. o/c; 64 fasteners in 2 rows.		
SW_W1B	Wood structural panels - sheathing	3/8	NO	1-3/8	8d 6	560	-	-	-	-	16d (d= 0.268 in) nails at 32 in. o/c; 12 fasteners in 1 row.		
SW_W1C	Wood structural panels - sheathing	19/32	YES	1-1/2	10d 2	2435	9 (3)	Simpson HD19	11	36	SDWS log screw (d= 0.197 in) at 10 in. o/c; 72 fasteners in 2 rows.		
SW_EC3A	Wood structural panels - sheathing	19/32	YES	1-1/2	10d 6	950	0	-	-	-	16d (d= 0.268 in) nails at 18 in. o/c; 42 fasteners in 2 rows.		
SW_EC3B	Wood structural panels - sheathing	3/8	NO	1-3/8	8d 6	560	-	-	-	-	16d (d= 0.268 in) nails at 60 in. o/c; 7 fasteners in 1 row.		
SW_EC3C	Wood structural panels - sheathing	19/32	YES	1-1/2	10d 6	950	3 (1)	Simpson HDU4-SDS2.5	-	-	wood screws 20 (d= 0.32 in) at 19 in. o/c; 40 fasteners in 2 rows.		
SW_EC2A	Wood structural panels - sheathing	19/32	YES	1-1/2	10d 3	1860	2 (1)	Simpson HDU4-SDS2.5	-	-	wood screws 20 (d= 0.32 in) at 21 in. o/c; 36 fasteners in 2 rows.		
SW_EC2B	Wood structural panels - sheathing	3/8	NO	1-3/8	8d 6	560	-	-	-	-	16d (d= 0.268 in) nails at 32 in. o/c; 12 fasteners in 1 row.		
SW_EC2C	Wood structural panels - sheathing	19/32	YES	1-1/2	10d 3	1860	6 (2)	Simpson HDU11-SDS2.5	-	-	SDWS log screw (d= 0.197 in) at 12 in. o/c; 58 fasteners in 2 rows.		
SW_EC1A	Wood structural panels - sheathing	19/32	YES	1-1/2	10d 2	2435	11 (4)	Simpson HD19	6	36	SDWS log screw (d= 0.197 in) at 9 in. o/c; 42 fasteners in 2 rows.		
SW_EC1B	Wood structural panels - sheathing	3/8	NO	1-3/8	8d 6	560	-	-	-	-	16d (d= 0.268 in) nails at 22 in. o/c; 17 fasteners in 1 row.		
SW_EC1C	Wood structural panels - sheathing	19/32	YES	1-1/2	10d 2	2435	11 (4)	Simpson HD19	11	36	SDWS log screw (d= 0.197 in) at 9 in. o/c; 82 fasteners in 2 rows.		
SW_WC3A	Wood structural panels - sheathing	19/32	YES	1-1/2	10d 6	950	0</						

6



Developer: W Capital Group  
r@wcapitalgroupre.com | 608.345.9848

• ■



**Architect:** OpeningDesign  
316 W Washington Ave | Suite 675  
Madison, WI 53703  
[info@openingdesign.com](mailto:info@openingdesign.com) | 773.425.6456



**General Contractor:** ROYAL CONSTRUCTION  
3 Greenway Street | Eau Claire, WI 54701  
[jim@royalbuilt.com](mailto:jim@royalbuilt.com) | 715-225-6377



**Civil Engineer:** CEDAR CORPORATION  
4 Wilson Avenue | Menomonie, WI 54751  
[win.ouim@cedarcorp.com](mailto:win.ouim@cedarcorp.com) | 715-235-9081




**Structural Engineer:** XC Structural Engineering  
Calle Apolonio Morales, 628036 Madrid,  
[ztato@xcengineering.xyz](mailto:ztato@xcengineering.xyz) | +34 610 56 26 37




**Structural Engineer of Record:** Ennovation  
29 Dale-Curtain Dr, McFarland, WI 53558




**mechanical Engineer:** HOVLAND'S HVAC  
E. Melby Street | Chippewa Falls, WI 54729  
[unsen@hovlands-inc.com](mailto:unsen@hovlands-inc.com) | 715.552.5595



**C O N S U L T A N T S   I N C .**




Aspen Commons | Ste 210 | Middleton, WI  
53562  
[novak@tailoredeng.com](mailto:novak@tailoredeng.com) | 608.209.7500



# CANNERY TRAIL RESIDENCES - 1750 N OXFORD AVE. - EAU CLAIRE, WI

## ELEVATIONS - FOUNDATION

**S300**



# CANNERY TRAIL RESIDENCES - 1750 N OXFORD AVE. - EAU CLAIRE, WI

6



tyler@wcapitalgroupre.com | 608.345.9848

○ |



**Architect:** OpeningDesign  
316 W Washington Ave | Suite 675  
Madison, WI 53703  
[ryan@openingdesign.com](mailto:ryan@openingdesign.com) | 773.425.6456



**General Contractor:** ROYAL CONSTRUCTION  
3653 Greenway Street | Eau Claire, WI 54701  
[jim@royalbuilt.com](mailto:jim@royalbuilt.com) | 715-225-6377




**Civil Engineer:** CEDAR CORPORATION  
604 Wilson Avenue | Menomonie, WI 54751  
[kevin.ouim@cedarcorp.com](mailto:kevin.ouim@cedarcorp.com) | 715-235-9081



**Structural Engineer:** XC Structural Engineering  
Calle Apolonio Morales, 628036 Madrid,  
[l.pereztato@xcenaeeringa.xyz](mailto:l.pereztato@xcenaeeringa.xyz) | +34 610 56 26 37



**Structural Engineer of Record:** Ennovation  
4729 Dale-Curtain Dr, McFarland, WI 53558





**ELECTRICAL  
CONSULTANTS INC.**

**Electrical Engineer:** PRISM DESIGN ELECTRICAL  
CONSULTANTS INC  
E8403 State Rd 85 | Mondovi, WI 54755  
[mlagren@prismdesign-electrical.com](mailto:mlagren@prismdesign-electrical.com) | 715 797 0602



**Plumbing Engineer:** TAILORED ENGINEERING  
1600 Aspen Commons | Ste 210 | Middleton, WI  
53562



# CANNERY TRAIL RESIDENCES - 1750 N OXFORD AVE. - EAU CLAIRE, WI

## ENLARGED PLANS

Date	Description
09/25/2019	<Progress>

**S400**