WOOD SHEAR WALL SCHEDULE

Shear wall ID	Sheathing material	Panel thickness (in)	Blocking	Minimum fastener penetration in framing member or blocking (in)	Fastener type and size	Panel edge fastener spacing (in)	Nominal unit shear capacity v_n (plf)	Hold-down anchor capacity (klp)	Number of bolts (1 in. diameter, 4 inch embedment depth)	Bolt spacing (in)	Bottom plate attachment (foundation) / Bottom plate attachment (floor to floor)
SW_N3A	Wood structural panels – sheathing	3/8	YES	1-3/8	8d	4	840	2	-	-	wood screws 20 (d= 0.32 in) at 25 in. o/c; 30 fasteners in 2 rows.
SW_N3B	Wood structural panels – sheathing	3/8	NO	1-3/8	8d	6	560	-	-	-	16d (d= 0.268 in) nails at 24 in. o/c; 16 fasteners in 1 row.
SW_N3C	Wood structural panels – sheathing	3/8	NO	1-3/8	8d	6	560	-	-	"	16d (d= 0.268 in) nails at 21 in. o/c; 35 fasteners in 2 rows.
SW_N3D	Wood structural panels – sheathing	3/8	YES	1-3/8	8d	4	840	2	-	-	wood screws 20 (d= 0.32 in) at 25 in. o/c; 30 fasteners in 2 rows.
SW_N2A	Wood structural panels – sheathing	19/32	YES	1-1/2	10d	4	1430	4	-	-	wood screws 20 (d= 0.32 in) at 14 in. o/c; 52 fasteners in 2 rows.
SW_N2B	Wood structural panels – sheathing	19/32	YES	1-1/2	10d	6	950	-	-	-	16d (d= 0.268 in) nails at 13 in. o/c; 28 fasteners in 1 row.
SW_N2C	Wood structural panels – sheathing	19/32	YES	1-1/2	10d	6	950	1	-	-	16d (d= 0.268 in) nails at 12 in. o/c; 59 fasteners in 2 rows.
SW_N2D	Wood structural panels – sheathing	19/32	YES	1-1/2	10d	4	1430	4	-	-	wood screws 20 (d= 0.32 in) at 14 in. o/c; 52 fasteners in 2 rows.
SW_N1A	Wood structural panels – sheathing	19/32	YES	1-1/2	10d	3	1860	7	10	36	SDWS log screw (d= 0.197 in) at 12 in. o/c; 58 fasteners in 2 rows.
SW_N1B	Wood structural panels – sheathing	19/32	YES	1-1/2	10d	6	950	-	11	36	16d (d= 0.268 in) nails at 19 in. o/c; 39 fasteners in 2 rows.
SW_N1C	Wood structural panels – sheathing	19/32	YES	1-1/2	10d	6	950	3	11	36	wood screws 20 (d= 0.32 in) at 19 in. o/c; 40 fasteners in 2 rows.
SW_N1D	Wood structural panels – sheathing	19/32	YES	1-1/2	10d	3	1860	7	10	36	SDWS log screw (d= 0.197 in) at 12 in. o/c; 60 fasteners in 2 rows.
SW_S3A	Wood structural panels – sheathing	19/32	YES	1-1/2	10d	6	950	2	-	-	wood screws 20 (d= 0.32 in) at 21 in. o/c; 36 fasteners in 2 rows.
SW_S3B	Wood structural panels – sheathing	19/32	YES	1-1/2	10d	6	950	2	-	-	wood screws 20 (d= 0.32 in) at 21 in. o/c; 36 fasteners in 2 rows.
SW_S2A	Wood structural panels – sheathing	19/32	YES	1-1/2	10d	3	1860	6	-	-	SDWS log screw (d= 0.197 in) at 13 in. o/c; 54 fasteners in 2 rows.
SW_S2B	Wood structural panels – sheathing	19/32	YES	1-1/2	10d	3	1860	6	-	-	SDWS log screw (d= 0.197 in) at 13 in. o/c; 54 fasteners in 2 rows.
SW_S1A	Wood structural panels – sheathing	19/32	YES	1-1/2	10d	2	2435	11	10	36	SDWS log screw (d= 0.197 in) at 8 in. o/c; 76 fasteners in 2 rows.
SW_S1B	Wood structural panels – sheathing	19/32	YES	1-1/2	10d	2	2435	11	10	36	SDWS log screw (d= 0.197 in) at 8 in. o/c; 76 fasteners in 2 rows.
SW_E3A	Wood structural panels – sheathing	19/32	YES	1-1/2	10d	4	1430	3	-	-	wood screws 20 (d= 0.32 in) at 16 in. o/c; 46 fasteners in 2 rows.
SW_E3B	Wood structural panels – sheathing	3/8	NO	1-3/8	8d	6	560	-	-	-	16d (d= 0.268 in) nails at 12 in. o/c; 30 fasteners in 1 row.
SW_E3C	Wood structural panels – sheathing	19/32	YES	1-1/2	10d	4	1430	6	-	-	SDWS log screw (d= 0.197 in) at 15 in. o/c; 32 fasteners in 2 rows.
SW_E2A	Wood structural panels – sheathing	19/32	YES	1-1/2	10d	3	1860	7	-	-	SDWS log screw (d= 0.197 in) at 11 in. o/c; 64 fasteners in 2 rows.
SW_E2B	Wood structural panels – sheathing	3/8	NO	1-3/8	8d	6	560	1	-	-	16d (d= 0.268 in) nails at 14 in. o/c; 51 fasteners in 2 rows.
SW_E2C	Wood structural panels – sheathing	19/32	YES	1-1/2	10d	2	2435	11	-	"	SDWS log screw (d= 0.197 in) at 9 in. o/c; 54 fasteners in 2 rows.
SW_E1A	Wood structural panels – sheathing	19/32	YES	1-1/2	10d	2	2435	13	7	36	SDWS log screw (d= 0.197 in) at 7 in. o/c; 64 fasteners in 2 rows.
SW_E1B	Wood structural panels – sheathing	3/8	NO	1-3/8	8d	6	560	-	11	36	16d (d= 0.268 in) nails at 32 in. o/c; 12 fasteners in 1 row.
SW_E1C	Wood structural panels – sheathing	19/32	YES	1-1/2	10d	2	2435	9	11	36	SDWS log screw (d= 0.197 in) at 10 in. o/c; 72 fasteners in 2 rows.
SW_W3A	Wood structural panels – sheathing	19/32	YES	1-1/2	10d	4	1430	3	-	-	wood screws 20 (d= 0.32 in) at 16 in. o/c; 46 fasteners in 2 rows.
SW_W3B	Wood structural panels – sheathing	3/8	NO	1-3/8	8d	6	560	-	-	-	16d (d= 0.268 in) nails at 12 in. o/c; 30 fasteners in 1 row.
SW_W3C	Wood structural panels – sheathing	19/32	YES	1-1/2	10d	4	1430	6	-	-	SDWS log screw (d= 0.197 in) at 15 in. o/c; 32 fasteners in 2 rows.
SW_W2A	Wood structural panels – sheathing	19/32	YES	1-1/2	10d	3	1860	7	-	-	SDWS log screw (d= 0.197 in) at 11 in. o/c; 64 fasteners in 2 rows.
SW_W2B	Wood structural panels – sheathing	3/8	NO	1-3/8	8d	6	560	1	-	-	16d (d= 0.268 in) nails at 14 in. o/c; 51 fasteners in 2 rows.
SW_W2C	Wood structural panels – sheathing	19/32	YES	1-1/2	10d	2	2435	11	-	-	SDWS log screw (d= 0.197 in) at 9 in. o/c; 54 fasteners in 2 rows.
SW_W1A	Wood structural panels – sheathing	19/32	YES	1-1/2	10d	2	2435	13	9	30	SDWS log screw (d= 0.197 in) at 7 in. o/c; 64 fasteners in 2 rows.
SW_W1B	Wood structural panels – sheathing	3/8	NO	1-3/8	8d	6	560	-	11	36	16d (d= 0.268 in) nails at 32 in. o/c; 12 fasteners in 1 row.
SW_W1C	Wood structural panels – sheathing	19/32	YES	1-1/2	10d	2	2435	9	11	36	SDWS log screw (d= 0.197 in) at 10 in. o/c; 72 fasteners in 2 rows.
SW_EC3A	Wood structural panels – sheathing	19/32	YES	1-1/2	10d	6	950	0	-	-	16d (d= 0.268 in) nails at 18 in. o/c; 42 fasteners in 2 rows.
SW_EC3B	Wood structural panels – sheathing	3/8	NO	1-3/8	8d	6	560	-	-	-	16d (d= 0.268 in) nails at 60 in. o/c; 7 fasteners in 1 row.
SW_EC3C	Wood structural panels – sheathing	19/32	YES	1-1/2	10d	6	950	3	-	-	wood screws 20 (d= 0.32 in) at 19 in. o/c; 40 fasteners in 2 rows.
SW_EC2A	Wood structural panels – sheathing	19/32	YES	1-1/2	10d	3	1860	2	-	-	wood screws 20 (d= 0.32 in) at 21 in. o/c; 36 fasteners in 2 rows.
SW_EC2B	Wood structural panels – sheathing	3/8	NO	1-3/8	8d	6	560	-	-	"	16d (d= 0.268 in) nails at 32 in. o/c; 12 fasteners in 1 row.
SW_EC2C	Wood structural panels – sheathing	19/32	YES	1-1/2	10d	3	1860	6	-	-	SDWS log screw (d= 0.197 in) at 12 in. o/c; 58 fasteners in 2 rows.
SW_EC1A	Wood structural panels – sheathing	19/32	YES	1-1/2	10d	2	2435	11	6	36	SDWS log screw (d= 0.197 in) at 9 in. o/c; 42 fasteners in 2 rows.
SW_EC1B	Wood structural panels – sheathing	3/8	NO	1-3/8	8d	6	560	-	11	36	16d (d= 0.268 in) nails at 22 in. o/c; 17 fasteners in 1 row.
SW_EC1C	Wood structural panels – sheathing	19/32	YES	1-1/2	10d	2	2435	11	11	36	SDWS log screw (d= 0.197 in) at 9 in. o/c; 82 fasteners in 2 rows.
SW_WC3A	Wood structural panels – sheathing	19/32	YES	1-1/2	10d	6	950	0	-	-	16d (d= 0.268 in) nails at 18 in. o/c; 42 fasteners in 2 rows.
SW_WC3B	Wood structural panels – sheathing	3/8	NO	1-3/8	8d	0	560	-	-	-	16d (d= 0.268 in) nails at 60 in. o/c; 7 fasteners in 1 row.
SW_WC3C	Wood structural panels – sheathing	19/32	YES	1-1/2	10d	6	950	3	-	-	wood screws 20 (d= 0.32 in) at 19 in. o/c; 40 fasteners in 2 rows.
SW_WC2A	Wood structural panels – sheathing	19/32	YES	1-1/2	10d	3	1860	2	-	-	wood screws 20 (d= 0.32 in) at 21 in. o/c; 36 fasteners in 2 rows.
SW_WC2B	Wood structural panels – sheathing	3/8	NO	1-3/8	8d	6	560	-	-	-	16d (d= 0.268 in) nails at 32 in. o/c; 12 fasteners in 1 row.
SW_WC2C	Wood structural panels – sheathing	19/32	YES	1-1/2	10d	3	1860	6	-	-	SDWS log screw (d= 0.197 in) at 12 in. o/c; 58 fasteners in 2 rows.
SW_WC1A	Wood structural panels – sheathing	19/32	YES	1-1/2	10d	2	2435	11	6	36	SDWS log screw (d= 0.197 in) at 9 in. o/c; 42 fasteners in 2 rows.
SW_WC1B	Wood structural panels – sheathing	3/8	NO	1-3/8	8d	6	560	-	11	36	16d (d= 0.268 in) nails at 22 in. o/c; 17 fasteners in 1 row.
SW_WC1C	Wood structural panels – sheathing	19/32	YES	1-1/2	10d	2	2435	11	11	36	SDWS log screw (d= 0.197 in) at 9 in. o/c; 82 fasteners in 2 rows.

WOOD FLOOR PLAN NOTES:

1. TYPICAL FLOOR CONSTRUCTION: 1" GYPSUM CONCRETE TOPPING (120 PCF MAXIMUM DENSITY) ON 3/4" TONGUE & GROOVE APA RATED WOOD FLOOR SHEATHING (PLYWOOD OR OSB). GLUE & SCREW FLOOR SHEATHING TO WOOD FLOOR STRUCTURE. SHEATHING TO BE ATTACHED TO FLOOR MEMBERS w/ SIMPSON STRONG-TIE STRONG-DRIVE WSNTL FASTENERS ON A 6"/6" o/c PATTERN (EDGE/FIELD).
3. TYPICAL STAIR LANDING CONSTRUCTION: 3/4" TONGUE & GROOVE APA RATED WOOD FLOOR SHEATHING (PLYWOOD OR OSB). GLUE & SCREW FLOOR SHEATHING TO WOOD FLOOR STRUCTURE. SHEATHING TO BE ATTACHED TO FLOOR MEMBERS w/ SIMPSON STRONG-TIE STRONG-DRIVE WSNTL FASTENERS ON A 6"/6" o/c PATTERN (EDGE/FIELD).
4. REFER TO ARCHITECTURAL DRAWINGS FOR STAIR FRAMING AND CONFIGURATION.
5. "HPX" DENOTES A WOOD HEADER/POST CONSTRUCTION. REFER TO WOOD HEADER/POST SCHEDULE FOR HEADER & POST DESIGNATION.
6. "WPX" DENOTES A WOOD POST. REFER TO WOOD HEADER/POST SCHEDULE FOR WOOD POST DESIGNATION ONLY.
7. ALL EXTERIOR WOOD STUD WALLS SHALL HAVE (1) LAYER OF 1/2" APA RATED SHEATHING (PLYWOOD OR OSB) ON THE EXTERIOR WALL FACE. REFER TO STANDARD DETAILS FOR TYPICAL BEARING WALL CONSTRUCTION AND SHEATHING ATTACHMENT. IF WALL IS NOT SPECIFICALLY DESIGNATED AS A SHEAR WALL, ATTACH SHEATHING TO WALL STUDS w/ 10d COMMON NAILS ON 6"/12" PATTERN (EDGES/FIELD). NAILS TO HAVE A MINIMUM PENETRATION INTO FRAMING MEMBER OF 1-1/2".
8. REFER TO TYPICAL WOOD WALL DETAILS FOR FRAMING AROUND AN OPENING THROUGH A WOOD STUD BEARING WALL. TYPICAL.
9. REFER TO EXTERIOR MISCELLANEOUS VENEER LINTEL SCHEDULE FOR ALL OPENINGS IN EXTERIOR VENEER.
10. ALL WOOD POSTS SHALL LINE UP FLOOR TO FLOOR DOWN TO THE TOP OF CONCRETE FOUNDATION WALL OR TOP OF PRECAST PLANK LEVEL. PROVIDE SOLID BLOCKING OF SAME SIZE AS POST IN TRUSS SPACES.
11. AT INTERIOR BEARING WALLS WHERE FLOOR TRUSSES BEAR ON WALL FROM EITHER SIDE, LAP TRUSSES AND BEAR EACH TRUSS FULL WIDTH OF WALL, TYPICAL.
12. PROVIDE 2x6 STRONGBACK BRIDGING FULL LENGTH OF BUILDING. NAIL TO VERTICAL TRUSS WEB w/ (3) 16d NAILS. PROVIDE BRIDGING EQUALLY SPACED ALONG TRUSS SPAN AS REQUIRED BY DESIGN.
13. AT EXTERIOR DECKS, PROVIDE COMPOSITE OR PRESSURE TREATED 5/4" WOOD DECKING.
14. ALL WOOD HEADERS SHOWN IN STUD WALLS ARE DROPPED HEADERS AND SHALL BE PLACED AT WALL OPENING HT UNLESS NOTED OTHERWISE. REFER TO ARCH DRAWINGS FOR OPENING HEIGHTS. ALL OTHER HEADERS SHALL BE FLUSH w/ BOTTOM OF FLOOR FRAMING, TYPICAL.
15. ALL VERTICAL MASONRY WALL REINFORCEMENT SHALL RUN CONTINUOUS THROUGH BOND BEAMS AND EXTEND FULL HEIGHT OF THE WALL. GROUT CORES SOLID AT ALL VERTICAL REINFORCING.
16. "MW-X" INDICATES MASONRY WALL REINFORCEMENT TYPE. REFER TO SCHEDULE FOR SIZE & SPACING.
17. GROUT MASONRY CORES SOLID AT ALL MECHANICAL ANCHOR LOCATIONS, TYPICAL.
18. (XXX'-XX") INDICATES THE TOP OF STEEL BEAM ELEVATION.



WOOD FLOOR FRAMING LEGEND

WOOD FRAMING HEADER/POST SCHEDULE

MARK	MATERIAL	WIDTH (in)	DEPTH (in)	BEARING	REMARKS
H3.1, H3.2, H3.3	LVL	1.75	14	P3.1 to P3.6	Third floor enclosed balconies. South facade.
H3.4 to H3.9	LVL	3.5	7.25	2x6 stud	Bearing stud width will match wall studs width.
H3.10	LVL	3.5	14	P3.7/CMU wall	Notched in CMU wall
H2.1 to H2.6	LVL	3.5	7.25	2x6 stud	Bearing stud width will match wall studs width.
H2.7	LVL	3.5	14	P3.7/CMU wall	Notched in CMU wall
H1.1 to H1.6	LVL	3.5	7.25	2x6 stud	Bearing stud width will match wall studs width.
H1.7	ASTM A992 steel	(2) C15x50	15	P1.1, P1.2, P1.3	
H1.8	ASTM A992 steel	W14x30	13.8	P1.3, P1.4	
H1.9	LVL	5.25	18	H17, bearing wall	
Facade headers (span < 3.5 feet)	LSL	<3.5	11.875	PFH	
Interior headers (span < 4.0 feet)	LSL	4	16	PIH	
Cantilevers					
C2,C5	LVL	2x5.25	14	SW_S1A and SW_S1B shear walls	
C1, C3, C4, C6	LVL	5.25	14	facade bearing walls	
C7, C8, C9, C10, C15	LVL	3.5	14	CMU wall	Bolted to masonry
C11, C12	LVL	5.25	14	facade bearing walls	
C13	LVL	5.25	18	SW_N2D shear wall	At shear wall bottom
C14	LVL	3.5	18	CMU wall	Bolted to masonry
C16	LVL	5.25	14	SW_N1A shear wall	
Posts					
P3.1 to p3.6	saw lumber	6	6		Third floor enclosed balconies. South facade.
P3.7	saw lumber	4	6		
P2.1	saw lumber	4	6		
P1.1, P1.2, P1.3	A500 Rect. HSS Grade B	HSS8x8x3/16			
P1.4	A500 Rect. HSS Grade B	HSS7x7x3/16			
P1.5	A500 Rect. HSS Grade B	HSS8x8x3/16			
PFH	A500 Rect. HSS Grade B	4	6		Facade header supports (span<3.5 feet)
PIH	A500 Rect. HSS Grade B	4	6		Interior header supports (span<4 feet)

I DID NOT SEE ANYTHING ON THE PLANS OR SCHEDULES ADDRESSES THE DOOR AND WINDOW HEADER SIZES; INCLUDING SHOULDER (JACK STUDS) STUDS OR KING STUD REQUIREMENTS

I DID NOT SEE ANYTHING ON THE PLANS OR SCHEDULES ADDRESSES THE LOAD BEARING STUD SCHEDULE INCLUDING TOP AND BOTTOM PLATE MATERIALS

INFORMATION REGARDING THE TRUSS ALIGNMENT WITH THE FLOOR TRUSSES AND JOISTS. DO YOU WANT TRUSSES AND STUDS TO ALIGN. THIS CAN BE AN ISSUE WITH TRUSS SPACING AT 24" O.C. AND STUDS AT 16" O.C

FOR THE SHEAR WALLS I DID NOT SEE ANYTHING ADDRESSING JAMB STUDS AND TIE DOWN INFORMATION/DETAILS AT THE FLOORS

CAPITAL GROUP
Developer: W Capital Group
tyler@wcapitalgroup.com | 608.345.9848

Architect: OpeningDesign
316 W Washington Ave | Suite 675
Madison, WI 53703
ryan@openingdesign.com | 773.425.6456

ROYAL CONSTRUCTION
General Contractor: ROYAL CONSTRUCTION
3653 Greenway Street | Eau Claire, WI 54701
jim@royalbuilt.com | 715-225-6377

Cedar corporation
Civil Engineer: CEDAR CORPORATION
604 Wilson Avenue | Menomonie, WI 54751
kevin.oium@cedarcorp.com | 715-235-9081

Structural Engineer: Structural Engineering
Calle Apolonio Morales, 628036 Madrid,
l.pereztato@xcengineering.xyz | +34 610 56 26 37

Ennovation Engineering Services Incorporated
Structural Engineer: Structural Engineering
4729 Dale-Curtain Dr, McFarland, WI 53558
kfrey@ennovationbuilt.com

Hovland's Heating · Ventilation · Air Conditioning Comfort for a lifetime.
Mechanical Engineer: HOVLAND'S HVAC
10954 E. Melby Street | Chippewa Falls, WI 54729
jhansen@hovlands-inc.com | 715.552.5595

Electrical Engineer: PRISM DESIGN ELECTRICAL CONSULTANS INC
E8403 State Rd 85 | Mondovi, WI 54755
bhalgren@prismdesign-electrical.com | 715.797.0602

TAILORED ENGINEERING
Plumbing Engineer: TAILORED ENGINEERING
1600 Aspen Commons | Ste 210 | Middleton, WI 53562
bnovak@tailoredeng.com | 608.209.7500

Date	Description
08.15.2019	75% CD Set

STRUCTURAL NOTES
CANNERY TRAIL RESIDENCES - 1750 N OXFORD AVE. - EAU CLAIRE, WI

S216

14/08/2019 16:51:10